Shot-noise limited measurement of sub-ppt birefringence phase shift in a high finesse cavity

Mathieu Durand, Jérôme Morville, D. Romanini

► To cite this version:

Mathieu Durand, Jérôme Morville, D. Romanini. Shot-noise limited measurement of sub-ppt birefringence phase shift in a high finesse cavity. *Physical Review A : Atomic, molecular, and optical physics* [1990-2015], 2010, 82, pp.031803(R). 10.1103/PhysRevA.82.031803 . hal-00563649

HAL Id: hal-00563649

<https://hal.science/hal-00563649>

Submitted on 7 Feb 2011

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Shot-noise limited measurement of sub-ppt birefringence phase shift in a high finesse cavity

Mathieu Durand and Jérôme Morville

*Laboratoire de Spectrométrie Ionique et Moléculaire,
Université Claude Bernard Lyon 1, 69622 Villeurbanne, France*

Daniele Romanini

Laboratoire de Spectrométrie Physique, Université Joseph Fourier, 38400 Saint Martin d'Hères, France

(Dated: June 10, 2010)

We report on a novel approach to high sensitivity anisotropy measurements using a high finesse cavity locked by optical feedback to a diode laser. We provide a simple and effective way to decouple the weak anisotropy of interest from the inherent mirror's birefringence whose drift may be identified as the key limiting parameter in cavity-based techniques. We demonstrate for the first time a shot-noise limited phase shift resolution up to now inaccessible in an optical cavity, readily achieving the state of the art level of 3×10^{-13} rad.

PACS numbers: 42.25.Lc, 07.60.Fs, 42.65.Hw, 42.50.Xa

Ultimate performance in the definition of the polarization state of light plays a key role in fundamental physical investigations. Detecting changes in a polarization state is widely used to study optical effects in crystals, biological systems or polymers. It has also demonstrated its ability to provide powerful tests of our understanding of light-matter interaction by the observation of magnetochiral birefringence [1], magnetoelectric Jones and linear birefringence [2, 3] or magnetoelectric Jones dichroism [4].

Today, observing the vacuum in a field acting on the polarization of light is one of the all-optical candidates to probe the photon-photon scattering, a fundamental feature of QED [5]. The 2 photons interaction through the creation of virtual electron-positron pairs yields to change of vacuum properties such the Kerr birefringence (induced by an transverse electric field), the Cotton-Mouton birefringence (induced by a transverse magnetic field) or the magnetoelectric birefringence (induced by transverse electric and magnetic fields) [6]. The strength of these nonlinear interactions scales with the QED correction of the Lagrangian $\frac{8\alpha^2\hbar^3}{45m^4c^5} \simeq 7 \times 10^{-30} \text{ m}^3\text{J}^{-1}$ where m is the electron mass, which yields to an induced phase shift in vacuum as weak as $3 \times 10^{-17} \text{ rad/T}^2\text{m}$ for optical wavelengths in the case of an external transverse magnetic field.

At such a low level, the contribution of new light scalar/pseudo-scalar particles such as axions that couple to photons should also manifest itself as a sizeable deviation from the QED prediction [7]. We may also recall that, even if finally attributed to instrumental artefact [8], the PVLAS collaboration aiming at the detection of the Vacuum Magnetic Birefringence [9], interpreted a thought-to-be signal as induced by intracavity axion production [10]. The interest in axions, providing the answer to the strong-CP problem, lies beyond Particle Physics and overlaps with Cosmology since such particle is con-

sidered as a serious dark matter candidate [11–14].

Probing polarization state changes using high sensitivity provided by a high finesse cavity is expected to be very promising. As noticed by Hall *et al.* [15] the ultimate shot-noise limited sensitivity, together with milliwatt optical power and state of the art magnetic fields (10 T), may resolve the QED predicted birefringence in vacuum, but up to now no cavity-based measurement was able to approach this fundamental limit. As pointed out by authors of advanced experiments [15, 16] this is due to the drift of the inherent residual birefringence of high reflectivity (HR) cavity mirrors. In this letter we present a novel approach unaffected by this problem and demonstrate for the first time a shot-noise limited phase shift resolution using an optical cavity, down to the state of the art level of 3.10^{-13} rad. We believe that this approach, which works well in the limit of very high cavity finesse, is a major step towards the measurement of effects like the vacuum birefringence.

Let us begin by considering that the effect of any intracavity anisotropy (mirror coating, Kerr or Cotton-Mouton birefringence, etc) is lifting the degeneracy of cavity polarization modes. For each transverse cavity mode two eigenvectors of polarization are then defined by different resonance frequencies. One way to access the intracavity anisotropy is therefore to measure the mode splitting [15, 17]. Hall *et al.* achieved a phase sensitivity of $10^{-9} \text{ rad}/\sqrt{\text{Hz}}$ per pass across a dynamic range of seven orders of magnitude using this method [15]. However, in the limit of weak mode splittings, with partial spectral overlap of the resonance profiles, another scheme is available. As in usual anisotropy measurements, the sample is sandwiched between crossed polarizers. The cavity is illuminated by 45° polarized light relative to its birefringence axes, which excites both polarization modes (approximately linear and orthogonal). The ratio between the crossed and the parallel signals from the

analyzer is then proportional to the square of the intracavity polarization change. This idea was first applied to detect small circular dichroisms induced in an atomic vapor by a polarized saturating field [18], and then generalized to different polarization effects (Faraday rotation, Cotton-Mouton effect, Kerr effect, circular dichroism) by the same group [19]. Although limited in dynamic range, this approach appears to provide the best performances in term of sensitivity [16].

In high finesse cavities, the first source of birefringence is HR mirror birefringence. Its phase shift per reflection, around 10^{-6} rad, is four orders of magnitude above the Kerr or the Cotton-Mouton birefringence induced in atomic gases for typical electric or magnetic field values under standard temperature and pressure (STP) conditions. Given the small round-trip mirror birefringence, the combined effect of both mirrors is equivalent (to the first order) to that of a single birefringent element. Its phase shift is bounded between the difference and the sum of the two mirror's phase shifts following a sinusoidal function of the angle between their birefringence axes. One way to eliminate the combined mirror birefringence would be to use mechanical stress to equalize their phase shifts and then orient the axes orthogonally. Then, by modulating the field inducing the gas birefringence and by adding outside the cavity a much larger ellipticity, the measurement dependency with the weak Kerr or Cotton-Mouton birefringence would be linearized and the useful signal would thus be enhanced [16]. However, the measurement becomes very sensitive to any change of the combined mirror birefringence, which may rapidly produce a large signal offset. In particular, thermal stress induced by intracavity optical field buildup has been highlighted [15] as the main limitation of the achievable sensitivity in mode splitting measurements. When using the crossed polarizers approach, mirror birefringence inhomogeneities combined with mechanical drift was suggested as the main noise source [16]. In this Letter we present a method to profitably exploit the mirror birefringence as a DC bias around which the weak induced ellipticity is modulated. This, as with an externally added ellipticity [16], linearizes the response to the useful signal, but above all it offers the unique advantage of a measurement free of mirror birefringence drift, with ideal averaging properties allowing to approach the ultimate limits. Indeed we demonstrate shot noise performance in an application to the measurement of Kerr effect in gases.

In order to fully benefit from the use of a high finesse cavity, it is necessary to lock the laser frequency to the exact center of a cavity mode. To reach this objective, different servo-locked configurations have been established [20, 21], that by Pound-Drever-Hall being the most popular. An attractive alternative is to take advantage of the frequency locking that occurs when a semiconductor laser is coupled to a high finesse cavity by a

FIG. 1: Experimental setup. ECDL, Extended Cavity Diode Laser; APP, anamorphic prism pairs; BS, beam splitter; PZT, piezoelectric transducer; P, polarizer; PD, amplified photodiode; Σ , summation; $\int$, integrator stage.

weak resonant optical feedback (OF) [22]. The simultaneous and drastic linewidth reduction is so effective that the optically locked diode laser emission may be regarded as monochromatic compared to the sub-kHz cavity resonance. Usually, to separate the OF from the direct reflection of the cavity input mirror, particular cavity and injection configurations (V-cavity or confocal cavity) are used [22]. As demonstrated by Morville *et al.* [23], a simpler axisymmetric two-mirror cavity configuration is exploitable: the cavity mirror birefringence allows resonant OF to be selected by its modified polarization. For an external-cavity diode laser (ECDL) in the Littrow configuration, an OF as a fraction of laser power in the range of 10^{-6} to a few 10^{-4} acts in the perturbative regime of the free-running laser and forces optical locking. This corresponds to a mirror birefringence value in the range of 10^{-7} to a few 10^{-6} assuming a finesse of 250 000 and a cavity transmission of 10%. Because of the OF, the ECDL frequency is no longer defined by its free-running value (depending on injection current and grating orientation), but mostly by the cavity resonance frequency and the OF phase. Thus, the laser frequency may be locked to the exact resonance center by servo controlling the OF phase and the injection current thanks to a modulation/demodulation scheme of the cavity transmission similar to the one proposed by Ohshima *et al.* [24].

A scheme of our experimental setup for gas-phase Kerr effect measurement is shown in Fig. 1. A 3 mW diode laser beam ($\lambda = 810$ nm) is first circularized by anamorphic prisms, then focused into a very high finesse cavity (250 000) in order to mode-match its TEM_{00} mode. The cavity of 52 cm long is formed by two mirrors of 50 cm of radius of curvature and by a glass tube in which the gas circulates as a laminar flow under STP conditions. The transverse electric field is generated by applying a voltage between two 47 cm long electrodes separated by 3 mm and inserted in the glass cell on both sides of the optical axis.

The polarizer P followed by the quarter-wave retarder

(a Fresnel rhomb) constitute an optical isolator against the direct cavity reflection which preserves the incident (circular) polarization. On the other hand, the resonant intracavity field is sensitive to the HR coating birefringence, and its polarization is appreciably different from the incident one [19, 23]. Light resonating inside the cavity is therefore partially returned through the isolator as the OF. The linearly polarized probe exploited in [19, 23] is here replaced by circularly polarized light. This makes the orientation of the mirrors and the electrodes independent of the laboratory frame and should reduce the optical-field-induced mirror birefringence [15].

The PC servo-control (dashed box) generates a reference modulation at frequency f which is applied to the laser frequency. By lock-in phase detection on the cavity transmission (photodiode PD1), an error signal is then generated to correct small resonance frequency drifts by acting on the OF phase through a PZT mounted mirror. The modulation frequency is limited by the cavity bandwidth (~ 1 kHz) and has been fixed to 800 Hz corresponding to the quietest spectral range. The diode laser current source and the mechanical environment are stable enough that correction of the OF phase alone is sufficient to keep the exact resonance for about one hour.

A flip-flop digital circuit is used to generate an in-phase square modulation at frequency $\Omega = f/2$ which is applied to the transverse electric field inducing the Kerr gas birefringence. A fraction ($\sim 4\%$) of the OF power feeding back from the cavity is deflected by a beamsplitter (BS) onto a low noise amplified photodiode (PD2): providing the birefringence signal. With respect to polarization analysis in transmission, this analysis in reflection allows to use a single set of high quality polarizer plus Fresnel rhomb which may be adjusted with high precision. The very critical tilt of the rhomb is optimized by setting the laser in scanning mode while looking at fringes from a thick etalon (not shown in the figure) and minimising the direct cavity reflection effects. The resulting extinction factor of this analyzer has been evaluated at better than 10^{-6} [25]. The PD2 output is then demodulated at Ω by a lock-in amplifier, whose output is digitized together with the DC components of PD1 and PD2 using a 16-bit data acquisition system (NI USB 6251). The Ω and DC levels of PD2 are then normalized by dividing out the DC component of the cavity transmission (PD1).

Finally, the total observable cavity anisotropy ρ , which is the ratio of the birefringence signal over the cavity transmission, can be written in a similar way to [19] as a sum of its DC and Ω components [25]:

$$\rho = \rho_{DC} + \rho_{\Omega} \cdot \cos(\Omega \cdot t) \quad (1)$$

FIG. 2: Kerr phase-shift resolution as a function of the DC bias. Dashed line: photon-noise limited, thick line: technical noise, black dot: our experiment. I_0 is the cavity transmitted power, S the photodiode responsivity and e the electron charge. Our parameters: $I_0 = 240 \mu\text{W}$, $F = 250\,000$ and $S = 0.5 \text{ A/W}$.

with

$$\rho_{DC} = \kappa \cdot \left(\frac{F}{2 \cdot \pi} \right)^2 \cdot \phi_M^2 \quad (2a)$$

$$\rho_{\Omega} = \frac{\kappa}{\sqrt{2}} \cdot \left(\frac{F}{\pi} \right)^2 \cdot \phi_M \phi_g \quad (2b)$$

where ϕ_g is the phase shift induced by the Kerr effect in the gas while ϕ_M is that associated with the cavity mirrors. The slow axes of these birefringences need to be aligned in order to maximize the useful signal, which is one of the optimization steps of our scheme. From these relations it is clear that measuring ρ_{DC} and ρ_{Ω} , together with the cavity finesse F and the BS reflection coefficient κ (which would be 1 in the case of direct polarization analysis at the cavity output) immediately yields the Kerr phase shift $\phi_g = \frac{\pi}{F} \cdot \frac{1}{\sqrt{2 \cdot \kappa}} \cdot \frac{\rho_{\Omega}}{\sqrt{\rho_{DC}}}$.

From Eq. (2b) it seems tempting to increase the DC bias through ϕ_M in order to improve the system resolution. However, each component of the ratio used to obtain ρ_{Ω} depends on the DC bias which leads to non trivial resolution dependency upon the DC bias value. Given that the ρ_{Ω} noise is mainly due to the weakest component, which is the small birefringence signal, the theoretical shot-noise limited resolution is illustrated in Fig. 2 (dashed line) as a function of the DC bias ϕ_M . It is approximately constant below π/F , but rapidly increases above this threshold due to the spectral splitting of the two eigenmodes which becomes larger than their linewidth. A complete analysis, however, needs to account for additional noise sources: photodetector noise (input noise of the current amplifier, thermal noise of the transimpedance gain, quantization noise at the digitalizer stage) and cavity transmission power fluctuations. The latter has two origins: the intrinsic diode laser power fluctuations and its residual frequency fluctuations. Nor-

FIG. 3: Nitrogen phase shift distributions for 1 s measurements at four electric field levels: (a) $E = 0$ V/m; (b) $E = 1.3 \times 10^3$ V/m (only the Gaussian fit is shown); (c) $E = 2.7 \times 10^3$ V/m; (d) $E = 6.4 \times 10^3$ V/m.

malized to the shot noise, the cavity transmission fluctuations are proportional to the birefringence signal while the photodetector noise is inversely proportional to it. This counterbalancing behavior leads to an optimum of resolution as a function of DC bias as shown in Fig. 2 (thick line). It is noteworthy that theory predicts a shot-noise-limited measurement provided that ϕ_M is around $0.1 \cdot \pi/F$. For a finesse of 250 000, this yields an optimal combined mirrors birefringence of 10^{-6} rad. Since the intrinsic coating birefringence of our mirrors is slightly greater than this value, a simple adjustment of their relative orientation allowed this condition to be achieved.

Fig. 3 presents the experimental Kerr phase shift distributions and their Gaussian fits for four settings of the modulated electric field. These distributions are obtained from measurements of ρ_Ω and ρ_{DC} after application of Eqs. (2a) and (2b) in the above optimal experimental conditions. The test gas used is nitrogen at near STP conditions. Integration time for an elementary phase shift measurement is one second, and each distribution is formed by several thousand points. The standard deviation of these distributions is 4×10^{-12} rad and defines the weakest value of Kerr anisotropy which can be resolved in one second. The experimental resolution agrees perfectly with the theoretical estimation including the contribution of the relevant noise sources shown in Fig. 2 (black dot). By increasing the integration time, the measured Allan variance of the phase shift shown Fig. 4 a) indicates that the resolution continues to drop with a white noise dependence to the value of 3×10^{-13} rad at 800 s, the maximal integration time currently limited by the laser frequency servo loop. This limit could be overcome by also controlling this drift as shown in a similar setup [25] wherein the exact resonance could be maintained for more than ten hours. In Fig. 4b), the simultaneously measured Allan variance of the HR mirror birefringence is shown and its evolution clearly illustrates that indeed the mirror birefringence value drifts as fast as $1/f^2$. This demonstrates the ability to decouple the two measurements.

In conclusion we have shown an effective way to cancel out the drift of the mirror birefringence in very weak

FIG. 4: Simultaneously measured Allan variance for a) the Kerr phase shift induced in nitrogen by $E = 9 \cdot 10^3$ V/m and b) the phase shift induced by the HR mirror. Error bars are from the statistical errors from the calculation of the Allan variance, which have the usual property of growing at longer integration times.

anisotropy measurement in a high finesse cavity. This new method has been applied to the detection of the Kerr effect in nitrogen and has demonstrated for the first time a resolution at the shot-noise limited level. The resolution of $3 \cdot 10^{-13}$ rad is three order of magnitude better than previously reported Kerr birefringence measurement. Finally this technique may constitute a major step towards the vacuum birefringence detection using a polarization state probe.

-
- [1] M. Vallet *et al.*, Phys. Rev. Lett. **87**, 183003 (2001).
 - [2] T. Roth and G. L. J. A. Rikken, Phys. Rev. Lett. **85**, 4478 (2000).
 - [3] T. Roth and G. L. J. A. Rikken, Phys. Rev. Lett. **88**, 063001 (2002).
 - [4] D. Budker and J. E. Stalnaker, Phys. Rev. Lett. **91**, 263901 (2003).
 - [5] E. Iacopini and E. Zavattini, Phys. Lett. B **85**, 151 (1979).
 - [6] G. L. J. A. Rikken and C. Rizzo, Phys. Rev. A **63**, 012107 (2000).
 - [7] L. Maiani, R. Petronzio, and E. Zavattini, Phys. Lett. B **175**, 359 (1986).
 - [8] E. Zavattini *et al.*, Phys. Rev. Lett. **99**, 129901(E) (2007).
 - [9] D. Bakalov *et al.*, Quantum Semiclass. Opt. **10**, 239 (1998).
 - [10] E. Zavattini *et al.*, Phys. Rev. Lett. **96**, 110406 (2006).
 - [11] S. Lamoreaux, Nature **441**, 31 (2006).
 - [12] A. C. Melissinos, Phys. Rev. Lett. **102**, 202001 (2009).
 - [13] S. Asztalos *et al.*, Phys. Rev. Lett. **104**, 041301 (2010).
 - [14] J. E. Kim and G. Carosi, Rev. Mod. Phys. **82**, 557 (2010).
 - [15] J. L. Hall, J. Ye, and L.-S. Ma, Phys. Rev. A **62**, 013815 (2000).
 - [16] M. Bregant *et al.*, Phys. Rev. D **78**, 032006 (2008).

- [17] G. Bailly, R. Thon, and C. Robilliard, *Rev. Sci. Instrum.* **81**, 033105 (2010).
- [18] A. L. Floch, J. M. Lenormand, and R. L. Naour, *Appl. Phys. B* **28**, 303 (1982).
- [19] M. Vallet *et al.*, *Opt. Commun.* **168**, 423 (1999).
- [20] R. W. P. Drever *et al.*, *Appl. Phys. B* **31**, 97 (1983).
- [21] T. W. Hänsch and B. Couillaud, *Opt. Commun.* **35**, 441 (1980).
- [22] B. Dahmani, L. Hollberg, and R. Drullinger, *Opt. Lett.* **12**, 876 (1987).
- [23] J. Morville and D. Romanini, *Appl. Phys. B* **74**, 495 (2002).
- [24] S. Ohshima and H. Schnatz, *J. Appl. Phys.* **71**, 3114 (1992).
- [25] M. Durand, Ph.D. thesis, Univ. Claude Bernard Lyon1, Lyon, France (2009), the manuscript (in French) can be downloaded from <http://tel.archives-ouvertes.fr/tel-00432201/fr>.