Fault isolation filter and sensors scheduling co-design for networked control systems

Mohamed Amine Sid, Samir Aberkane, Dominique Sauter, Didier Maquin

► To cite this version:

Mohamed Amine Sid, Samir Aberkane, Dominique Sauter, Didier Maquin. Fault isolation filter and sensors scheduling co-design for networked control systems. IEEE Multi-Conference on Systems and Control, MSC 2012, Oct 2012, Dubrovnik, Croatia. pp.CDROM. hal-00702667

HAL Id: hal-00702667

<https://hal.science/hal-00702667>

Submitted on 8 Apr 2014

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Fault isolation filter and sensors scheduling co-design for networked control systems

M. A. Sid*, S. Aberkane, D. Sauter and D. Maquin
Centre de recherche en automatique de Nancy (CRAN)
CNRS : UMR7039 Universit de Lorraine, France

*Mohamed-Amine.Sid@cran.uhp-nancy.fr

Abstract— This paper addresses the problem of multiple fault detection and isolation under communication constraints. More specifically, we consider the issue of sensor scheduling and fault isolation co-design under limited bandwidth capacity. The proposed isolation filter can be viewed as special structure of the traditional Kalman filter. The sensor scheduling sequence and the proposed filter are built in order to ensure the fault isolability property and noise effect minimization.

I. INTRODUCTION

The study of networked control systems (NCS) is receiving much importance in this recent years. This is mainly due to the several advantages resulting from using a shared real time network through which sensors, actuators and controllers communicate. Compared with classic fault detection (FD) systems, diagnosis over networks can reduce the system wiring, make the system easy to supervise, maintain and increase system agility... *etc.* Nevertheless, new constraints also arise when sensor information and control information are transmitted over a network. Such constraints can be categorized in five types [5], [6]:

- 1) Quantization errors in the signals transmitted over the network due to the finite word length of the packets;
- 2) Packet dropouts caused by the unreliability of the network;
- 3) Variable sampling/transmission intervals;
- 4) Variable communication delays;
- 5) Medium access constraints due to the limited bandwidth and sharing the network by multiple nodes and the fact that only one node is allowed to transmit its packet per transmission
- 6) Power consumption mainly in wireless networked control systems.

The presence of these network induced effects can degrade the performance of FD systems and implies more robust algorithms to this communication constraints.

It is clear that all of these constraints can exist in a communication network, but only some of them were fully considered in the literature, mainly the induced delay effect, packet loss and sampling influences. The delay issue is considered for example in [1], [2], [3], [5]. In [4], the authors deal with the design of robust FD systems for NCS

with large transfer delays, in which it is impossible to totally decouple the fault effects from unknown inputs. An adaptive Kalman filter is proposed in [7] to minimize the effects of the network induced delay on the residual signal. [16] considered the problematic of FD for NCS with both delayed inputs and measurements. In [19], [20], the FD system for NCSs with packet dropouts was designed by modeling the NCSs as a Markov jumping linear system (MJLS). The issue of FD with multiple network induced constraints has been considered for example [2], [14], [21]. Note that, to the best of the author knowledge, the issue of fault isolation in networked systems has not been fully investigated nowadays.

In this paper, we will address the problem of multiple fault detection and isolation under communication constraints. More specifically, we will consider medium access constraints. In this case, the shared network can only accommodates a limited number of simultaneous communications between components. In this context, it is only meaningful to specify a fault detection and isolation module in conjunction with a communication policy which indicates the times at which the plants sensors are to be granted medium access. This communication policy is known in the literature as communication sequence. The communication sequence specifies which sensors are able to send information to the detection filter at each time step. Hence, the considered problematic leads naturally to consider a *co-design* problematic. That is, the design of a fault detection and isolation filter in conjunction with sensor scheduling sequence. The sensor scheduling sequence and the proposed filter are built in order to ensure the fault isolability property and noise effect minimization.

The rest of the paper is organized as follow: section II gives the problem formulation. In section III, we will give our main results. The sensor scheduling problem will be discussed in section IV. A numerical example will be given in section V to illustrate the effectiveness of the proposed co-design method. Finally, we will provide some conclusions and some future research directions in section VI.

II. PROBLEM FORMULATION

Consider the remote system depicted in Fig.1. The state space representation of the plant under actuator and/or com-

Fig. 1. Remote filtering

ponent faults is given as follows:

$$\begin{cases} x_{k+1} = Ax_k + Bu_k + F\Upsilon_k + w_k \\ y_k = Cx_k + v_k \end{cases} \quad (1)$$

where $x_k \in \mathcal{R}^n$ is the state vector, u_k is the control input, $F = [f_1, f_2, \dots, f_q] \in \mathcal{R}^{n \times q}$ is the fault distribution matrix, $\Upsilon_k = [\Upsilon_k^1, \Upsilon_k^2, \dots, \Upsilon_k^q]^T \in \mathcal{R}^q$ is the fault vector and $y_k \in \mathcal{R}^m$ is the measurement signals vector. We assume that each component of the output vector y_i represents the sensor $i \in \{1, 2, \dots, m\}$. The initial state vector x_0 , process noise w_k and measurement noise v_k are uncorrelated, zero mean white Gaussian random processes with $x_0 \sim N(\bar{x}_0, \bar{P}_0)$, $w_k \sim N(0, W)$ and $v_k \sim N(0, I_m)$ respectively, where $\bar{P}_0, W$ and R are symmetric, positive definite matrices.

The main objective of this paper consists in the design of a fault detection and isolation filter that takes into account the communication constraints induced by the shared communication medium. More specifically, the communication constraint we deal with in this paper is referred to in the literature as a medium access constraint. In this case, the shared network can only accommodate a limited number of simultaneous communications between components. In this context, it is only meaningful to specify a filter in conjunction with a communication policy which indicates the times at which the plants sensors are to be granted medium access. This communication policy is known in the literature as communication sequence [13]. The communication sequence specifies which sensors are able to send information to the filter at each time step.

We will consider that the communication medium connecting the sensors and the residual generator has b output channels, with

$$1 \leq b \leq m \quad (2)$$

At any time, only b of the m sensors can access these channels to communicate with the residual generator while others must wait.

A. Communication sequence

Suppose that there are m different sensors and that at each time step k only $b < m$ are allowed to transmit messages. We then have $\sigma = C_m^b = \frac{m!}{b!(m-b)!}$ possible configurations.

Let us introduce the application: $\mu_k : Z \rightarrow \mathcal{M} = \{1, \dots, \sigma\}$, that determine at each sample time the corresponding sensors group index. We call this application the *switching pattern* for the sensor side. In Fig. 1, the signal $\tilde{y}_k \in \mathbb{R}^b$ is related to y_k by the following relation: $\tilde{y}_k = S(\mu_k)y_k$. The *switch matrix* $S(\mu_k) \in \mathbb{R}^{b \times m}$ is used to select the subset of measures that will be sent to the controller at each time step k . This subset is indexed by the values of the switching pattern μ_k . Considering the band limited effect, the *extended plant model* is described by

$$\begin{cases} x_{k+1} = Ax_k + Bu_k + F\Upsilon_k + w_k \\ \tilde{y}_k = \mathcal{C}_{\mu_k}x_k + \tilde{v}_k \end{cases} \quad (3)$$

where $\mathcal{C}_{\mu_k} = S(\mu_k)C$ and $\tilde{v}_k = S(\mu_k)v_k$.

B. Fault detection filter

The fault detection and isolation filter proposed in this paper is a modified version of the filter proposed in [22]. The state space representation of this filter is given by

$$\begin{cases} \hat{x}_{k+1} = A\hat{x}_k + Bu_k + K_k(\tilde{y}_k - \hat{y}_k) \\ \hat{y}_k = \mathcal{C}_{\mu_k}\hat{x}_k \end{cases} \quad (4)$$

where $\hat{x}_k$ and $\hat{y}_k$ denote the state and output estimation vectors, respectively.

It is important to note that in the context considered in this paper, both the filter gain K_k and the switching pattern $\mu(k)$ are design parameters.

III. MAIN RESULTS

In this section, we will introduce our main results. Before doing this, we will first recall some basic definitions that will be used in the sequel.

Definition 1. [22] The linear stochastic system (1) is said to have fault detectability indexes $\rho = \{\rho_1, \rho_2, \dots, \rho_q\}$ if $\rho_i = \min\{v : CA^{v-1}f_i \neq 0, v = 1, 2, \dots\}$.

Definition 2. The time-varying fault detectability matrix associated with the extended plant is defined as

$$D_{\mu_k} = \mathcal{C}_{\mu_k}\Psi \quad (5)$$

where

$$\Psi = [F_1, AF_2, \dots, A^{s-1}F_s] \quad (6)$$

Let $s = \max\{\rho_i, i = 1, 2, \dots, q\}$ be the maximum value of fault detectability indexes. We define $\tilde{\Upsilon}_k = [\tilde{\Upsilon}_k^1, \tilde{\Upsilon}_k^2, \dots, \tilde{\Upsilon}_k^s]^T$, $\tilde{F} = [\tilde{F}_1, \tilde{F}_2, \dots, \tilde{F}_s]$. Where $\tilde{\Upsilon}_i \in \mathcal{R}_i^q$ represents the part of faults having detectability index ρ_i and distribution matrix $\tilde{F}_i \in \mathcal{R}^{n, \rho_i}$. The extended system can be equivalently rewritten as

$$\begin{cases} x_{k+1} = Ax_k + Bu_k + \tilde{F}\tilde{\Upsilon}_k + w_k \\ \tilde{y}_k = \mathcal{C}_{\mu_k}x_k + \tilde{v}_k \end{cases}$$

Consider the filter given by (4). The estimation error $e_k = (x_k - \hat{x}_k)$ and the output residuals $q_k = (\tilde{y}_k - \hat{y}_k)$ dynamics are given by

$$\begin{cases} e_{k+1} &= (A - K_k \mathcal{C}_{\mu_k})e_k + \bar{F}\bar{Y}_k - K_k \tilde{v}_k + w_k, \\ q_k &= \mathcal{C}_{\mu_k} e_k + \tilde{v}_k \end{cases} \quad (7)$$

From superposition principle, it follows that for an additive faults occurring at time instant r (with $k > r + s$), the output residuals q_k can be expressed as:

$$q_k = \bar{q}_k + \bar{\rho}_{k,r} \begin{bmatrix} \bar{\eta}_r^T & \cdots & \bar{\eta}_{k-s}^T & \cdots & \bar{\eta}_{k-2}^T & \bar{\eta}_{k-1}^T \end{bmatrix}^T \quad (8)$$

with

$$\begin{aligned} \bar{\rho}_{k,r} &= \mathcal{C}_{\mu_k} \begin{bmatrix} G_{k-1,r}\bar{F} & \cdots & G_{k-1,k-(s-1)}\bar{F} & \cdots & G_{k-1}\bar{F} & \bar{F} \end{bmatrix} \\ G_{k-1,k-j} &= G_{k-1}G_{k-2}\cdots G_{k-j} \\ G_k &= (A - K_k \mathcal{C}_{\mu_k}) \end{aligned}$$

and $\bar{q}_k$ corresponds to the output residuals for the non faulty case.

Following similar arguments as in [22], the following result is derived.

Proposition 1. (Fault isolability condition) Under the condition $\text{rank}(\mathcal{C}_{\mu_k}) = q$, the solutions of the algebraic constraints: $(A - K_k \mathcal{C}_{\mu_k})\bar{\Psi} = 0$ can be parameterized as $K_k = \omega \Pi_{\mu_k} + \bar{K}_k \Sigma_{\mu_k}$ with

$$\Sigma_{\mu_k} = \alpha_{\mu_k} (I_m - D_{\mu_k} \Pi_{\mu_k}), \Pi_{\mu_k} = D_{\mu_k}^+ \text{ and } \omega = A\bar{\Psi} \quad (9)$$

where $\bar{K}_k \in \mathbb{R}^{n,b-q}$ is the reduced gain describing the remaining freedom of design, $D_{\mu_k}^+$ is the generalized inverse or pseudo-inverse of D_{μ_k} and α_{μ_k} is an arbitrary matrix determined so that matrix Σ_{μ_k} is of full rows rank.

Under these conditions, the residual q_k can then be expressed as

$$q_k = \bar{q}_k + D_{\mu_k} \begin{bmatrix} \bar{\eta}_{k-1}^{1T} & \bar{\eta}_{k-2}^{2T} & \cdots & \bar{\eta}_{k-s}^{sT} \end{bmatrix}^T \quad (10)$$

Remark 1. In the result given above, it is important to recall that the matrices $\mathcal{C}_k$ depend on the switching pattern μ_k . μ_k being a design parameter, it follows that the switching patterns that contains sequences which violate the rank condition in Proposition 1 have to be excluded. Hence, let us define the set of admissible switching patterns Ξ^* given by

$$\Xi^* = \{\mu_k : Z \rightarrow \mathcal{M}^* \subseteq \mathcal{M}\} \quad (11)$$

where $\mathcal{M}^*$ contains the indices corresponding to sensor configurations (traduced by corresponding matrices $\mathcal{C}_{\mu_k}$) that verify the rank condition $\text{rank}(\mathcal{C}_{\mu_k}) = q$.

Based on the development above, the fault isolation filter can be designed by computing the free parameter $\bar{K}_k$ so that the trace of covariance matrix $\bar{P}_k = E(\bar{e}_k \bar{e}_k^T)$ is minimized.

Proposition 2. (Fault isolation filter design) For a fixed switching pattern $\mu_k \in \Xi^*$, The proposed fault detection filter described by the following relations:

$$\hat{x}_{k+1} = A\hat{x}_k + Bu_k + \omega q_k^r + \bar{K}_{\mu_k} \gamma_k \quad (12)$$

$$\begin{aligned} \bar{P}_{k+1} &= (\bar{A}_{\mu_k} - \bar{K}_{\mu_k} \bar{C}_{\mu_k}) \bar{P}_k (\bar{A}_{\mu_k} - \bar{K}_{\mu_k} \bar{C}_{\mu_k})^T + \bar{K}_{\mu_k} \bar{V}_{\mu_k} \bar{K}_{\mu_k}^T + \bar{W}_{\mu_k} \\ &= \phi_{\mu_k}(\bar{P}_k) \end{aligned} \quad (13)$$

$$\bar{K}_{\mu_k} = \bar{A}_{\mu_k} + \bar{P}_k \bar{C}_{\mu_k}^T (\bar{C}_{\mu_k} \bar{P}_k \bar{C}_{\mu_k}^T + \bar{V}_{\mu_k})^{-1} \quad (14)$$

with

$$\bar{A}_{\mu_k} = A - \omega \Pi_{\mu_k} \mathcal{C}_{\mu_k} \quad (15)$$

$$\bar{C}_{\mu_k} = \Sigma_{\mu_k} \mathcal{C}_{\mu_k} \quad (16)$$

$$\bar{V}_{\mu_k} = \Sigma_{\mu_k} \Sigma_{\mu_k}^T, \quad (17)$$

$$\bar{W}_{\mu_k} = W + \omega \Pi_{\mu_k} \Pi_{\mu_k}^T \omega^T \quad (18)$$

where

$$\gamma_k = \Sigma_{\mu_k} (\tilde{y}_k - \mathcal{C}_{\mu_k} \hat{x}_k) \quad (19)$$

$$q_k^r = \Pi_{\mu_k} (\tilde{y}_k - \mathcal{C}_{\mu_k} \hat{x}_k) \quad (20)$$

have the following properties

- γ_k is decoupled from the faults
- q_k^r satisfy the relation

$$q_k^r = \Pi_{\mu_k} \bar{q}_k + \begin{bmatrix} \bar{\eta}_{k-1}^{1T} & \bar{\eta}_{k-2}^{2T} & \cdots & \bar{\eta}_{k-s}^{sT} \end{bmatrix}^T \quad (21)$$

Each component of the reduced output residual $q_k^r \in \mathbb{R}^q$ is sensitive to only one fault. Thus, it is used for the fault isolation.

Proof. The proof of this proposition follows similar arguments as for the proof of Theorem 3.1 in [22].

One can see that the evolution of the covariance matrix given by the Riccati equation (13) depends on the initial covariance matrix P_0 and the switching pattern given by μ_k . Hence, in addition to the isolability condition (see **Remark 1**), the scheduling strategy can be generated to optimize the covariance matrix evolution. This point will be further exposed in the next section.

IV. FINITE HORIZON OPTIMAL SCHEDULING

The problem addressed here is to choose which b sensors should operate at each time-step to minimize a function of the error covariance of the state estimation at each time step. Defining the scheduling strategy s_N is equivalent to define the values of μ_k for each $k = 0, \dots, N-1$, or equivalently $s_N = [\mu_0 \ \mu_1 \ \cdots \ \mu_{N-1}]$. Let $\mathcal{S}_N = \mathcal{M}^N$ be the set of all possible N -horizon scheduling strategies and let $\mathcal{S}_N^*$ be the set of all admissible N -horizon scheduling strategies (see **Remark 1**). The problem of optimal scheduling is formulated as

$$\min_{s_N \in \mathcal{S}_N^*} \mathcal{J}(s_N) \quad (22)$$

where

$$\mathcal{J}(s_N) = \sum_{i=1}^N \text{tr}(\bar{P}_i) = \sum_{i=0}^{N-1} \text{tr}(\phi_{\mu_i}(\bar{P}_i)) \text{ and } \mu_i = s_N(i).$$

The search algorithm:

Search algorithms are used for solving optimization problem (22). The trivial way of solution is to perform all possible scheduling cases. This enumerating method is only tractable for relatively short time horizons. It requires much resources in memory and computational time for longer estimation horizons. To overcome this limitation, we will use in this paper a pruning technique proposed in [18]. As showed in [18], the proposed algorithm can significantly reduce the computation complexity. Before proceeding, we will first recall some definitions to ease the reading of the paper.

Definition 3. (Characteristic sets) Let $\{\mathcal{H}_k\}_{k=0}^N$ be defined as the characteristic sets as they completely characterize the objective function. Each set is of the form $(\bar{P}, \gamma) \in \mathcal{A} \times \mathbb{R}_+$ ($\mathcal{A}$ being the set of all symmetric positive semidefinite matrices) and is generated recursively by

$$\mathcal{H}_{k+1} = \pi_{\mathcal{M}^*}(\mathcal{H}_k) \text{ from } \mathcal{H}_0 = \{(\bar{P}_0, \text{tr}(\bar{P}_0))\}$$

with

$$\pi_{\mathcal{M}^*}(\mathcal{H}) = \{(\phi_i(\bar{P}), \gamma + \text{tr}(\phi_i(\bar{P}))) : \forall i \in \mathcal{M}^*, \forall (\bar{P}, \gamma) \in \mathcal{H}\}$$

Note that the above definition differs from the original one in [18] by using $\mathcal{M}^*$ instead of $\mathcal{M}$. This is due to the fault isolability constraints in our context.

The sets $\mathcal{H}_k$, $k = 1, \dots, N$, express the covariance of the estimate and the objective cost at every time-step under every possible sensor schedule. Let $\mathcal{H}_k(i)$ be the i^{th} element of $\mathcal{H}_k$, $\bar{P}_k(i)$ and $\gamma_k(i)$ be the covariance matrix and objective cost corresponding to $\mathcal{H}_k(i)$, $\mathcal{M}^{*k}$ the set of all ordered sequences of admissible (in terms of isolability constraint) sensor schedules of length k , $\lambda(\bar{P}_k(i)) \in \mathcal{M}^{*k}$ be the ordered sensor schedule corresponding to the covariance matrix $\bar{P}_k(i)$ and λ^* be the optimal sensor schedule for the problem.

Definition 4. (Algebraic redundancy) [18] A pair $(\bar{P}, \gamma) \in \mathcal{H}$ is called algebraically redundant with respect to $\mathcal{H} \setminus \{(\bar{P}, \gamma)\}$, if there exist nonnegative constants $\{\alpha_i\}_{i=1}^{l-1}$ such that

$$\sum_{i=1}^{l-1} \alpha_i = 1 \text{ and } \begin{bmatrix} \bar{P} & 0 \\ 0 & \gamma \end{bmatrix} \geq \sum_{i=1}^{l-1} \alpha_i \begin{bmatrix} \bar{P}(i) & 0 \\ 0 & \gamma(i) \end{bmatrix}$$

where $l = \text{card}(\mathcal{H})$ and $\{(\bar{P}(i), \gamma(i))\}_{i=1}^{l-1}$ is an enumeration of $\mathcal{H} \setminus \{(\bar{P}, \gamma)\}$.

The following theorem provides a condition which characterizes the branches that can be pruned without eliminating the optimal solution of the sensor scheduling problem.

Theorem 1. [18] If the pair $(\bar{P}, \gamma) \in \mathcal{H}_k$ is algebraically redundant, then the branch and all of its descendants can be pruned without eliminating the optimal solution from the search tree.

We are now in position to describe the sensor scheduling algorithm. Before doing this, let us recall the notion of *equivalent subset* of the search tree. This one is defined as a set that still contains the optimal sensor schedule after pruning, the pruning being realized using Theorem 1. The computation of the equivalent subsets is done via **Algorithm 1** in [18]. The sensor scheduling algorithm is given as follows

Algorithm 2. Sensor scheduling for a finite horizon

- i) $\mathcal{H}_0 = \{(\bar{P}_0, \text{tr}(\bar{P}_0))\}$
- ii) for $k = 1, \dots, N$, do
 - $\mathcal{H}_k = \pi_{\mathcal{M}^*}(\mathcal{H}_{k-1})$
 - Perform Algorithm 1 in [18] with $\mathcal{H}_k$
- end for
- iii) $\lambda^* = \arg \min_{j \in \{1, \dots, \text{card}(\mathcal{H}_N)\}} \mathcal{J}(\lambda(\mathcal{H}_N(j)))$

Remark 2. In [18], the authors proposed a suboptimal solution which consists in approximating the search tree by pruning branches which are *numerically* redundant. To this end, they use the notion of ε -redundancy. As pointed out by the authors, the ε -redundancy concept can typically eliminate many more branches of the search tree leading to less complexity problems.

V. ILLUSTRATIVE EXAMPLE

We consider the following discrete-time system

$$A = \begin{bmatrix} 0.2 & 1 & 0 & 0.2 \\ 0 & 0.1 & 1 & 0.4 \\ 0 & 0 & 0.4 & 1 \\ 0 & 0 & 0 & 0.3 \end{bmatrix}, F = \begin{bmatrix} -1 & 1 \\ 1 & 0 \\ 0 & -1 \\ 1 & 1 \end{bmatrix}$$

$$C = \begin{bmatrix} 0 & 0.7 & 0 & 0 \\ 0 & 0 & 0.2 & 0 \\ 0 & 0 & 0 & 5 \end{bmatrix}, V = I$$

$$W = \begin{bmatrix} 0.89 & 0 & 0 & 0 \\ 0 & 0.5 & 0 & 0 \\ 0 & 0 & 0.95 & 0 \\ 0 & 0 & 0 & 0.58 \end{bmatrix}$$

The fault associated to the first column of the matrix F occurs at time instant $r_1 = 50$, with $\eta_k^1 = 10 \sin(0.1k)$, while the second fault (associated to the second column of F) occurs at time $r_2 = 120$ with $\eta_k^2 = 5$.

We use the suboptimal version of Algorithm 2 (see Remark 2) to compute the suboptimal sensor schedule. Figure 2 shows the reduced output residuals $q_k^r = [q_k^{r1} \ q_k^{r2}]^T$, in the case of using the suboptimal sensor schedule sequence and an arbitrary periodic schedule, respectively. One can

Fig. 2. Reduced output residuals

Fig. 3. $tr(\hat{P}_k)$

see that based on the proposed filter, one has the possibility to detect and isolate multiple faults.

Figure 3 shows the evolution of the trace of the covariance matrix of the estimation error for the two cases: suboptimal sensor schedule and arbitrary periodic schedule. One can see clearly the advantage and the performance of the proposed method.

VI. CONCLUSIONS

This paper addresses the problem of multiple fault detection and isolation under communication constraints. More specifically, we have considered the issue of sensor scheduling and fault isolation co-design under limited bandwidth capacity. We have proposed a detection and isolation filter in addition with an optimal (or suboptimal) sensor scheduling sequence that ensure the fault isolability property and noise effect minimization. Future directions of research will

include the infinite horizon case and extension to online scheduling techniques.

REFERENCES

- [1] Y. Wang; S. X. Ding; H. Ye; G. Wang, "A New Fault Detection Scheme for Networked Control Systems Subject to Uncertain Time-Varying Delay", IEEE Transactions on Signal Processing, vol. 56, no.10, pp.5258-5268, Oct. 2008
- [2] W. Li; Z. Zhu; S.X. Ding, "Fault detection design of networked control systems," IET Control Theory and Applications, vol.5, no.12, pp.1439-1449, August 2011
- [3] Y.Q. Wang; H. Ye; S.X. Ding; G.Z. Wang; D.H. Zhou,"Residual generation and evaluation of networked control systems subject to random packet dropout", Automatica, vol.45, no.10, pp. 2427-2434, 2009
- [4] Z. Mao; B. Jiang; P. Shi, " H_∞ fault detection filter design for networked control systems modeled by discrete Markovian jump systems," IET Control Theory and Applications, vol.1, no.5, pp.1336-1343, Sept. 2007
- [5] W.P.M.H. Heemels; A.R. Teel; N. Van de Wouw; D. Nesic, "Networked Control Systems With Communication Constraints: Tradeoffs Between Transmission Intervals, Delays and Performance", IEEE Transactions on Automatic Control, vol.55, no.8, pp.1781-1796, Aug.2010
- [6] W. Zhang; M.S. Branicky; S.M. Phillips, "Stability of networked control systems," IEEE Control Systems, vol.21, no.1, pp.84-99, Feb 2001
- [7] K. Chabir; D. Sauter; M. Ben Gayed; M.N. Abdelkrim, "Design of an adaptive Kalman filter for fault detection of Networked Control Systems", 16th Mediterranean Conference on Control and Automation, pp.1124-1129, 25-27 June 2008
- [8] Z. Ping; S.X. Ding, "Influence of Sampling Period on a Class of Optimal Fault-Detection Performance", IEEE Transactions on Automatic Control, vol.54, no.6, pp.1396-1402, June 2009
- [9] Z. Mao; B. Jiang; P. Shi, "Protocol and Fault Detection Design for Nonlinear Networked Control Systems", IEEE Transactions on Circuits and Systems, II Express Briefs, vol.56, no.3, pp.255-259, March 2009
- [10] S. Li; B. Xu, "Modified Fault Isolation Filter for Networked Control System with Send-on-delta Sampling," 30th Chinese Control Conference, pp.4145-4150, 22-24 July 2011
- [11] W. Zhang; H. Jianghai; J. Lian, "Quadratic optimal control of switched linear stochastic systems", Systems & Control Letters, Volume 59, Issue 11, Nov 2010
- [12] Z. Li; W. Wang; Y. Jiang, "Intelligent scheduling and optimisation for resource-constrained networks," IET Control Theory and Applications, vol.4, no.12, pp.2982-2992, December 2010
- [13] D. Hristu-Varsakelis, "Short-Period Communication and the Role of Zero-Order Holding in Networked Control Systems", IEEE Transactions on Automatic Control, vol.53, no.5, pp.1285-1290, June 2008
- [14] H. Song; L. Yu; W.A. Zhang, "Stabilisation of networked control systems with communication constraints and multiple distributed transmission delays," IET Control Theory and Applications, vol.3, no.10, pp.1307-1316, October 2009
- [15] F. Gomez-Estern; C. Canudas-de-Wit; F.R. Rubio, "Adaptive Delta Modulation in Networked Controlled Systems With bounded Disturbances". IEEE Transactions on Automatic Control, vol.56, no.1, pp.129-134, Jan. 2011
- [16] J. Li; G.Y. Tang, "Fault diagnosis for networked control systems with delayed measurements and inputs", IET Control Theory Applications, vol.4, no.6, pp.1047-1054, June 2010
- [17] L. Shi; C. Peng; J. Chen, "Sensor data scheduling for optimal state estimation with communication energy constraint". Automatica, Volume 47, Issue 8, Aug 2011
- [18] M.P. Vitus; W. Zhang; A. Abate; J. Hu; C.J. Tomlin, "On efficient sensor scheduling for linear dynamical systems". American Control Conference (ACC), pp.4833-4838, June 30 2010-July 2 2010
- [19] Y. Wang; H. Ye; S.X. Ding; G. Wang; D. Zhou, "Residual generation and evaluation of networked control systems subject to random packet dropout". Automatica, Volume 45, Issue 10, October 2009
- [20] P. Zhang; S.X. Ding; P.M. Frank; M. Sader, "Fault detection of networked control systems with missing measurements", Fifth Asian Control Conf., Melbourne, Australia, 2004, pp. 12581263

- [21] H.H. Nejad; D. Sauter; S. Aberkane; C. Aubrun, "Fault detection and isolation in networked control systems with access constraints and packet dropouts," 19th Mediterranean Conference on Control and Automation (MED), pp.461-466, 20-23 June 201
- [22] J.Y. Keller, "Fault isolation filter design for linear stochastic systems", Automatica, Volume 35, Issue 10, October 1999