



**HAL**  
open science

# Enhanced Aging Model for Supercapacitors taking into account Power Cycling: Application to the Sizing of an Energy Storage System in a Direct Wave Energy Converter

Thibaut Kovaltchouk, Bernard Multon, Hamid Ben Ahmed, Judicael Aubry, Pascal Venet

## ► To cite this version:

Thibaut Kovaltchouk, Bernard Multon, Hamid Ben Ahmed, Judicael Aubry, Pascal Venet. Enhanced Aging Model for Supercapacitors taking into account Power Cycling: Application to the Sizing of an Energy Storage System in a Direct Wave Energy Converter. *IEEE Transactions on Industry Applications*, 2015, 51 (3), pp.2405 - 2414. 10.1109/TIA.2014.2369817 . hal-01160366

**HAL Id: hal-01160366**

**<https://hal.science/hal-01160366>**

Submitted on 5 Jun 2015

**HAL** is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

# Enhanced Aging Model for Supercapacitors taking into account Power Cycling: Application to the Sizing of an Energy Storage System in a Direct Wave Energy Converter

Thibaut Kovaltchouk, Bernard Multon, Hamid Ben Ahmed, Judicaël Aubry and Pascal Venet

**Abstract**—This paper proposes an original model for supercapacitors that takes into account both calendar aging and cycling aging. A state variable is used to quantify the State-Of-Aging. This model is based on a series of recent experiments conducted in various research laboratories on the same technology (Maxwell Technology) and serves to represent the degradation of Equivalent Series Resistance and capacitance. This model is particularly useful in an aging-aware life cycle cost analysis. We show that an accurate aging model is critical to the design of an Energy Storage System that optimizes the economic life cycle cost. Such an optimization is especially applicable for smoothing in offshore systems like Direct Wave Energy Converters, which require both cost reduction and high reliability. The influence of an aging model in the sizing process is investigated towards the end of this paper.

**Index Terms**—aging, design optimization, direct wave energy converter, energy storage, irregular waves, life estimation, life cycle costing, power quality, power smoothing, supercapacitors.

## I. NOMENCLATURE

$C$	Capacitance of the supercapacitor [F]
$C_0$	Initial value of $C$ [F]
$C_{ESS}$	Capacitance of the Energy Storage System [F]
$C_{ESS0}$	Initial value of $C_{ESS}$ [F]
$C_{life}$	Life-cycle cost [€]
$E_{rated}$	Energy rating of the Energy Storage System [J]

T. Kovaltchouk, B. Multon, H. Ben Ahmed are with the SATIE laboratory, UMR CNRS 8029, ENS Rennes, UEB, av. Robert Schuman, 35170 Bruz, France e-mail: thibaut.kovaltchouk@ens-rennes.fr.

J. Aubry is with Équipe mécatronique, ESTACA, Campus de Laval, rue Georges Charpak, 53061 Laval, France.

P. Venet is with AMPERE UMR CNRS 5005, Université Lyon 1, Université de Lyon, 43 bd du 11 Novembre, 69100 Villeurbanne, France.

Manuscript received May 27, 2014; revised September 6, 2014; approved for publication in the IEEE TRANSACTIONS ON INDUSTRY APPLICATIONS by the Power Electronics Devices and Components Committee. Paper 2014-PEDCC-0488 presented at the 9th International Conference on Ecological Vehicles and Renewable Energies (EVER 2014), Monaco, March 25-27.

© 2015 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, including reprinting/republishing this material for advertising or promotional purposes, collecting new collected works for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works

Kovaltchouk, T.; Multon, B.; Ben Ahmed, H.; Aubry, J.; Venet, P., "Enhanced Aging Model for Supercapacitors Taking Into Account Power Cycling: Application to the Sizing of an Energy Storage System in a Direct Wave Energy Converter," Industry Applications, IEEE Transactions on , vol.51, no.3, pp.2405,2414, May-June 2015

DOI: 10.1109/TIA.2014.2369817

$ESR$	Equivalent Series Resistance of the supercapacitor [ $\Omega$ ]
$ESR_0$	Initial value of $ESR$ [ $\Omega$ ]
$ESR_{ESS}$	Equivalent Series Resistance of the Energy Storage System [ $\Omega$ ]
$ESR_{ESS0}$	Initial value of $ESR_{ESS}$ [ $\Omega$ ]
$E_{Max}$	Maximum value of $E_{Sto}$ with the smoothing control [J]
$E_{Min}$	Minimum value of $E_{Sto}$ with the smoothing control [J]
$\tilde{E}_{Min}$	Estimation of $E_{Min}$ with $V_{ESSMin}$ for the smoothing control [J]
$E_{Sto}$	Energy stored in the Energy Storage System [J]
$\tilde{E}_{Sto}$	Estimation of $E_{Sto}$ with $V_{ESS}$ for the smoothing control [J]
$H_s$	Significant wave height of a sea-state (2.5 m here) [m]
$I$	Current flowing through the cell [A]
$I_{ESS}$	Current flowing through the Energy Storage System [A]
$\tilde{I}_{RMS}$	Estimation of the root mean square current flowing through the cell [A]
$K$	Constant parameter for the aging law [-]
$k_{acc}^{(i)}$	Acceleration factor between calendar aging model computations and test results [-]
$\tilde{k}_{RMS}$	Constant parameter for the aging law [ $s \cdot V^{-1}$ ]
$\tilde{N}_{Cells}$	Equivalent number of BCAP3000 in the Energy Storage System [-]
$\tilde{N}_{Replace}$	Number of Energy Storage System replacements during the useful life of the entire system [-]
$P_{lt}$	Long-term flicker severity [-]
$P_{Grid}$	Grid power (after smoothing) [W]
$P_{Loss}$	Power losses in the Energy Storage System [W]
$P_{Max}$	Maximum value of $P_{Prod}$ (1.1 MW here) [W]
$P_{Prod}$	Production power (before smoothing) [W]
$P_{Sto}$	Stored power in the Energy Storage System [W]
$R_{thca}$	Thermal resistance between the case and the ambient temperature [ $K \cdot W^{-1}$ ]
$SoA$	State-of-Aging: state variable corresponding to

	health: equal to 0 at the beginning and reaches 1 when $C = 0.8 \times C_0$ or $ESR = 2 \times ESR_0$ [-]
$T_{life}(V, \theta_c)$	Lifetime with a terminal voltage of the capacity $V$ and case temperature $\theta_c$ (calendar tests) [h]
$T_{life}^{ref}$	Reference lifetime for a reference case condition $T_{life}^{ref} = T_{life}(V^{ref}, \theta_c^{ref})$ , a constant parameter for the aging model [h]
$T_{life}^{(i)}$	Lifetime measured for experiment $i$ [h]
$\hat{T}_{life}^{(i)}$	Estimation thanks to a calendar aging model of the lifetime for experiment $i$ [h]
$T_p$	Peak period of a sea-state (8 s here) [s]
$V$	Capacitive voltage of the cell [V]
$V^{ref}$	Reference value for $V$ (2.7 V here) [V]
$V_0$	Constant parameter for the aging law [V]
$V_{ESS}$	Capacitive voltage of the Energy Storage System [V]
$V_{ESSMax}$	Maximum value of $V_{ESS}$ with the smoothing control [V]
$V_{ESSMin}$	Minimum value of $V_{ESS}$ with the smoothing control [V]
$V_{ESS Rated}$	Rated capacitive voltage of the Energy Storage System [V]
$V_{Max}$	Maximum value of $V$ with the smoothing control (2.5 V here) [V]
$V_{Min}$	Minimum value of $V$ with the smoothing control [V]
$V_{Rated}$	Rated capacitive voltage of the cell (2.7 V here) [V]
$\Delta SoA$	Aging resolution for the lifetime estimations (1 % here) [-]
$\theta_0$	Constant parameter for the aging law [K]
$\theta_a$	Ambient temperature [°C]
$\theta_c$	Case temperature of the cell [°C]
$\theta_c^{ref}$	Reference value for $\theta_c$ (65 °C) [°C]
$\tau_{filter}$	Time constant of the filter used to compute $\hat{I}_{RMS}$ [s]
$\tau_{Sto}$	Time constant of the smoothing filter applied by the Energy Storage System with its energy policy [s]

## II. INTRODUCTION

Supercapacitors, also known as Electric Double-Layer Capacitors, ultracapacitors or Electrochemical Double-Layer Capacitors (EDLC), cannot compete with batteries in terms of energy density, yet their much longer cycling life, power density and operating temperature range make them an energy storage option to be seriously considered in many applications, whether mobile [1] or stationary [2], [3].

To ensure enduring performance over its lifetime, supercapacitor reliability must be quantified by means of accelerated aging tests and/or application of an aging model. Many laboratories and manufacturers have conducted calendar and cycling aging tests [4]–[11].

The present paper uses these tests in order to build an advanced aging model for supercapacitors. This model must take into account power cycling effects and not only calendar

effect, like in [5]–[8]. Indeed, these effects can be important in high-cycling applications, as will be seen in our application.

The model proposed here is similar to the model presented in [10], but improvements have been made: first, cycling experiments from an other laboratory are used to improve the fitting of the model with different cell sizes [6]; next a state variable is used to quantify the State-of-Aging, similar to the State-of-Health used in battery models [12]; finally the electrical parameters depend on this aging variable in order to take into account the degradation of the electrical performances.

These improvements allow the use of this model in an aging-aware sizing process, like in [13], and, to the best of our knowledge, the proposed model is the only model that can be used in a sizing process and take into account the power cycling.

To show an example of such a process, this model is then implemented to minimize the life cycle cost of an Energy Storage System (ESS) for a Direct Wave Energy Converter (DWEC) and compared to the application of conventional aging models which doesn't take into account power cycling aging.

Power fluctuation minimization is one of the keys for developing direct electricity production from fluctuating renewable energies, especially in the case of direct wave energy conversion, where the output power is strongly pulsating. The problem herein is to satisfy a power quality constraint, e.g. the flicker [14], so as to ensure grid integration thanks to supercapacitor energy storage systems.

In our case, the studied DWEC is the SEAREV [15] [16] (see Fig. 1); it consists of a completely enclosed floating buoy with an embedded pendular wheel. Excitation forces from the swell on the buoy generate relative motion between the float and the wheel; this oscillating motion is then damped in order to produce energy. Damping is ensured by a three-phase Permanent Magnet Synchronous Generator (PMSG) connected to a back-to-back converter. The PMSG is a surface permanent magnet, low-speed high-torque machine with 124 pole pairs; its design has been optimized to minimize the per-kWh production cost [16]. The back-to-back converter is composed of: a Pulse Width Modulation (PWM) inverter connected to the PMSG, for controlling damping; a PWM-inverter connected to the grid, for regulating the DC bus voltage and supplying the grid with power; and a chopper connected to the supercapacitors, for smoothing electrical power output (see Fig. 1).

## III. ENHANCED AGING MODEL

### A. Electrical model

The electrical model chosen to represent a supercapacitor is the series connection of a capacitance  $C$  and resistance  $ESR$  (Equivalent Series Resistance). The temperature dependence of these parameters has not been considered herein. More complex models exist, yet this simplified one is sufficient to compute losses with the level of precision required for a sizing process. Moreover, these electrical parameters are given in the manufacturer's data-sheet

TABLE I  
COMPARISONS OF LIFETIME EXPECTANCY ACCORDING TO MANUFACTURER AND LABORATORY MODELS FOR MAXWELL TECHNOLOGY CELLS (RATED CAPACITANCE: 350 F, 2600 F OR 3000 F)

	$\theta_0$	$V_0$	$T_{life}^{ref} = T_{life}(2.7\text{ V}, 65^\circ\text{C})$	$T_{life}(2.7\text{ V}, 25^\circ\text{C})$	$T_{life}(0\text{ V}, 70^\circ\text{C})$
Maxwell data-sheets [4]	-	-	1500 h	10 years	4 years
LUSAC [5]	8.7 K	-	1550 h	4.3 years*	-
IMS [6]	-	100 mV	1910 h	-	-
RWTH [7]	10 K	100 mV	1500 h	2.7 years*	$16 \times 10^6$ years*
PSI [8]	10 K	95 mV	1450 h	2.6 years*	$42 \times 10^6$ years*
Ampère [9]	8.6 K	87 mV	1500 h	4.4 years*	$260 \times 10^6$ years*

\*These values correspond to extrapolations.




Fig. 1. Main diagram of the SEAREV Direct Wave Energy Converter with a Supercapacitor Power Smoothing System

### B. Classical Eyring's Law

The classical aging model for supercapacitors is Eyring's Law, which yields the lifetime [17]. For our purposes, the lifetime is considered when the capacity  $C$  is reduced by 20% or the resistance  $ESR$  is doubled. Calendar tests are performed to determine the parameters of this equation. Voltage and temperature remain constant over time in these tests.

$$T_{life}(V, \theta_c) = T_{life}^{ref} \times \exp\left(\ln(2) \frac{\theta_c^{ref} - \theta_c}{\theta_0}\right) \times \exp\left(\ln(2) \frac{V^{ref} - V}{V_0}\right) \quad (1)$$

where  $T_{life}$  is the lifetime in hours,  $\theta_c$  the case temperature, and  $V$  the voltage across the component.  $\theta_0$  and  $V_0$  are the respective decreases in temperature and voltage necessary to double the lifetime.  $T_{life}^{ref}$  is the lifetime, in hours, for a case temperature of  $\theta_c^{ref}$  (here, the maximum operating temperature,  $65^\circ\text{C}$ ) with a voltage of  $V^{ref}$  (here, the rated voltage, 2.7 V).

We deduce from (1) a dynamical aging model which leads to the same result. The hypothesis introduced at this time is that degradation rate is solely dependent on  $V$  and  $\theta_c$ . With Equation (1), we have defined a variable State-of-Aging  $SoA$  to represent the aging over time. The value is 0 initially and reaches 1 at the end of the lifetime:

$$\frac{dSoA}{dt}(V, \theta_c) = \frac{1}{T_{life}(V, \theta_c)} \quad (2)$$

In this paper, we will consider the Maxwell technology. Several laboratories have conducted calendar tests and deduced

the corresponding parameters [4]–[9]. Some results are shown in TABLE I.

### C. Accounting for high-temperature, low-voltage aging

We notice that there is a huge difference between models extrapolations and data-sheet value in the last column of TABLE I which represent a low-voltage high-temperature case. The model presented in (2) cannot explain aging when the supercapacitor is fully discharged and the storage temperature is high. So we modify the equation in order to model this phenomenon.

$$\frac{dSoA}{dt} = \frac{1}{T_{life}^{ref}} \times \exp\left(\ln(2) \frac{\theta_c - \theta_c^{ref}}{\theta_0}\right) \times \left[ \exp\left(\ln(2) \frac{V - V^{ref}}{V_0}\right) + K \right] \quad (3)$$

where  $K$  is a dimensionless constant that replaces the voltage term whenever voltage is low. This adjustment is arbitrary and must be considered with caution: others low-voltage experiments are necessary to confirm or rebut this model. We can notice that this adjustment has few impact on high-cycling applications because the voltage is rarely very low in these cases, but this could have important effects for other applications.

A total of 23 calendar experiments from [4]–[10] have been examined for the purpose of optimizing the four parameters ( $T_{life}^{ref}$ ,  $\theta_0$ ,  $V_0$  and  $K$ ). Regression is applied on  $\log(T_{life})$ . Results are shown in TABLE II. The comparison between model and experimental outputs is presented in Fig. 2. The coefficient of determination ( $R^2$ ) is equal to 96% (on a logarithmic scale), which means that 96% of the variations in lifetime for these 23 tests can be explained by our model.

TABLE II  
PARAMETERS FOR THE CALENDAR AGING MODEL AND LIFETIME EXPECTANCY

$\theta_0$	7.7 K
$V_0$	89 mV
$K$	$29 \times 10^{-3}$
$T_{life}^{ref}$	1470 h
$V^{ref}$	2.7 V
$\theta_c^{ref}$	$65^\circ\text{C}$
$T_{life}(2.7\text{ V}, 25^\circ\text{C})$	5.9 years
$T_{life}(0\text{ V}, 70^\circ\text{C})$	3.7 years




Fig. 2. Calendar lifetime as a function of voltage for four case temperatures (70°C, 65°C, 50°C and 30°C): Comparison between the model and experiments from [4]–[10]

#### D. Degradation of electrical parameters as a function of aging

The two electrical parameters  $C$  and  $ESR$  change with age. Two distinct phases are observed: an initial burning phase, and a linear phase [18]. We propose herein to model just the linear phase with the capacitance and conductance (i.e. the inverse of  $ESR$ ) parameters, which decrease linearly with the State-of-Aging variable  $SoA$  (in proportion with time at constant voltage and temperature). Similar hypotheses have been previously adopted in [7] [16].

$$C = C_0 \times (0.95 - 0.15 SoA) \quad (4)$$

$$ESR^{-1} = ESR_0^{-1} \times (1 - 0.3 SoA) \quad (5)$$

where  $C_0$  and  $ESR_0$  are respectively the initial values of  $C$  and  $ESR$ .

Four experiments were used to derive this law. The level of agreement between experiment and model is shown in Fig. 3. The quick burning phase at the time of startup is not taken into account, hence the capacity changes instantaneously from 100% to 95% at  $SoA = 0$ . The ratio between the speeds with which relative resistance and relative capacitance decrease is equal to 2 for our model. This ratio lies between 1.5 and 2 in [7] and equals 2.5 in [16].




Fig. 3. Evolution of electrical parameters input into the electrical model in the (Relative conductance - Relative capacitance) plane: Comparison between model and experiments [6], [9], [10], [19].

#### E. Thermal model

The self-heating effect is very important because the degradation rate accelerates exponentially with respect to temperature. The thermal time constant of the cell (around 1900 s for the BCAP3000 cell) is considered herein to be high enough relative to the time cycle (typically a few tens of seconds) so as to neglect case temperature variations. In order to determine the case temperature of the elements, we thus introduce a simple static thermal model:

$$\theta_c = \theta_a + R_{thca} \langle ESR \times I(t)^2 \rangle \quad (6)$$

where  $\theta_a$  is the ambient temperature,  $R_{thca}$  the thermal resistance of the element, and  $I$  the current flowing through the component. The operator  $\langle . \rangle$  represents the average of a quantity over a cycle duration. Thus, during a cycle, the case temperature  $\theta_c$  is considered as a constant.

#### F. Calendar aging model applied to cycling tests

Given the small number of fully-documented cycling aging tests in the literature and aging mechanisms that differ somewhat from one manufacturer to the other, the experiments used to build this model have been conducted with similar supercapacitor cells (2600 F and 3000 F from Maxwell Technologies). The 8 experiments referred to in this paper have all been conducted in two French laboratories: Ampère Laboratory [9] [10] and IMS Laboratory [6] [19].

With the above calendar model (equations (3), (4), (5) and (6)), aging during the cycling test can be simulated and compared with the experiments results.

We can see in equation (6) that the rate of aging depends on the case temperature, considered here as a constant during a cycling test, but also on the voltage. So the rate of aging is computed with the same step-size than the voltage, i.e. 0.1 s.

During cycling tests, the waveforms of current  $I(t)$  and voltage  $V(t)$  depend on aging due to their dependence on electrical parameters  $C$  and  $ESR$ . Consequently, the RMS (Root Mean Square) current, losses and self-heating all depend on the State-of-Aging.

To predict a lifetime, it is necessary to compute cycling with different States-of-Aging. The method used in this paper is a simple adaptive step-size resolution with an aging resolution of  $\Delta SoA = 1\%$ ; it is illustrated in Fig. 4. The mean rate of aging is computed using a time window corresponding to the cycle duration.

#### G. Aging dependence in an RMS current

Let's begin by comparing these simulations with the results obtained from the 8 experiments. It should be noted that the recovery during stoppage has not been considered, as recommended by the manufacturer [20].

The residuals are too important to consider that the model used is sufficient: the results from the cycling tests are between 20 and 200 smaller than lifetime from simulations (see Fig. 5). Let's define an accelerator factor  $k_{acc}^{(i)}$  for each experiment  $i$  that represents the acceleration due to the cycling test as




Fig. 4. Method for computing lifetime  $T_{life}$  with the evolution in capacitance  $C$  and  $ESR$  using a simple adaptive step-size method (with  $\Delta SoA = 1\%$ )

compared to an equivalent calendar aging. This accelerator is defined by:

$$k_{acc}^{(i)} = \frac{\tilde{T}_{life}^{(i)}}{T_{life}^{(i)}} \quad (7)$$

where  $\tilde{T}_{life}^{(i)}$  is the theoretical result obtained with the calendar aging model, and  $T_{life}^{(i)}$  is the result for experiment  $i$ .

Figure 5 shows the 8 values for  $k_{acc}^{(i)}$  as a function of the relative RMS current ( $I_{RMS}/C_0$ ): Clearly,  $k_{acc}^{(i)}$  is dependent on this value. The RMS current dependency has already been investigated in [10].




Fig. 5. Acceleration of aging vs. calendar model results as a function of relative RMS current across the component at a 50% State-of-Aging

An enhanced model is thus being proposed here, as inspired

by [10]:

$$\frac{dSoA}{dt} = \frac{1}{T_{life}^{ref}} \times \exp\left(\ln(2) \frac{\theta_c - \theta_c^{ref}}{\theta_0}\right) \times \left[ \exp\left(\ln(2) \frac{V - V^{ref}}{V_0}\right) + K \right] \times \exp\left(k_{RMS} \frac{\tilde{I}_{RMS}}{C_0}\right) \quad (8)$$

where  $\tilde{I}_{RMS}$  is an evaluation of the RMS current flowing through the component.

The computation of  $\tilde{I}_{RMS}$  involves a three-step procedure:

- 1) Compute the square current (9),
- 2) Then, filter it with a first-order low-pass filter and time constant  $\tau_{filter}$  (10),
- 3) Finally, take the root square of the result (11).

$$x(t) = I(t)^2 \quad (9)$$

$$Y(s) = \frac{X(s)}{1 + \tau_{filter}s} \quad (10)$$

$$\tilde{I}_{RMS}(t) = \sqrt{y(t)} \quad (11)$$

where  $X(s)$  and  $Y(s)$  are respectively the Laplace transform of  $x(t)$  and  $y(t)$ , two intermediate variables expressed in a unit of  $A^2$ .

The two additional parameters  $k_{RMS}$  and  $\tau_{filter}$  are optimized to fit the experimental data. All these model parameters are listed in TABLE III. The comparison between data recorded and model output is shown in Fig. 6.

The coefficient of determination (71%) is less than that for the calendar model, which gives rise to several explanations:

- Model imperfection (including the choice of  $\tilde{I}_{RMS}$  as an explanatory parameter)
- A precise knowledge of experimental parameters: ambient temperature, cycle definition, evolution in electrical parameters during testing
- Component variability.

TABLE III  
PARAMETERS INPUT INTO THE CYCLING AGING MODEL

$\theta_0$	7.7 K
$V_0$	89 mV
$K$	$29 \times 10^{-3}$
$T_{life}^{ref}$	1470 h
$V^{ref}$	2.7 V
$\theta^{ref}$	65 °C
$k_{RMS}$	$68 \text{ s} \cdot \text{V}^{-1}$
$\tau_{filter}$	45 s

#### IV. SIZING OF AN ENERGY STORAGE SYSTEM

Now we have a model to compute the rate of aging and the degradation of electrical parameters, we can use this model to optimize the size of an Energy Storage System (ESS) in order to minimize the life cycle cost of this system. In the chosen application, an energy storage is added to a Direct






Fig. 6. Ratio between lifetime derived by the tests and cycling model predictions as a function of relative RMS current across the supercapacitor at a 50% State-of-Aging

Wave Energy Converter in order to respect the flicker, which is a voltage-quality constraint in grid.

The different step of the life cycle cost analysis are represented in Fig. 7. First, we must have an hydro-mechanical model to compute the power production profile. Then, the energy management must be optimized in order to respect the flicker constraint. After that, a thermal and electrical simulation is used to compute voltage, temperature and current profiles. Finally, the aging model with the degradation of the electrical parameters presented in chapter III is used to quantify the cost.

We present now each part of this analysis.

#### A. Hydro-mechanical simulation and hypotheses

The hydro-mechanical part of the model (developed in [21] [22]) is used to compute both speed and torque at the Permanent Magnet Synchronous Generator shaft based on the sea-state and a damping law.

A sea-state is described by its significant wave height  $H_s$  and peak wave period  $T_p$ ; this state provides important information on the power source, such as wind speed for wind turbines. To simplify the presentation of the results, let's consider herein a unique sea-state, adopted as the design sea-state:  $H_s = 2.5$  m and  $T_p = 8$  s. The power profile used for our analysis is shown in Fig. 8. It is 30 minutes long to be representative of the sea-state.

A more complete study takes into account all the encountered sea states and their probability of appearance, like in [23]. Each sea-state requires an hydro-mechanical simulation, an optimized energy management and a thermal and electrical simulation, but the methodology stays the same.

The energy produced with this sea-state (average power: 190 kW) over 13 years corresponds to the energy produced by the system over 20 years at the Yeu Island site (France).




Fig. 7. Life cycle cost analysis with hydro-mechanical, electrical, thermal and aging simulations in DWEC case




Fig. 8. Power production profile (3 time scales) in the case of sea-state:  $H_s = 2.5$  m;  $T_p = 8$  s

#### B. Energetic Model of the Energy Storage System

The Energy Storage System (ESS), as described in Fig. 1, will be composed of  $N_{Cells}$  Maxwell BCAP3000 reference cells ( $C_0 = 3000$  F,  $V_{Rated} = 2.7$  V,  $ESR_0 = 0.29$  m $\Omega$  and  $R_{thca} = 3.2$  K $\cdot$ W $^{-1}$ ). The series and parallel connections of these elements allow adjusting the rated voltage and total size of the ESS. All cells are assumed to be identical and to endure the same conditions. We can notice that balancing circuits are typically used to compensate voltage deviation between the cells [17], and thus help to make this assumption.

This model is then the same whether for the entire system or an individual element, i.e.: a capacity  $C_{ESS}$  in series with an equivalent series resistance  $ESR_{ESS}$ . The voltage at the capacity terminal is denoted  $V_{ESS}$  (capacitive voltage), while the current flowing through the system is denoted  $I_{ESS}$ .

The rated system energy  $E_{Rated}$  is directly proportional to the number of cells and the rated energy of the reference cell:

$$E_{Rated} = \frac{1}{2} C_{ESS0} V_{ESS\ Rated}^2 \quad (12)$$

$$= N_{Cells} \frac{1}{2} C_0 V_{Rated}^2 \quad (13)$$

The energy stored in the ESS  $E_{Sto}$  is also easy to compute for each time step:

$$E_{Sto} = \frac{1}{2} C_{ESS} V_{ESS}^2 \quad (14)$$

$$= N_{Cells} \frac{1}{2} C V^2 \quad (15)$$

The system losses  $P_{Loss}$  depend on the system state variable ( $E_{Sto}$ ) and parameters ( $C_{ESS}$  and  $ESR_{ESS}$ ) but also on the power stored in the ESS  $P_{Sto}$ :

$$P_{Loss} = C_{ESS} ESR_{ESS} \times \frac{P_{Sto}^2}{2 E_{Sto}} \quad (16)$$

$$= C ESR \times \frac{P_{Sto}^2}{2 E_{Sto}} \quad (17)$$

### C. Objective and energy management of the Energy Storage System

The Energy Storage System is necessary to satisfy the flicker constraint. The maximum long-term flicker severity  $P_{lt}$  for a wave farm is 0.25, according to French rules for an HTA Grid (distribution grid between 1 kV and 50 kV, typically 20 kV). The principle is illustrated in Fig. 9.




Fig. 9. Power smoothing with Energy Storage to satisfy a flicker constraint

We are assuming herein that the flicker severity for a Wave Energy Converter farm can be computed under the same hypothesis as for the wind turbine farm in [24]. The total long-term flicker severity  $P_{lt}$  for a farm with  $N_i$  converters and the same individual long-term severity  $P_{lti}$  is assumed to equal:  $P_{lt} = \sqrt{N_i} \times P_{lti}$ .

Let's now assume a situation with 10 productive units; then, the limit for each unit would be:  $0.25/\sqrt{10} = 0.079$ . This constraint will be used to size the individual Energy Storage System (ESS), which is controlled individually.

Let's also assume that the grid has a short-circuit apparent power of 50 MVA and a grid impedance angle of  $60^\circ$ , both of which are typical values for a weak medium-voltage grid. In order to limit grid current, the grid reactive power production is set to:  $Q_{Grid} = 0$ .

The energy policy requires information on the energy in the ESS; it is considered that this energy can be deduced from the value of capacitive voltage  $V_{ESS}$ , with no information on the  $SoA$  or value of  $C_{ESS}$ :

$$\tilde{E}_{Sto} = \frac{1}{2} 0.8 C_{ESS0} V_{ESS}^2 \quad (18)$$

where  $\tilde{E}_{Sto}$  is the estimated energy in the storage system when considering the capacitive voltage. It is important to note that this value is always underestimated whenever  $SoA < 1$ .

The production power  $P_{Prod}$  is filtered using the Energy Storage System via a very simple control strategy: grid power  $P_{Grid}$  has a linear relationship with the estimated energy contained in the ESS:

$$P_{Grid} = \frac{\tilde{E}_{Sto} - \tilde{E}_{Min}}{\tau_{Sto}} \quad (19)$$

$$P_{Grid} = \frac{0.8 C_{ESS0}}{C_{ESS}} \frac{E_{Sto} - E_{Min}}{\tau_{Sto}} \quad (20)$$

where  $\tilde{E}_{Min}$  is the minimum estimated energy in the ESS,  $E_{Min}$  the minimum energy in the ESS, and  $\tau_{Sto}$  a time constant used to define the energy policy.

Storage power  $P_{Sto}$  can therefore be expressed as:

$$\frac{dSoA}{dt} = P_{Sto} \quad (21)$$

$$= P_{Prod} - \frac{0.8 C_{ESS0}}{C_{ESS}} \frac{E_{Sto} - E_{Min}}{\tau_{Sto}} \quad (22)$$

This control strategy ensures energy limitations whenever power production  $P_{Prod}$  is bounded, and such is the case here with  $0 \leq P_{Prod} \leq P_{Max} = 1.1$  MW. These limitations are:

$$E_{Min} = \frac{C_{ESS}}{0.8 C_{ESS0}} \tilde{E}_{Min} \quad (23)$$

$$= \frac{1}{2} C_{ESS} V_{ESSMin}^2 \quad (24)$$

$$E_{Max} = E_{Min} + \frac{C_{ESS}}{0.8 C_{ESS0}} \tau_{Sto} P_{Max} \quad (25)$$

$$= \frac{1}{2} C_{ESS} \left( V_{ESSMin}^2 + \frac{2 \tau_{Sto} P_{Max}}{0.8 C_{ESS0}} \right) \quad (26)$$

$$= \frac{1}{2} C_{ESS} V_{ESSMax}^2 \quad (27)$$

where  $E_{Min}$  and  $E_{Max}$  are the boundaries for energy (proportional to  $C_{ESS}$ , hence dependent on  $SoA$ ), and  $V_{ESSMin}$  and  $V_{ESSMax}$  the boundaries for capacity voltage (independent of  $C_{ESS}$  and therefore of  $SoA$ ). To limit aging, the maximum voltage allowed is limited:  $V_{Max} = 2.5$  V.

The Laplace transformation of Equation (22) yields a relationship between power production and grid power as follows:

$$\frac{P_{Grid}(s)}{P_{Prod}(s)} = \frac{1}{1 + \tau'_{Sto} s} \quad (28)$$

where  $P_{Grid}(s)$  and  $P_{Prod}(s)$  are respectively the Laplace transform of  $P_{Grid}(t)$  and  $P_{Prod}(t)$ , and  $\tau'_{Sto} = (C_{ESS})/(0.8 C_{ESS0}) \tau_{Sto}$  is the time constant of the equivalent filter. Production is then smoothed by a first-order low-pass filter.

As could have been predicted, the filter functions better with a new ESS (filter constant time =  $\tau_{Sto}/0.8$ ) rather than with an



older ESS (at the end of ESS life, filter constant time =  $\tau_{Sto}$ ). The variable  $\tau_{Sto}$  is chosen to satisfy the constraint limit in the worst case.

#### D. Electrical and thermal models

Current, voltage and case temperature must be computed for an individual cell thanks the global variable  $E_{Sto}$ ,  $P_{Sto}$  and  $P_{Loss}$ . The static thermal hypothesis has the same justification as in subsection III-E.

$$V = \sqrt{\frac{2 E_{Sto}}{N_{Cells} C}} \quad (29)$$

$$I = \frac{P_{Sto}}{V} \quad (30)$$

$$\theta_c = \theta_a + R_{thca} \frac{P_{Loss}}{N_{Cells}} < \quad (31)$$

Here, the expected ambient temperature is 20 °C.

Figure 10 shows, for the same production, the effect of aging on both the grid power and voltage. Let's remark that the difference between grid power in both cases is small. Each time simulation lasts 30 minutes and is repeated 100 times in order to compute the lifetime, as explained in Fig. 4 and shown in Fig. 11. We can notice in this example that the cells voltage are always relatively high (over 2 V). So the adjustment of the model for low-voltage aging (developed in chapter III section III-C) has very few effect on this application.




Fig. 10. Power production, grid power, stored energy and ESS voltage vs. time with the two extreme aging values for an energy rating of 2 kWh - Extracted from a 30-minute simulation

The risk of thermal runaway is present at the end of the lifetime due to the fact that self-heating is proportional to

$ESR$  and therefore its increase tends to accelerate. Figure 11 shows aging  $SoA$ , the evolution in losses, degradation rate and replacements vs. time. Let's point out that the acceleration in aging near the end of the lifetime is not very significant. A good approximation for computing losses and degradation rate seems to calculate these values at system midlife ( $SoA = 0.5$ ).




Fig. 11. State of Aging: average loss of power degradation rate and replacements vs. time for an energy rating of 2 kWh ( $N_{replace} = 2.38$  during the 13 years)

#### E. Life cycle model

The goal of this model is to determine the sizing that minimizes total lifetime cost; this cost takes into account the price of losses using a feed-in tariff set at 0.15 €/kWh, with the initial investment costing 20 k€/kWh (corresponding to approximately 20 €/kF according to this technology) and a proportional replacement cost that considers the price of the new storage system.

$$C_{life}(k\text{€}) = 20 (1 + N_{replace}) E_{Rated}(kWh) + 0.15 \cdot 10^{-3} P_{loss}(kW) 8766(h) 13(\text{years}) \quad (32)$$

where  $N_{replace}$  is the number of replacements and has been assumed here as a continuous variable to improve the precision of results. In reality, this number is obviously an integer.

This model does not take into account either the intervention cost or production losses during failure, both of which can be considerable in an offshore system.

For each energy rating, the evolution in losses and degradation is computed as described in the previous sections and illustrated by Fig. 7, thus yielding a computation of the life cycle cost. Results are shown in Fig. 12. The red zone corresponds to insufficient energy with respect to the flicker constraint, while the dark green zone indicates the initial investment, the light green zone the replacement cost, and the yellow zone the ESS losses. The first figure corresponds to no use of an aging model, while the second figure displays a conventional aging model (without current) as well as the enhanced model proposed herein. Let's focus on two specific energy rating values: the economic optimum with the conventional model (marked with a circle) and then with the enhanced model (marked with a cross).




Fig. 12. Lifetime cost as a function of energy rating with three models: no consideration of aging, use of the conventional calendar model, and use of our enhanced model that takes current into account. The economic optimum with a conventional aging model is marked by a circle and the optimum obtained with the enhanced model is marked by a cross.

The minimum sizing to satisfy the flicker constraint depends on the sea-state, yet in all proposed sizing configurations, the energy amount is quite sufficient.

Let's note the importance of the aging model in the sizing process: without the enhanced model, the choice involves, above all else, a trade-off between losses and investment; on the other hand, with the enhanced model, the choice becomes a trade-off between investment and replacement. Furthermore, the optimum with the enhanced model corresponds to a sizing whose lifetime equals the useful life (13 years here):  $N_{replace}$  is cancelled out exactly with the optimum.

The final life cycle cost of around 90 k€ seems to be admissible, representing an impact on energy costs of 4 € per MWh.

The robustness of the third optimum with the model is much higher than for the other two. Yet many uncertainties still remain: the aging model (naturally) with its set of input parameters, e.g. ambient temperature, in addition to the behavior of balancing circuits [25], component variability, maximum voltage or even thermal exchanges into the ESS [26]. Clearly, the larger the ESS, the more robust the life cycle cost. A decision must be made (in terms of sizing selection): decision theory provides the typical tool to help quantify the robustness of a decision and the acceptable level of risk [27].

To further decrease this cost, several solutions can be studied: switching technologies, a greater use of supercapacitors (even if the capacity drop exceeds 20%), or improved energy management [28].

## V. CONCLUSION

The enhanced aging model presented in this paper has been built on the basis of several experiments conducted by the manufacturer or other laboratories. This model is able to explain cycling test results by taking into account the dependence of current on aging rate, in addition to the classical self-heating behavior.

This model was then applied to size an energy storage system for a Direct Wave Energy Converter. To satisfy the flicker constraint, it proved essential to smooth the power production, which led to the possibility of grid compliance. A simple energy management law was adopted in order to filter the power while ensuring a limited voltage range. In this case, the number of cycles turned out to be very high. This study has been compared with other hypotheses regarding aging. Results have demonstrated the advantages of an enhanced model for such a study, especially in the case of high power fluctuations and reliability requirements, which would be typical for DWEC. The purpose of sizing was to minimize life cycle costs. A proposed formulation of this cost takes into account investment, replacement and losses.

This aging-aware life cycle analysis with our enhanced model has proven its importance in this case, but can also be used in other applications, such as smart grids, electric or hybrid vehicles.

This study is only part of the design of a complete electric conversion chain that takes lifetime into account [22] [23]. In the case of DWEC, other more efficient control strategies are available [29], though these would also be more stringent in terms of power fluctuation and hence in terms of flicker and fatigue cycling in supercapacitors. The influence of such control strategies for recovery modes should be considered in future research on this topic.

## ACKNOWLEDGMENTS

This work has been supported by the French National Research Agency (ANR) within the project *QUALIPHE* (power quality and grid integration of direct wave energy converters), which is part of the *PROGELEC* program.

## REFERENCES

- [1] B. Vulturescu, R. Trigui, R. Lallemand, and G. Coquery, "Implementation and test of a hybrid storage system on an electric urban bus," *Transportation Research Part C: Emerging Technologies*, vol. 30, pp. 55–66, May 2013.
- [2] Z. Zhou, F. Scuiller, J. F. Charpentier, M. Benbouzid, and T. Tang, "Grid-connected marine current generation system power smoothing control using supercapacitors," in *IECON 2012 - 38th Annual Conference on IEEE Industrial Electronics Society*. IEEE, Oct. 2012, pp. 4035–4040.
- [3] N. Mendis, K. M. Muttaqi, and S. Perera, "Management of Low- and High-Frequency Power Components in Demand-Generation Fluctuations of a DFIG-Based Wind-Dominated RAPS System Using Hybrid Energy Storage," *Industry Applications, IEEE Transactions on*, vol. 50, no. 3, pp. 2258–2268, May 2014.
- [4] Maxwell Technologies, "Datasheet K2 Series Ultracapacitors," pp. 1–4, 2007.
- [5] H. Gualous, R. Gallay, G. Alcicek, B. Tala-Ighil, A. Oukaour, B. Boudart, and P. Makany, "Supercapacitor ageing at constant temperature and constant voltage and thermal shock," *Microelectronics Reliability*, vol. 50, no. 9–11, pp. 1783–1788, Sep. 2010.
- [6] O. Briat, J.-m. Vinassa, N. Bertrand, E. H. El Brouji, J.-y. Deletage, and E. Woïrgard, "Contribution of calendar ageing modes in the performances degradation of supercapacitors during power cycling," *Microelectronics Reliability*, vol. 50, no. 9–11, pp. 1796–1803, Sep. 2010.
- [7] O. Bohlen, J. Kowal, and D. U. Sauer, "Ageing behaviour of electrochemical double layer capacitors Part I. Experimental study and ageing model," *Journal of Power Sources*, vol. 172, no. 1, pp. 468–475, Oct. 2007.
- [8] R. Kötz, P. Ruch, and D. Cericola, "Aging and failure mode of electrochemical double layer capacitors during accelerated constant load tests," *Journal of Power Sources*, vol. 195, no. 3, pp. 923–928, Feb. 2010.
- [9] P. Kreczanik, "Etude de la fiabilité et du vieillissement d'un système de stockage par supercondensateurs pour l'alimentation partielle et ponctuelle d'un trolleybus grâce à la récupération de l'énergie de freinage. Approche du composant au système de stockage," Ph.D. dissertation, Université Claude Bernard Lyon 1, 2011.
- [10] P. Kreczanik, P. Venet, A. Hijazi, and G. Clerc, "Study of Supercapacitor Ageing and Lifetime Estimation According to Voltage, Temperature and RMS Current," *Industrial Electronics, IEEE Transactions on*, vol. 61, no. 9, pp. 4895–4902, 2014.
- [11] E. L. Hassane, E. Brouji, J.-M. Vinassa, O. Briat, N. Bertrand, J.-Y. Deletage, and E. Woïrgard, "Ageing assessment of supercapacitors during calendar life and power cycling tests," in *Energy Conversion Congress and Exposition, 2009. ECCE 2009*. IEEE, 2009, pp. 1791–1798.
- [12] L. Johannesson, N. Murgovski, S. Ebbesen, B. Egardt, E. Gelso, and J. Hellgren, "Including a Battery State of Health model in the HEV component sizing and optimal control problem," in *7th IFAC Symposium on Advances in Automotive Control*, 2013, pp. 398–403.
- [13] P. Haessig, B. Multon, H. Ben Ahmed, S. Lascaud, and L. Jamy, "Aging-aware NaS battery model in a stochastic wind-storage simulation framework," in *IEEE PowerTech*, 2013.
- [14] A. Blavette, D. L. O'Sullivan, T. W. Lewis, and M. G. Egan, "Dimensioning the equipment of a wave farm: Energy storage and cables," in *Ecological Vehicles and Renewable Energies (EVER)*, Mar. 2013, pp. 1–9.
- [15] A. Babarit, M. Guglielmi, and A. H. Clément, "Declutching control of a wave energy converter," *Ocean Engineering*, vol. 36, no. 12–13, pp. 1015–1024, Sep. 2009.
- [16] J. Aubry, P. Bydlowski, B. Multon, H. Ben Ahmed, and B. Borgarino, "Energy Storage System Sizing for Smoothing Power Generation of Direct Wave Energy Converters," in *3rd International Conference on Ocean Energy*, Bilbao, Oct. 2010, pp. 1–7.
- [17] D. Linzen, S. Buller, E. Karden, and R. W. De Doncker, "Analysis and Evaluation of Charge-Balancing Circuits on Performance, Reliability, and Lifetime of Supercapacitor Systems," *Industry Applications, IEEE Transactions on*, vol. 41, no. 5, pp. 1135–1141, 2005.
- [18] R. German, P. Venet, A. Sari, O. Briat, and J.-M. Vinassa, "Improved Supercapacitor Floating Ageing Interpretation Through Multi-pore Impedance Model Parameters Evolution," *Power Electronics, IEEE Transactions on*, vol. 29, no. 7, pp. 3669–3678, 2014.
- [19] E. H. El Brouji, "Prise en compte du vieillissement dans la modélisation des supercondensateurs," Ph.D. dissertation, Université Bordeaux I, 2009.
- [20] Maxwell Technologies, "Application note: Maxwell Technologies BOOSTCAP Energy Storage Modules Life Duration Estimation," pp. 4–5, 2007.
- [21] A. Babarit, M. Guglielmi, and A. H. Clément, "Declutching control of a wave energy converter," *Ocean Engineering*, vol. 36, no. 12–13, pp. 1015–1024, Sep. 2009.
- [22] J. Aubry, H. Ben Ahmed, and B. Multon, "Sizing Optimization Methodology of a Surface Permanent Magnet Machine-Converter System over a Torque-Speed Operating Profile : Application to a Wave Energy Converter," *Industrial Electronics, IEEE Transactions on*, vol. 59, no. 5, pp. 2116,2125, 2012.
- [23] T. Kovaltchouk, J. Aubry, B. Multon, and H. Ben Ahmed, "Influence of IGBT current rating on the thermal cycling lifetime of a power electronic active rectifier in a direct wave energy converter," in *Power Electronics and Applications (EPE 2013), Proceedings of the 2013-15th European Conference on*, Lille, 2013, pp. 1–10.
- [24] International Electrotechnical Commission (IEC), "IEC 61400-21 Wind turbine generator systems - Measurement and assessment of power quality characteristics of grid connected wind turbines," 2001.
- [25] P. Kreczanik, T. Kovaltchouk, A. Hijazi, P. Venet, and G. Clerc, "Consideration of the ageing in the control of the balancing circuit of supercapacitor," in *Super Capacitors & Applications, Proc. of the 4th European Symposium on - ESSCAP 2010*, Bordeaux, 2010.
- [26] A. Hijazi, P. Kreczanik, E. Bideaux, P. Venet, G. Clerc, and M. Di Loreto, "Thermal Network Model of Supercapacitors Stack," *Industrial Electronics, IEEE Transactions on*, vol. 59, no. 2, pp. 979–987, 2012.
- [27] R. Chedid, H. Akiki, and S. Rahman, "A decision support technique for the design of hybrid solar-wind power systems," *Energy Conversion, IEEE Transactions on*, vol. 13, no. 1, pp. 76,83, 1998.
- [28] P. Haessig, T. Kovaltchouk, B. Multon, H. Ben Ahmed, and S. Lascaud, "Computing an Optimal Control Policy for an Energy Storage," in *EuroScyPy*, Brussels, 2013, pp. 1–8.
- [29] T. Kovaltchouk, B. Multon, H. Ben Ahmed, F. Rongère, A. Glumineau, and J. Aubry, "Influence of control strategy on the global efficiency of a Direct Wave Energy Converter with electric Power Take-Off," in *Ecological Vehicles and Renewable Energies (EVER)*, 2013, pp. 1,10.



**Thibaut Kovaltchouk** was born in Besançon, France, in 1988. He received electrical engineering agrégation (2011) and the Master degree in Mechatronics (2012) from the ENS de Cachan, Brittany satellite, and the Rennes 1 University, Rennes, France. He is currently working toward the Ph.D. degree in electrical engineering at the SATIE laboratory, ENS Rennes, France. His current research interests include wave energy, electromechanical chain sizing, electrical devices aging models, model predictive control and energy storage.



**Bernard Multon (M95)** was born on 1960. He received the M.S. degree in electrical engineering from the ENS de Cachan, France (1981), electrical engineering agrégation (1982) and the Ph.D. degree from the University of Paris 6 (1985). Since 1995, he is Full Professor at École Normale Supérieure de Rennes. He teaches electrical engineering and energetics in the Mechatronics Department and he conducts his research in SETE group in laboratory SATIE-CNRS on electromechanical chain sizing and new electrical energy conversion systems (renewable and human power, energy storage).



**Judicaël Aubry** was born in Nantes, France, in 1985. He received the Master degree and PhD degree in electrical engineering from the École Normale Supérieure de Cachan, Cachan, France, respectively in 2008 and 2011. He is currently assistant professor in the Embedded Systems and Energy team at the ESTACA, Laval, France. His current research interests include electrical drive and machine optimization, particle swarm optimization and lightweight transportation.



**Hamid Ben Ahmed** received the Ph.D. and HDR degrees in 1994, and 2006, respectively. From 1994 to 1997, he was a Research Associate in the SATIE laboratory. Since 1997, he was an Assistant Professor in the Mechatronics Department of École Normale Supérieure de Rennes, France. His research interests include the design, modeling, and optimization of novel topologies of electromagnetic actuators and generators, and the optimization of renewable energy systems.



**Pascal Venet** was born in Aix-Les-Bains, France, in 1965. He received the Ph.D. degree in electrical engineering in 1993 from the Lyon 1 University, France. After postdoctoral positions, he joined the Lyon 1 University as Assistant Professor from 1995 to 2009. Since 2009, he has been Professor of Electrical Engineering at the Lyon 1 University. He has developed his research activity in an Electrical Engineering Laboratory (AMPERE). He is responsible for the team "Reliability Diagnosis Supervision" of the laboratory. His current research interests include characterizations, modeling, fault diagnostics, reliability and ageing of energy storage systems such as capacitors, supercapacitors and batteries.