A comprehensive model for analysis of real-time optical performance of a solar power tower with a multi-tube cavity receiver

Yu Qiu^a, Ya-Ling He^{a,*}, Peiwen Li^b, Bao-Cun Du^a

^a Key Laboratory of Thermo-Fluid Science and Engineering of Ministry of Education, School of Energy and Power Engineering, Xi'an Jiaotong University, Xi'an, Shaanxi 710049, China

^b Department of Aerospace and Mechanical Engineering, The University of Arizona, Tucson, AZ 85721, USA

Corresponding author: Tel: 029-82665930, E-mail: yalinghe@xjtu.edu.cn

Abstract: A comprehensive model for analysis of the real-time optical performance of a Solar Power Tower (SPT) with a Multi-Tube Cavity Receiver (MTCR) was developed using Monte Carlo Ray Tracing (MCRT) method. After validation, the model was used to study the optical performance of the DAHAN plant. The model-obtained results show that the solar flux in the MTCR exhibits a significant non-uniformity, showing a maximum flux of $5.141 \times 10^5 \text{ W} \cdot \text{m}^{-2}$ on the tubes. A comparison of the tracking models indicates that it is a good practice to treat the tracking errors as the random errors of the tracking angles when considering the random effect on the solar flux distribution. Study also indicates that multi-point aiming strategy of tracking helps homogenizing the flux and reducing the energy maldistribution among the tubes. Additionally, time-dependent optical efficiencies were investigated, and the yearly efficiency for the energy absorbed by the tubes was found to be 65.9%. At the end of the study, the cavity effect on the efficiency was revealed quantitatively, which indicates that the optical loss can be reduced significantly by the cavity effect, especially when the coating absorptivity is relatively low. It is concluded that the present model is reliable and suitable for predicting both the detailed solar flux and the real-time efficiency of SPT.

Keywords: Solar power tower; Multi-tube cavity receiver; Optical model; Multi-point aiming strategy; Real-time solar flux distribution; Real-time efficiency

1. Introduction

Global energy consumption has increased rapidly with the economic growth over the past half century, and it has resulted in not only the tight global supply but also serious global environment

* Corresponding author. Tel.: +86-29-8266-5930; fax: +86-29-8266-5445.

E-mail address: yalinghe@xjtu.edu.cn.

27 issues. For example, the global warming caused by carbon dioxide emitted through fossil fuel
28 combustion has become a pressing issue for years [1-3]. For solving these problems, renewable
29 energy sources, including solar energy, wind energy, bioenergy, hydropower, geothermal energy,
30 ocean energy, etc., are considered to be highly competitive candidates. Among these candidates,
31 solar energy is the most bountiful resource. Efficient utilization of solar energy is being considered
32 as one of the promising solutions to the challenges [4-8]. The Concentrating Solar Power (CSP)
33 technology, mainly including the Solar Power Tower (SPT)[9-11], Parabolic Dish Collector[12-15],
34 Parabolic Trough Collector [16-19], and linear Fresnel reflector[20-22], has become a promising
35 choice to utilize solar energy during the past few decades [23, 24]. Relatively, the SPT is considered
36 as an advanced and promising technology for large scale utilization of solar energy[25].

37 A typical SPT consists of a heliostat field, a receiver mounted on a tower, thermal energy
38 storage and conversion modules. There are four typical configurations of receivers including
39 Multi-Tube Cavity Receiver (MTCR), Multi-Tube External Receiver (MTER), volumetric receiver,
40 and direct-absorption receiver for SPT [26-28]. Among these configurations, the MTCR has been
41 widely applied for the high efficiency [29]. In the SPT using a MTCR, the heliostats will track the
42 sun and concentrate the sun rays into the MTCR firstly. Then, the solar radiation will be absorbed
43 by the absorber tubes and walls after multiple reflections. It is commonly known that the absorbed
44 solar flux on the tubes is exceedingly uneven and varies greatly over time, which would result in
45 extreme fluctuant non-uniform temperature and stress, and lead to negative effects on the
46 performance and safety of the system [30-32]. Hence, the accurate simulation of the real-time solar
47 flux in MTCR and real-time optical efficiency of the system is of great importance for the
48 performance optimization, system design, and safe operation of the SPT [33, 34].

49 Many studies have focused on this topic, and computer codes have been developed, such as
50 UHC, DELSOL and HFLCAL based on convolution methods, MIRVAL, HFLD and SOLTRACE
51 based on Monte Carlo Ray Tracing (MCRT) [33, 35]. In convolution methods, the solar flux
52 concentrated by an elementary mirror is considered with an equivalent error cone calculated by
53 convolutions of Gaussian distributions of the sun shape, the slope and tracking errors of the mirror
54 [35]. MCRT is a statistical method in which a number of random solar rays are generated and traced

in the collector[36]. In MCRT, the sun shape and the slope and tracking errors of the surfaces are calculated by probability density functions. The interactions (absorption, reflection, refraction, etc.) with the surfaces for each ray are determined by Monte Carlo method. The flux in an elementary surface in the receiver is proportional to the number of rays absorbed in the element. These tools have also been applied in performance prediction and optimization of the SPT. Vant-Hull et al. [34] used UHC to design the aiming strategies and control the incident flux on the cylinder receiver of Solar Two plant. Salomé et al. [9] used HFLCAL to control the incident flux on the MTCR's aperture of THEMIS plant. Rinaldi et al. [37] computed the incident flux on the simplified tube panels of a MTCR in PS10 by DELSOL3. Mecit et al. [38] used MIRVAL to compute the incident flux on the aperture of a particle receiver in the heliostat field at the National Solar Thermal Test Facility of Sandia National Laboratories. Yao et al. [39] developed HFLD and used it to compute the incident flux on the MTCR's aperture in DAHAN plant and optimize the heliostat field. Similar work has been done for DAHAN by Yu et al. [40], and the time-dependent incident flux on the simplified tube panels was revealed. Yellowhair et al. [33] used SOLTRACE to evaluate some novel complex receivers with fins for the enhancement of the solar radiation absorption. Sanchez-Gonzalez and Santana [41] also used SOLTRACE to simulate the incident flux on a cylinder receiver, and the results are used to validate a projection method for flux prediction.

Garcia et al.[35] indicated that the convolution methods and most MCRT models are limited to standard receiver geometries such as flat plate, cylinder, and simplified cavity receiver without considering the tubes and cavity effect, although they can predict the real-time optical performance which includes the real-time flux and efficiency. It is also found that there is almost no limit on geometries in SOLTRACE. However, it has no function to predict the real-time performance, because the sun position and heliostat tracking angles cannot be updated automatically in the code. The current status is that no studies have developed a model to manage both the complex geometry with complex optical processes in the MTCR of a SPT and the prediction of real-time optical performance.

To provide better studies to the optical system of SPT, present work focuses on developing a comprehensive optical model using Monte Carlo Ray Tracing (MCRT) [36, 42]. The main

contributions are summarized as:

(1) The originality of this work is that an optical model which can manage both the complex geometry with intricate optical processes in a Solar Power Tower (SPT) using a Multi-Tube Cavity Receiver (MTCR) and the prediction of the real-time optical performance which consists of the real-time flux and optical efficiency was developed. A realistic SPT was simulated to illustrate the application of the model.

(2) The typical real-time non-uniform solar fluxes in the MTCR and real-time optical efficiency of the SPT were numerically obtained and discussed. The effects of tracking models and aiming strategies were investigated, and corresponding useful recommendations were offered.

(3) The real-time, daily and yearly optical efficiencies throughout the whole year were evaluated. The impact of cavity effect on optical efficiencies and optical loss were quantificationally revealed and analyzed.

2. Physical model

The DAHAN plant located at 40.4°N, 115.9°E in Beijing is considered as the physical model [10, 43]. The heliostat field with 100 heliostats and a new designed molten salt MTCR including 30 panels are shown in Fig. 1 and Fig. 2, respectively. Every heliostat is composed of 64 facets with the size of 1.25 m × 1.25 m and mounted on a 6.6 m pillar. These facets are carefully aligned to form a spherical surface. The tube panels are divided into three regions which are the ① west panels, ② middle panels and ③ east panels as shown in Fig. 2. The detailed parameters of DAHAN are given in Table 1. Due to the lack of published data, the slope and tracking errors of the heliostat are assumed to be the same as those of PS10 plant[37, 44], where the tracking errors of the two axes of a heliostat are assumed to be equal to each other.

In the model, two aiming strategies are provided for the heliostat field. One is the traditional one-point aiming strategy, where all heliostats aim at the center of the MTCR's aperture, i.e. *O* in Fig. 2. The other is called multi-point aiming strategy, where the heliostat field is divided into several regions, and a specific aiming point is provided for each region. For present plant, the field is divided into five regions which are represented by different shapes and marked with B, C, D, E, O as shown in Fig. 1(b). Corresponding aiming points on the aperture are given in Fig. 2 and marked

111 in the same way as those of the regions.

112 (a) Photo of the DAHAN heliostat field[40, 45]

114 (b) Details of the field and 5 regions.

115 Fig. 1. Radial staggered heliostat field in DAHAN plant.

117 Fig. 2. Sketch of the MTCR in DAHAN plant.

Table 1 Parameters and assumptions of DAHAN plant [10, 37, 44, 46].

Parameters	Dim.	Parameters	Dim.
Heliostat number n_h	100	Tube distance in a panel	1 mm
Heliostat shape	Spherical	Distance between panels	1 mm
Heliostat width W_h	10 m	Aperture height	5 m
Heliostat height L_h	10 m	Aperture width	5 m
Heliostat center height	6.6 m	Heliostat reflectivity $\rho_{h,1}$	0.9
Tower height	118 m	Heliostat cleanliness $\rho_{h,2}$	0.97
Tower radius	10 m	Altitude tracking error $\sigma_{te,1}=\sigma_{te}$	0.46 mrad
Receiver Height H_o	78 m	Azimuth tracking error $\sigma_{te,2}=\sigma_{te}$	0.46 mrad
Receiver altitude α_r	25°	Heliostat slope error σ_{se}	1.3 mrad
Panel number	30	Coating absorptivity α_t	0.9
Tubes in a rear panel	25	Coating diffuse reflectance $\rho_{t,d}$	0.1
Tubes in a side panel	20	Cavity wall absorptivity α_w	0.6
Tube radius	19 mm	Wall diffuse reflectance $\rho_{w,d}$	0.4

120 3. Mathematical model

121 The transfer of a sunray in a SPT with a MTCR could be divided into two parts. One is the
 122 process in the heliostat field as shown in Fig. 3, and the other is the process within the MTCR as
 123 shown in Fig. 4. The first process mainly consists of four minor processes which are (1) photon
 124 initialization on the heliostat in the field, (2) shading of the tower or adjacent heliostats, (3) specular
 125 reflection on the heliostat, and (4) blocking of adjacent heliostats. The second part mainly includes
 126 two minor processes which are (1) diffuse and specular reflection on the tubes and cavity walls, and
 127 (2) absorption on the tubes and the walls. In the second part, the cavity effect which refers to the
 128 multiple reflections and absorptions on the tubes and walls should be considered carefully.

129 A real-time Monte Carol Ray Tracing (MCRT) model and corresponding code named after
 130 SPTOPTIC were developed to simulate these processes and calculate the real-time optical
 131 performance, with the flow chart shown in Fig. 5. In the model, several widely used assumptions are
 132 made as follows:

133 (1) The surface of each heliostat is assumed to be a continuous spherical surface by ignoring
 134 the narrow gaps among the facets [40]. The center of the spherical surface is assumed to coincide
 135 with the top of its pillar[40]. The tracking errors of two tracking axes for each heliostat and the slope
 136 error of the heliostat are assumed to approximately follow the Gaussian distribution[40, 47]. The

aligned error of the facets can be ignored[41] or approximately considered as an equivalent part of the slope error[48].

(2) The rays which hit the same location on a heliostat are assumed to be within a cone with an apex angle of 9.3 mrad for considering the shape effect of the sun [39, 49].

(3) The solar ray transfer in the MTCR can be simulated without considering the effect of the thermal radiation heat transfer in the receiver[14].

To describe the model, several Cartesian right-handed coordinate systems are established in Fig. 3. The ground system is defined as $X_gY_gZ_g$, where the tower base G is the origin, and X_g , Y_g , and Z_g points to the south, east, and zenith, respectively. The heliostat system is defined as $X_hY_hZ_h$, where the center of each heliostat H is the origin. X_h is horizontal, and Y_h is normal to the tangent plane at H and points upwards. Z_h is perpendicular to X_hY_h plane. The incident-normal system is defined as $X_iY_iZ_i$, where the point which is hit by the ray on the heliostat is the origin, and Z_i points towards the sun. X_i is horizontal and normal to Z_i , and Y_i is perpendicular to X_iZ_i plane and points upwards. The receiver system is defined as $X_rY_rZ_r$, where the aperture center is the origin. X_r points to the east, and Y_r points upwards. Z_r is perpendicular to X_rY_r plane. The tube system is defined as $X_tY_tZ_t$ and the tube center T is the origin. X_t is parallel to X_rY_r , and Y_t is coincident with the tube centerline and points upwards. Z_t is normal to X_tY_t plane. The wall system is defined as $X_wY_wZ_w$ in the similar way as that of $X_tY_tZ_t$ (Fig. 3). The local system on tube is defined as $X_lY_lZ_l$, and the relation between $X_lY_lZ_l$ and it is illustrated in Fig. 3. The transformation matrixes including $M_1 \sim M_{14}$ among these systems are summarized in the Appendix.

Fig. 3. Sketch of the SPT with a MTCR showing the solar ray transfer and coordinate systems.

Fig. 4. Details of the optical processes in the MTCR.

Fig. 5. The flow diagram of the SPTOPTIC code.

3.1 Modeling of solar ray transfer in the heliostat field

3.1.1 Tracking equations of the heliostat

165 The altitude (α_h) and azimuth (A_h) of the heliostat's center normal are calculated by Eq.(1),
 166 where the quadrant ambiguity of A_h should be recognized when the sun rays come from the north
 167 [50]. The tracking errors are treated as the angles' errors (**Model A**) [51]. This treatment is different
 168 from another model (**Model B**) which treats the tracking errors as an equivalent slope error and
 169 calculates the total slope error by $\sqrt{\sigma_{se}^2 + \sigma_{te,1}^2 + \sigma_{te,2}^2}$ [50].

$$\begin{aligned} \alpha_h &= \sin^{-1} \left(\frac{\sin \alpha_s + \cos \lambda_h}{2 \cos \theta_i} \right) + R_{te,1} \\ A_h &= \tan^{-1} \left(\frac{\sin \theta_h \sin \lambda_h - \sin A_s \cos \alpha_s}{\cos \theta_h \sin \lambda_h - \cos A_s \cos \alpha_s} \right) + R_{te,2} \end{aligned} \quad (1)$$

171 where θ_h is the azimuth of the heliostat in the field, which is calculated using Eq.(2); λ_h which is
 172 the angle between the line HA and local vertical is computed by Eq.(3); Given in Eq.(4) are H and
 173 A which are the heliostat's center and the aiming point in $X_g Y_g Z_g$, respectively; θ_i is the incident
 174 angle of the principle ray at the heliostat center; α_s and A_s are the solar altitude and azimuth given in
 175 Eq.(6) and (7) [52], respectively; $R_{te,1} \sim N(0, \sigma_{te,1}^2)$ and $R_{te,2} \sim N(0, \sigma_{te,2}^2)$ are the tracking errors of
 176 α_h and A_h , respectively.

$$\theta_h = \cos^{-1} \left(x_{H,g} / \sqrt{x_{H,g}^2 + y_{H,g}^2} \right), \quad y_{H,g} \geq 0 \quad (2)$$

$$\lambda_h = \cos^{-1} \left[(z_{A,g} - z_{H,g}) / D_{H,A} \right] \quad (3)$$

$$\mathbf{H} = [x_{H,g} \quad y_{H,g} \quad z_{H,g}]^T, \quad \mathbf{A} = [x_{A,g} \quad y_{A,g} \quad z_{A,g}]^T \quad (4)$$

$$\theta_i = \cos^{-1} \left[\frac{\sqrt{2}}{2} \sqrt{\sin \alpha_s \cos \lambda_h - \cos \alpha_s \sin \lambda_h \cos(\theta_h - A_s) + 1} \right] \quad (5)$$

$$\alpha_s = \sin^{-1} (\sin \varphi \sin \delta + \cos \varphi \cos \delta \cos \omega) \quad (6)$$

$$A_s = \cos^{-1} \left(\frac{\sin \alpha_s \sin \varphi - \sin \delta}{\cos \alpha_s \cos \varphi} \right), \quad \omega \leq 0 \quad (7)$$

$$\omega = (t_s - 12) \cdot 15^\circ \quad (8)$$

184 In the above equations, $D_{H,A}$ is the distance between H and A . Variables φ , δ , ω , and t_s are the
 185 latitude, declination, hour angle, and solar time, respectively; the heliostat azimuth in the field

186 should be $2\pi - \theta_h$ when $y_{H,g} < 0$; the solar azimuth should be $-A_s$ when $\omega > 0$.

187 3.1.2 Solar model and photon initialization

188 The shape effect of the sun is considered, and the photons initialized at a point on the heliostat
189 are treated as a cone with an apex angle of $2\delta_{sr}=9.3$ mrad (Fig. 3)[51]. So, the unit vector ($\mathbf{I}$) of an
190 incident photon in $X_iY_iZ_i$ can be written in Eq.(9) [20]. A solar radiation model given in Eq.(11) is
191 applied to predict the Direct Normal Irradiance (DNI) at any time in a year [53]. The energy carried
192 by each photon on the heliostats (e_p) is calculated by Eq.(12).

$$193 \quad \mathbf{I}_i = \begin{bmatrix} \delta_s \cos \theta_s & \delta_s \sin \theta_s & \sqrt{1 - \delta_s^2} \end{bmatrix}^T \quad (9)$$

$$194 \quad \delta_s = \sin^{-1} \left(\sqrt{\xi_1 \sin^2 \delta_{sr}} \right), \theta_s = 2\pi\xi_2 \quad (10)$$

$$195 \quad DNI = 1367 \left[1 + 0.033 \cos \left(\frac{2N_{\text{day}}\pi}{365} \right) \right] \cdot \frac{\sin \alpha_s}{\sin \alpha_s + 0.33} \quad (11)$$

$$196 \quad e_p = DNI \cdot L_h W_h \sum_{i=1}^{n_h} \eta_{\cos}(i) / N_p \quad (12)$$

197 where each ξ is a uniform random number between 0 and 1, i.e. $\xi \sim U[0,1]$; N_{day} is the day number in
198 a year; $\eta_{\cos}(i)$ is the cosine efficiency of the i th heliostat; N_p is the total number of the photons traced
199 in the field; L_h and W_h are the height and width of the heliostat, respectively.

200 The solar radiation is assumed to be uniform, so the photons are initialized uniformly on the
201 heliostat, and the intersection of the photon and the heliostat is initialized by Eq.(13).

$$202 \quad \mathbf{P}_h = \begin{bmatrix} x_{P,h} \\ y_{P,h} \\ z_{P,h} \end{bmatrix} = \begin{bmatrix} W_h (\xi_3 - 0.5) \\ L_h (\xi_4 - 0.5) \\ 2D_{H,O} - \sqrt{4D_{H,O}^2 - x_{P,h}^2 - y_{P,h}^2} \end{bmatrix} \quad (13)$$

203 where $D_{H,O}$ is the distance between $\mathbf{H}$ and $\mathbf{O}$ in Fig. 3; and the heliostat radius equals to twice of
204 $D_{H,O}$.

205 3.1.3 Specular reflection on the heliostat

206 When the photon hits the heliostat, the reflection computation will be conducted. Firstly, a
207 random number (ξ_5) is generated to determine the optical process by Eq.(14). Then, if the photon is
208 reflected, the incident vector $\mathbf{I}_i$ will be transformed from $X_iY_iZ_i$ to $X_hY_hZ_h$ by Eq.(15). Finally, the
209 reflected vector $\mathbf{R}_h$ at $\mathbf{P}_h$ in $X_hY_hZ_h$ will be calculated by Eq. (16). The slope error is assumed to

210 follow the Gaussian distribution[51], and the normal vector (N_h) at P_h is expressed in Eq.(17). The
 211 realistic normal vector for each location on the heliostat can also be used to replace N_h for more
 212 accurate simulation if the measured data are obtained using the approach given in Ref.[54].

$$213 \quad \begin{cases} 0 \leq \xi_5 < \rho_{h,1} \cdot \rho_{h,2} \cdot \eta_{att}, \text{ specular reflection} \\ \rho_{h,1} \cdot \rho_{h,2} \cdot \eta_{att} \leq \xi_5 \leq 1, \text{ abandoned} \end{cases} \quad (14)$$

$$214 \quad \mathbf{I}_h = [\cos \alpha_{hi} \quad \cos \beta_{hi} \quad \cos \gamma_{hi}]^T = \mathbf{M}_4 \mathbf{M}_3 \mathbf{M}_2 \mathbf{M}_1 \cdot \mathbf{I}_i \quad (15)$$

$$215 \quad \mathbf{R}_h = 2(\mathbf{I}_h \cdot \mathbf{N}_h) \mathbf{N}_h - \mathbf{I}_h \quad (16)$$

$$216 \quad \begin{aligned} \mathbf{N}_h &= \mathbf{M}_6 \mathbf{M}_5 \begin{bmatrix} \rho_h \cos \varphi_h & \rho_h \sin \varphi_h & \sqrt{1 - \rho_h^2} \end{bmatrix}^T \\ \rho_h &= \sqrt{-2\sigma_{se}^2 \ln(1 - \xi_6)}, \varphi_h = 2\pi\xi_7 \end{aligned} \quad (17)$$

217 where η_{att} is the atmospheric attenuation which is computed as a function of the distance between $\mathbf{O}$
 218 and $\mathbf{H}$ for each heliostat[55]; $\mathbf{M}_1$ and $\mathbf{M}_2$ are the transformation matrixes from $X_i Y_i Z_i$ to $X_g Y_g Z_g$; $\mathbf{M}_3$
 219 and $\mathbf{M}_4$ are the transformation matrixes from $X_g Y_g Z_g$ to $X_h Y_h Z_h$; $\mathbf{M}_5$ and $\mathbf{M}_6$ are the transformation
 220 matrixes to introduce slope error [56]; ρ_h and φ_h are the radial and tangential angles of N_h caused by
 221 slope error [51].

222 3.1.4 Shading and blocking

223 The shading is the part of heliostat shadowed by the adjacent heliostats or the tower, and the
 224 blocking is the part of reflected rays blocked by nearby heliostats (Fig. 3). The blocking here is
 225 taken as an example to illustrate the modeling of the two processes. First, the initialized location (P_I)
 226 on heliostat I and the reflection vector (R_I) at P_I are transformed from $X_h Y_h Z_h(I)$ to $X_h Y_h Z_h(II)$ and
 227 expressed as $P_{I,II}$ (Eq.(18)) and $R_{I,II}$ (Eq. (19)), respectively. Then, the equation of the reflected ray
 228 in system II can be derived using $P_{I,II}$ and $R_{I,II}$. Finally, the intersection of the ray and heliostat II
 229 surface is calculated, and if it is within heliostat II, the ray is blocked.

$$230 \quad P_{I,II} = (\mathbf{M}_4 \mathbf{M}_3)_{II} \cdot [(\mathbf{M}_8 \mathbf{M}_7)_I \cdot P_I + \mathbf{H}_I - \mathbf{H}_{II}] \quad (18)$$

$$231 \quad R_{I,II} = (\mathbf{M}_4 \mathbf{M}_3)_{II} \cdot (\mathbf{M}_8 \mathbf{M}_7)_I \cdot R_I \quad (19)$$

232 where $\mathbf{M}_7$ and $\mathbf{M}_8$ are the transformation matrixes from $X_h Y_h Z_h$ to $X_g Y_g Z_g$.

233 3.2 Modeling of solar ray transfer in the MTCR

234 3.2.1 Intersection with the surfaces in MTCR

235 When a ray is reflected and arrives at the focal plane of the field, i.e., the MTCR's aperture (Fig.

3), the intersection $\mathbf{P}_{a,r}$ in $X_r Y_r Z_r$ is calculated by transforming $\mathbf{P}_h$ and $\mathbf{R}_h$ to $X_r Y_r Z_r$, which are expressed as $\mathbf{P}_{h,r}$ and $\mathbf{R}_r$ in Eq.(20) and Eq.(21), respectively. When the ray gets through the aperture and hits the tube or wall, the intersection will be calculated, where the particular orientation of each surface has been considered. The intersection with the tube is taken as an example to illustrate this process. Firstly, the $\mathbf{P}_{a,r}$ and $\mathbf{R}_r$ are transformed from $X_r Y_r Z_r$ to $X_t Y_t Z_t$ by Eq.(22) and Eq.(23) and expressed as $\mathbf{P}_{a,t}$ and $\mathbf{I}_t$, respectively. Then, the intersection ($\mathbf{P}_{t,t} = [x_{P,t} \ y_{P,t} \ z_{P,t}]^T$) in $X_t Y_t Z_t$ is computed by solving the ray and the tube equations. The intersection of the ray and the wall can be calculated in the similar way.

$$\mathbf{P}_{h,r} = \mathbf{M}_9 \cdot (\mathbf{M}_8 \mathbf{M}_7 \cdot \mathbf{P}_h + \mathbf{H}_g - \mathbf{O}_g) \quad (20)$$

$$\mathbf{R}_r = \mathbf{M}_9 \mathbf{M}_8 \mathbf{M}_7 \cdot \mathbf{R}_h \quad (21)$$

$$\mathbf{P}_{a,t} = \mathbf{M}_{11} \mathbf{M}_{10} \cdot (\mathbf{P}_{a,r} - \mathbf{T}_r) \quad (22)$$

$$\mathbf{I}_t = \mathbf{M}_{11} \mathbf{M}_{10} \cdot \mathbf{R}_r \quad (23)$$

where $\mathbf{O}_g$ is the origin of $X_r Y_r Z_r$ in $X_g Y_g Z_g$; $\mathbf{M}_9$ is the transformation matrix from $X_g Y_g Z_g$ to $X_r Y_r Z_r$; $\mathbf{M}_{10}$ and $\mathbf{M}_{11}$ are the transformation matrixes from $X_r Y_r Z_r$ to $X_t Y_t Z_t$; $\mathbf{T}_r$ is the origin of $X_t Y_t Z_t$ in $X_r Y_r Z_r$.

3.2.2 Multiple reflections among the tubes and walls

When the photon hits the cavity walls or the tubes (Fig. 3), a random number (ξ_8) is generated to determine the optical process by Eq.(24). If the photon is reflected diffusely, the reflected vector ($\mathbf{R}_l$) in $X_l Y_l Z_l$ will be computed by Eq. (25) based on the Lambert law [20, 57]. If the photon is reflected specularly, $\mathbf{R}_l$ will be calculated by Fresnel's Law in the similar way as that on the heliostat [20, 58].

$$\begin{cases} 0 \leq \xi_8 < \rho_{t,d} & , \text{ diffuse reflection} \\ \rho_{t,d} \leq \xi_8 < 1 - \alpha_t & , \text{ specular reflection} \\ \rho_{t,d} + \rho_{t,s} \leq \xi_8 \leq 1 & , \text{ absorption} \end{cases} \quad (24)$$

$$\begin{aligned} \mathbf{R}_l &= [\sin \delta_d \cos \theta_d \quad \sin \delta_d \sin \theta_d \quad \cos \delta_d]^T \\ \delta_d &= \cos^{-1}(\sqrt{\xi_9}), \quad \theta_d = 2\pi\xi_{10} \end{aligned} \quad (25)$$

After the reflection, firstly, $\mathbf{R}_l$ will be transformed from $X_l Y_l Z_l$ to $X_t Y_t Z_t$ and expressed as $\mathbf{R}_t$ in Eq.(26). Then, $\mathbf{R}_t$ and $\mathbf{P}_{t,t}$ are transformed from $X_t Y_t Z_t$ to $X_r Y_r Z_r$ and expressed as $\mathbf{R}_r$ and $\mathbf{P}_{t,r}$ in Eq.(26) and Eq.(27). Then we should go back to section 3.2.1 and begin to calculate the next

intersection between the ray and other surfaces using the new $\mathbf{R}_r$ and $\mathbf{P}_{t,r}$. These processes will continue until the ray is absorbed or lost.

$$\mathbf{R}_t = \mathbf{M}_{12} \cdot \mathbf{R}_l, \mathbf{R}_r = \mathbf{M}_{14} \mathbf{M}_{13} \cdot \mathbf{R}_t \quad (26)$$

$$\mathbf{P}_{t,r} = \mathbf{M}_{14} \mathbf{M}_{13} \cdot \mathbf{P}_{t,t} + \mathbf{T}_r \quad (27)$$

where $\mathbf{P}_{t,t} = [x_{P,t} \ y_{P,t} \ z_{P,t}]^T$ is the intersection on the tube in $X_t Y_t Z_t$; $\mathbf{M}_{12}$ is the transformation matrix from $X_l Y_l Z_l$ to $X_t Y_t Z_t$; $\mathbf{M}_{13}$ and $\mathbf{M}_{14}$ are the transformation matrixes from $X_t Y_t Z_t$ to $X_r Y_r Z_r$.

3.2.3 Statistics of the photon and flux

The quadrilateral grids are generated on the tubes and walls, and when a photon is absorbed by these surfaces, the statistics of the photon would be conducted in the following way. First, the photons absorbed in each element ($n_{p,e}$) would be counted. Then, the local solar flux in each element (q_l) would be computed after the tracing of the last photon by Eq.(28).

$$q_l = e_p n_{p,e} / S_e \quad (28)$$

where S_e is the area of the element.

3.3 Parameter definitions

Some performance indexes are defined below to characterize the optical performance.

The instantaneous efficiency of the MTCR ($\eta_{i,R}$) which is also called the effective absorptivity is defined as the ratio of the energy absorbed by the tubes ($Q_{ij,T}$) and the energy entering the aperture ($Q_{ij,A}$) in Eq.(29). The instantaneous optical loss ($Q_{i,loss}$) of the MTCR is defined as the difference between $Q_{ij,A}$ and $Q_{ij,T}$ in Eq.(29). One important advantage of the MTCR is reducing optical loss due to the cavity effect compared to the Multi-tube External Receiver (MTER). The impact of cavity effect is quantitated in the following way. When the cavity effect is considered, $Q_{ij,T}$ will be calculated by considering the multiple reflections and absorptions for each ray on the tubes and walls. When the cavity effect is not considered, $Q_{ij,T}$ will be calculated by assuming that each incident ray from the field will just interact with the tube or wall one time. After this only interaction (absorption or reflection), the ray which is not absorbed will be abandoned, and this is similar to what happens in a MTER.

The energy maldistribution index (σ_E) among the tubes is defined in Eq.(30). The instantaneous optical efficiency of the SPT ($\eta_{i,T}$) is defined as the ratio of $Q_{ij,T}$ and the maximum solar energy that

can be accepted by the heliostats ($Q_{ij,H}$) in Eq.(31). The daily and yearly optical efficiencies are defined as $\eta_{d,T}$ and $\eta_{y,T}$ in the similar way in Eq.(32) and Eq.(33), where the SPT is assumed to operate when the solar altitude is larger than 10° [20]. The instantaneous optical efficiency ($\eta_{i,A}$) for $Q_{ij,A}$ is defined as the ratio of $Q_{ij,A}$ and $Q_{ij,H}$ in Eq.(35), and the daily and yearly efficiencies of the energy entering the aperture are defined in the similar way.

$$\eta_{i,R} = Q_{ij,T} / Q_{ij,A}, Q_{i,loss} = Q_{ij,A} - Q_{ij,T} \quad (29)$$

$$\sigma_E = \frac{\sqrt{\sum_{i=1}^{n_t} [E_t(i) - \bar{E}_t]^2 / (n_t - 1)}}{\bar{E}_t}, \bar{E}_t = \frac{1}{n_t} \sum_{i=1}^{n_t} E_t(i) \quad (30)$$

$$\eta_{i,T} = Q_{ij,T} / Q_{ij,H}, Q_{ij,H} = DNI_{ij} \cdot L_h W_h n_h \quad (31)$$

$$\eta_{d,T} = \left(\int_{i=t_{s1}}^{t_{s2}} Q_{ij} \right) / \left(\int_{i=t_{s1}}^{t_{s2}} Q_{ij,H} \right) \quad (32)$$

$$\eta_{y,T} = \left(\sum_{j=1}^{365} \int_{i=t_{s1}}^{t_{s2}} Q_{ij} \right) / \left(\sum_{j=1}^{365} \int_{i=t_{s1}}^{t_{s2}} Q_{ij,H} \right) \quad (33)$$

$$\alpha_s(t_{s1}) = \alpha_s(t_{s2}) = 10^\circ \quad (34)$$

$$\eta_{i,A} = Q_{ij,A} / Q_{ij,H} \quad (35)$$

where n_t is the number of the tubes; $E_t(i)$ is the power absorbed by i th tube; $\alpha_s(t_s)$ is the solar altitude at the solar time of t_s , DNI_{ij} is the DNI at i o'clock in j th day in a year, respectively.

4. Grid-independence study, uncertainty analysis, and validation of the model

The grid-independence test is conducted using five grid systems at summer solstice noon, where Model B and the one-point aiming strategy are applied, and sufficient photons of 3×10^9 are traced. The result is given in Fig. 6, where the local flux at $Y_t=0$ on Tube 443 located at the hot spot is examined. It is found that the flux profile varies insignificantly when the grid system is larger than 20 (circumferential) $\times 200$ (lengthwise) for each tube, which indicates this grid system can be regarded as grid-independent.

The uncertainty which depends on photon number (N_p) is analyzed with at the above condition. Figure 7 shows the maximum flux on the tubes ($q_{l,max}$) and $\eta_{i,T}$ with different N_p . It is seen that there will be no obvious change in $q_{l,max}$ and $\eta_{i,T}$ when N_p is larger than 5×10^8 and 2×10^7 , respectively.

Fig. 6. Grid-independence test.

Fig. 7. Uncertainty analysis of the MCRT model

To validate the model, firstly, the flux contour for a single heliostat located at $(-189.3, -110.9)$ in Fig. 1(b) was computed using both present model and SolTrace under the above condition. It is seen in Fig. 8 that the computed quasi-circular contours on the MTCR's aperture agree well with each other. Then, the computed incident flux and power on the MTCR's tube panels (simplified as flat plates) of PS10 plant is compared with those in literature [37] as shown in Fig. 9, where 624 heliostats are used in the heliostat field. It is seen that the patterns of the fluxes in Fig. 7(a) and 7(b) agree well with each other. The deviations of the peak fluxes and the total powers are less than 0.1% and 0.4%, respectively. Furthermore, the flux profiles on a MTCR's tubes in a linear Fresnel reflector [20] were computed and compared with those of SOLTRACE at normal incidence. It is seen in Fig. 10 that the present profiles agree with those of SOLTRACE quite well. The good

328 agreement indicates that the present model is appropriate for modeling both the heliostat field and
 329 the MTCR.

330

331 Fig. 8. Comparison of the incident flux contours for a single heliostat between MCRT and SOLTRACE.

332

(a) Data from Ref.[37]. Total Power =54.8 MW, Peak flux =714.0 kW·m⁻² (b) Present result. Total Power =55.0 MW, Peak flux =714.9 kW·m⁻²

333 Fig. 9. Comparison of the incident flux contours for PS10 plant between published data and present result
 334 (Equinox noon, $DNI=970 \text{ W} \cdot \text{m}^{-2}$).

335

336 Fig. 10. Comparison of the flux profiles on the tubes between MCRT and SOLTRACE.

337 5. Results and discussion

338 In this section, the characterization of the real-time optical performance for the DAHAN plant
339 is illustrated as an example to show the application of the present MCRT model. Firstly, the detailed
340 real-time flux distribution in the MTCR is studied. Then, the effects of tracking models and aiming
341 strategies on both the real-time flux and the real-time optical efficiency are investigated. Then, the
342 real-time optical efficiency at different time in a year is discussed. Finally, the impact of the cavity
343 effect and absorptivity on the efficiency is further analyzed.

344 5.1 Typical real-time solar flux distribution

345 Figure 11 shows the typical solar fluxes in the MTCR at $t_s=12$, spring equinox, where the
346 one-point aiming strategy and Model B are used. It is seen from Fig. 11(a) that local flux on the
347 aperture decreases from the center to the margin because all heliostats aim at the center, and the
348 maximum flux ($q_{l,max}$) of $2.622 \times 10^6 \text{ W} \cdot \text{m}^{-2}$ appears at the center. From Fig. 11(b) and (c), it is
349 observed that two high flux regions appear on ① the west panels and ③ the east panels, where
350 $q_{l,max}$ of $5.141 \times 10^5 \text{ W} \cdot \text{m}^{-2}$ occurs on tube 443 in Fig. 2 and Fig. 11(c). This is because most energy
351 from the heliostats at the west side of the field will be concentrated on the east panels after crossing
352 the aperture center, and the opposite is true for the heliostats at the east side. It is also seen that most
353 energy is concentrated on the middle part of each tube, and other parts along the length are barely
354 utilized. This is because the rays can only shine on the middle part of the tubes when all heliostats
355 aim at the aperture center.

356 From Fig. 11(d), it is seen that a hot spot appears on the middle cavity wall defined in Fig. 2,
357 because the incident rays from the field hit this wall through the gaps between the tubes. However,
358 there is no spot on the east and west walls for the reason that the incident rays are blocked by the
359 tubes installed along these walls which are very steep in the depth direction of the receiver. Also,
360 two hot spots appear on the upper and lower walls due to the diffuse reflections in the MTCR.
361 Figure 11 (e) illustrates the whole flux distribution in the MTCR combining the tubes and cavity
362 walls, and this detailed distribution could be applied in heat transfer analysis of the MTCR and
363 performance evaluation of the system in the future.

Fig. 11. Typical solar flux distributions in the MTCR at $t_s=12$, spring equinox
 (Model A, one-point aiming strategy, $\sigma_{te}=0.46 \text{ mrad}$, $DNI=961 \text{ W} \cdot \text{m}^{-2}$).

5.2 Effects of tracking-error models on real-time performance

The effects of two tracking-error models on the real-time performance are studied in this section, where the one-point aiming strategy is used. The results of the solar flux distribution, maximum flux ($q_{l,max}$), maldistribution index (σ_E), and instantaneous efficiencies ($\eta_{i,A}$, $\eta_{i,T}$) are compared.

Figure 11 and 12 show the solar fluxes computed using two tracking-error models with $\sigma_{te}=0.46 \text{ mrad}$. It is seen that the variation of the flux distribution is insignificant. And the values of $q_{l,max}$ on the aperture and the tube for Model A are only about 5.8 % and 2.5 % larger than those for Model B, respectively. It is also seen that the variations of σ_E , $\eta_{i,A}$ and $\eta_{i,T}$ are also not obvious.

(a) Aperture $q_{l,\max}=2.478\times10^6 \text{ W}\cdot\text{m}^{-2}$, $\eta_{i,A}=80.5\%$ (b) Tubes $q_{l,\max}=5.016\times10^5 \text{ W}\cdot\text{m}^{-2}$, $\eta_{i,T}=75.4\%$, $\sigma_E=63.5\%$

Fig. 12. Solar fluxes on the aperture and tubes with Model B and $\sigma_{te}=0.46 \text{ mrad}$
($t_s=12$, spring equinox, $DNI=961 \text{ W}\cdot\text{m}^{-2}$).

Figure 13 and 14 show the solar fluxes computed using two tracking-error models with $\sigma_{te}=1.0 \text{ mrad}$. It is seen that the random effect on the flux distribution becomes significant for Model A. And the values of $q_{l,\max}$ on the aperture and the tube for Model A are 24.9 % and 11.2% larger than those for Model B, respectively. It is also found that the maldistribution index (σ_E) for Model A is 8.2% larger than that for Model B. As a result, a deviation in $\eta_{i,T}$ of 1.5 percent is also observed.

These results indicate that the random effects of the tracking errors are smoothed by the widely-used Model B, which however is revealed by Model A more clearly. Since the accurate prediction of real-time optical performance is important for the safe operation and performance optimization of the plant, the random effect should be considered. For this purpose, Model A is recommended from the current study, especially, when σ_{te} is relatively large.

(a) Aperture $q_{l,\max}=2.254\times10^6 \text{ W}\cdot\text{m}^{-2}$, $\eta_{i,A}=80.1\%$ (b) Tubes $q_{l,\max}=4.787\times10^5 \text{ W}\cdot\text{m}^{-2}$, $\eta_{i,T}=75.0\%$, $\sigma_E=64.2\%$

Fig. 13. Solar fluxes on the aperture and tubes with Model A and $\sigma_{te}=1.00 \text{ mrad}$

($t_s=12$, spring equinox, $DNI=961 \text{ W}\cdot\text{m}^{-2}$).

Fig. 14. Solar fluxes on the aperture and tubes with Model B and $\sigma_{ic}=1.00 \text{ mrad}$

($t_s=12$, spring equinox, $DNI=961 \text{ W}\cdot\text{m}^{-2}$).

5.3 Effects of aiming strategies on real-time performance

The effects of one-point and multi-point aiming strategies on the real-time performance are investigated in this section. For DAHAN plant, a five-point aiming strategy as indicated in Fig. 1 and Fig. 2 is implemented, where the coordinate value (d) for the aiming points in $X_r Y_r Z_r$ is 0.7 m.

Figure 11 and 15 show the solar fluxes obtained using the two aiming strategies at $t_s=12$, spring equinox, and the fluxes at 15:00 are also illustrated in Fig. 16 and Fig. 17. It is seen that the maximum fluxes on the aperture and the tubes drop 36.8% and 10.5 % when the five-point strategy is applied at $t_s=12$, respectively. And the corresponding values are 33.4% and 12.0 % for $t_s=15$, respectively. It is noteworthy that $q_{l,max}$ on tubes decreases from $5.141 \times 10^5 \text{ W}\cdot\text{m}^{-2}$ to $4.599 \times 10^5 \text{ W}\cdot\text{m}^{-2}$ at $t_s=12$. This sharp decline of $q_{l,max}$ will certainly be of great help to the safe operation of the receiver.

Moreover, it is seen that the values of maldistribution index (σ_E) drop 31.6 % and 33.7 % when the five-point strategy is applied for $t_s=12$ and $t_s=15$, respectively, and it can also be seen that longer tubes are utilized. It indicates that the energy is distributed much more uniformly among the tubes, which could help to lower the average temperature and improve the thermal efficiency of the receiver. In addition, it is also found that the drops in the instantaneous optical efficiency for the power absorbed by tubes ($\eta_{i,T}$) are just 1.0 percent and 1.2 percent for $t_s=12$ and $t_s=15$, respectively.

These results indicate that the fluxes in the MTCR can be greatly homogenized by the multi-point aiming strategy with just a little drop in optical efficiency. Therefore, this method should be recommended to study SPT and will be used in the following sections. Similar results have also been obtained by Binotti et al. [59] when the multi-point aiming strategy is applied in PS10 plant.

Fig. 15. Solar flux distributions in the MTCR at $t_s=12$, spring equinox
(Multi-point aiming strategy, $\sigma_{te}=0.46$ mrad, $DNI=961 \text{ W}\cdot\text{m}^{-2}$).

Fig. 16. Solar flux distributions in the MTCR at $t_s=15$, spring equinox
(One-point aiming strategy, $\sigma_{te}=0.46$ mrad, $DNI=855 \text{ W}\cdot\text{m}^{-2}$).

Fig. 17. Solar flux distributions in the MTCR at $t_s=15$, spring equinox
(Multi-point aiming strategy, $\sigma_{te}=0.46$ mrad, $DNI=855 \text{ W}\cdot\text{m}^{-2}$).

5.4 Real-time optical efficiency of the plant in a year

The instantaneous efficiency of the plant for the power entering the aperture ($\eta_{i,A}$), the

instantaneous efficiency of the plant for the power absorbed by the tubes ($\eta_{i,T}$) and the instantaneous efficiency / effective absorptivity of the MTCR ($\eta_{i,R}$) in a year are analyzed in this section.

Figure 18 and 19 illustrate the variations of $\eta_{i,A}$, $\eta_{i,T}$ and $\eta_{i,R}$ on three typical days which are the summer solstice, spring equinox and winter solstice. It is seen in Fig. 18 that the work time increases from the winter solstice to the summer solstice due to the variation of the sunshine duration. It is also observed that $\eta_{i,A}$ and $\eta_{i,T}$ increase in the morning and decrease in the afternoon in every day, and the $\eta_{i,A}$ of 80.0 % and $\eta_{i,T}$ of 74.7 % are achieved at the noon of spring equinox, which is the design point of the plant. It is seen in Fig. 19 that $\eta_{i,R}$ is around 93.5 % for winter solstice and spring equinox, and for summer solstice it is around 93.0 %. It is also seen that $\eta_{i,R}$ almost keeps constant when $t_s=9-15$ h, while it is smaller in the early morning and late afternoon. This is because a greater proportion of power is shined on the cavity walls under the later condition.

Fig. 18. Variations of $\eta_{i,A}$ and $\eta_{i,T}$ on three typical days.

Fig. 19. Variation of $\eta_{i,R}$ on three typical days.

Figure 20 shows the variations of $\eta_{i,A}$, $\eta_{i,T}$ and $\eta_{i,R}$ during the whole year. It is seen that a whole year can be divided into two ranges approximately. One is the low-efficiency range which appears in summer, the other is the high-efficiency range that ranges from autumn to the spring of next year. It can be found that $\eta_{i,A}$ and $\eta_{i,T}$ during a day within the low-efficiency range vary more violently than those within the high-efficiency range. This is because the work time in summer is much longer than that in other seasons, so the efficiencies in the early morning and late afternoon are quite low as shown in Fig. 18. Furthermore, it is observed that the effective absorptivity of the MTCR ($\eta_{i,R}$) which varies little with time is in the range of 92.2-93.8% for the whole year, and this value is larger than the coating absorptivity. This is because the cavity effect which can cause an increase of the solar power absorption physically improves the optical efficiency, which is not significantly affected by the time in a year.

Fig. 20. Variations of instantaneous efficiencies ($\eta_{i,A}$, $\eta_{i,T}$ and $\eta_{i,R}$) in a year.

Figure 21 illustrates the variations of the daily efficiencies ($\eta_{d,A}$, $\eta_{d,T}$) in a year. There are two peaks and one valley for each efficiency curve, where the valley is at around the summer solstice, and the peaks are in spring and autumn. It can be found that the maximum values of $\eta_{d,A}$ and $\eta_{d,T}$ are 75.2% and 70.4%, respectively. And the corresponding minimum values are 64.9% and 60.6%, respectively. These variations of the curves are specially designed for obtaining a high yearly optical efficiency. From present simulation, it is found that the $\eta_{y,A}$ of 70.5% and $\eta_{y,T}$ of 65.9% can be achieved by DAHAN plant.

Fig. 21. The variations of daily efficiencies ($\eta_{d,A}$, $\eta_{d,T}$) in a year.

5.5 Impact of cavity effect on real-time efficiency

The impact of the cavity effect which refers to the multiple reflections and absorptions among the tubes and walls on the instantaneous efficiency / effective absorptivity of the MTCR ($\eta_{i,R}$), the optical loss ($Q_{i,loss}$) of the MTCR, and the instantaneous efficiency ($\eta_{i,T}$) for the power absorbed by the tubes ($Q_{ij,T}$) is further discussed in this section.

Figure 22 shows the variations of $\eta_{i,R}$ and $Q_{i,loss}$ against the coating absorptivity (α_t) at $t_s=12$, spring equinox. It is seen that the $\eta_{i,R}$ considering cavity effect is larger than that which ignores cavity effect at the same α_t . This is because the $Q_{i,loss}$ is reduced by the cavity effect when the cavity effect is considered. For example, $Q_{i,loss}$ decreases from 2748 kW to 1707 kW after considering the cavity effect at $\alpha_t=0.65$, and the corresponding increments of the absorbed power ($Q_{ij,T}$), $\eta_{i,R}$ and $\eta_{i,T}$ are 1041 kW, 13.5 percent and 10.8 percent, respectively. It is also seen that the decrement of $Q_{i,loss}$ due to cavity effect becomes less when α_t is higher. For instance, the cavity effect makes the increments of $Q_{ij,T}$, $\eta_{i,R}$ and $\eta_{i,T}$ being 340 kW, 4.4 percent and 3.5 percent at $\alpha_t=0.90$, respectively. Therefore, it is clear that the impact of cavity effect is more significant at low α_t than that at high α_t . The above results quantitatively reveal the impact of cavity effect on the MTCR's performance, which show that the optical loss can be reduced greatly due to cavity effect, especially when α_t is relatively low.

Fig. 22. Variations of $\eta_{i,R}$ and $Q_{i,loss}$ with α_t at $t_s=12$, spring equinox ($DNI=961 \text{ W}\cdot\text{m}^{-2}$).

Figure 23 illustrates the variations of $\eta_{i,R}$ and $Q_{i,loss}$ on spring equinox with $\alpha_t=0.90$. It is seen that the decrement of $Q_{i,loss}$ is in the range of 100-359 kW after considering the cavity effect, and the corresponding increment of $\eta_{i,R}$ is within 4.1-4.7 percent. Moreover, it is seen that $\eta_{i,R}$ is smaller than α_t when the cavity effect is ignored. This is because some rays entering the aperture hit the cavity walls rather than the tubes, and these rays will never be absorbed by the tubes when the cavity effect is ignored. The increment of $\eta_{i,T}$ can also be obtained by considering the variation of $\eta_{i,A}$ in Fig. 18. It is found that this increment is in the range of 2.0-3.8 percent.

Fig. 23. Variations of $\eta_{i,R}$ and $Q_{i,loss}$ on spring equinox with $\alpha_t=0.90$.

In summary, the evaluation of the real-time optical performance for an realistic SPT using the present model has been illustrated above, and the results indicate that this model is an exercisable

496 and useful tool for predicting both the detailed real-time solar flux which is important for the
497 performance optimization and safe operation, and the real-time efficiency which is important for the
498 system design. Some useful suggestions are also offered from the results. In addition, the model can
499 also be applied in the design process of a SPT in the following way. First, the SPT can be designed
500 in the traditional way. Then, the optical performance can be evaluated by present model. Finally, the
501 original design can be revised based on the evaluation results.

502 **6. Conclusions**

503 This work focuses on developing a model to analyze the real-time optical performance of a
504 solar power tower (SPT) with a multi-tube cavity receiver (MTCR). After validation, the real-time
505 optical performance of DAHAN plant was studied to illustrate the application of the model. The
506 following conclusions are derived.

507 (1) The real-time solar flux distribution in the MTCR exhibits a great non-uniform
508 characteristic, and the maximum flux ($q_{l,max}$) on the tubes is up to $5.141 \times 10^5 \text{ W} \cdot \text{m}^{-2}$.

509 (2) A tracking-error model which treats the tracking errors as the errors of the tracking angles
510 is recommended to SPT for considering the random effects of the errors on the flux uniformity and
511 efficiency.

512 (3) The multi-point aiming strategy which can greatly homogenize the solar flux compared to
513 the traditional one-point strategy is recommended to SPT. The maldistribution index and $q_{l,max}$ on
514 the tubes can be reduced by 31.6% and 10.5%, respectively, with only a 1 percent drop in efficiency
515 at typical condition.

516 (4) The cavity effect can improve the optical efficiency throughout the whole year, and the
517 effective absorptivity is 2.2-3.8 percent higher than coating absorptivity. Study on coating
518 absorptivity indicates that the smaller the absorptivity is, the more distinct the effect is. Further
519 studies on the optical efficiencies indicate that DAHAN can achieve the yearly efficiency of 65.9%.

520 (5) The validation study and simulation results indicate that the present model is reliable and
521 suitable for dealing with the complex geometry and optical processes in the SPT with a MTCR, and
522 it can predicts both the detailed solar flux and the real-time efficiency appropriately.

523 Acknowledgements

524 The study is supported by the funding for Key Project of National Natural Science Foundation
 525 of China (No.51436007) and the Major Program of the National Natural Science Foundation of
 526 China (No. 51590902).

527 Appendix

528 The transformation matrixes among the seven Cartesian right-handed coordinate systems are
 529 summarized as follows:

530 (1) M_1 and M_2 are the transformation matrixes from $X_i Y_i Z_i$ to $X_g Y_g Z_g$:

$$531 \quad \begin{aligned} M_1 &= \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos(\pi/2 - \alpha_s) & -\sin(\pi/2 - \alpha_s) \\ 0 & \sin(\pi/2 - \alpha_s) & \cos(\pi/2 - \alpha_s) \end{bmatrix} \\ M_2 &= \begin{bmatrix} \cos(A_s + \pi/2) & -\sin(A_s + \pi/2) & 0 \\ \sin(A_s + \pi/2) & \cos(A_s + \pi/2) & 0 \\ 0 & 0 & 1 \end{bmatrix} \end{aligned} \quad (1)$$

532 where α_s and A_s are the solar altitude and azimuth.

533 (2) M_3 and M_4 are the transformation matrixes from $X_g Y_g Z_g$ to $X_h Y_h Z_h$:

$$534 \quad \begin{aligned} M_3 &= \begin{bmatrix} \cos(A_h + \pi/2) & \sin(A_h + \pi/2) & 0 \\ -\sin(A_h + \pi/2) & \cos(A_h + \pi/2) & 0 \\ 0 & 0 & 1 \end{bmatrix} \\ M_4 &= \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos(\pi/2 - \alpha_h) & \sin(\pi/2 - \alpha_h) \\ 0 & -\sin(\pi/2 - \alpha_h) & \cos(\pi/2 - \alpha_h) \end{bmatrix} \end{aligned} \quad (2)$$

535 where α_h and A_h are the altitude and azimuth of the heliostat's center normal.

536 (3) M_5 and M_6 are the transformation matrixes to introduce slope error:

$$537 \quad M_5 = \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos \theta_2 & -\sin \theta_2 \\ 0 & \sin \theta_2 & \cos \theta_2 \end{bmatrix}, M_6 = \begin{bmatrix} \cos(\theta_1 + \pi/2) & -\sin(\theta_1 + \pi/2) & 0 \\ \sin(\theta_1 + \pi/2) & \cos(\theta_1 + \pi/2) & 0 \\ 0 & 0 & 1 \end{bmatrix} \quad (3)$$

$$538 \quad \begin{cases} \theta_1 = \begin{cases} \cos^{-1} \left(\cos \alpha_{h,ideal} / \sqrt{\cos^2 \alpha_{h,ideal} + \cos^2 \beta_{h,ideal}} \right), & \cos \beta_{h,ideal} \geq 0 \\ 2\pi - \cos^{-1} \left(\cos \alpha_{h,ideal} / \sqrt{\cos^2 \alpha_{h,ideal} + \cos^2 \beta_{h,ideal}} \right), & \cos \beta_{h,ideal} < 0 \end{cases} \\ \theta_2 = \gamma_{h,ideal} \end{cases} \quad (4)$$

$$539 \quad \mathbf{N}_{h,ideal} = \begin{bmatrix} \cos \alpha_{h,ideal} \\ \cos \beta_{h,ideal} \\ \cos \gamma_{h,ideal} \end{bmatrix} = \begin{bmatrix} -x_{P,h} / \sqrt{x_{P,h}^2 + y_{P,h}^2 + (z_{P,h} - 2D_{H,o})^2} \\ -y_{P,h} / \sqrt{x_{P,h}^2 + y_{P,h}^2 + (z_{P,h} - 2D_{H,o})^2} \\ -(z_{P,h} - 2D_{H,o}) / \sqrt{x_{P,h}^2 + y_{P,h}^2 + (z_{P,h} - 2D_{H,o})^2} \end{bmatrix} \quad (5)$$

540 where θ_1 and θ_2 are angle variables; $\mathbf{N}_{h,ideal}$ is the ideal normal vector at $\mathbf{P}_h = [x_{P,h} \ y_{P,h} \ z_{P,h}]^T$.

541 (4) $\mathbf{M}_7$ and $\mathbf{M}_8$ are the transformation matrixes from $X_h Y_h Z_h$ to $X_g Y_g Z_g$:

$$542 \quad \mathbf{M}_7 = \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos(\pi/2 - \alpha_h) & -\sin(\pi/2 - \alpha_h) \\ 0 & \sin(\pi/2 - \alpha_h) & \cos(\pi/2 - \alpha_h) \end{bmatrix} \quad (6)$$

$$\mathbf{M}_8 = \begin{bmatrix} \cos(A_h + \pi/2) & -\sin(A_h + \pi/2) & 0 \\ \sin(A_h + \pi/2) & \cos(A_h + \pi/2) & 0 \\ 0 & 0 & 1 \end{bmatrix}$$

543 (5) $\mathbf{M}_9$ is the transformation matrix from $X_g Y_g Z_g$ to $X_r Y_r Z_r$:

$$544 \quad \mathbf{M}_9 = \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos\left(\frac{\pi}{2} - \alpha_r\right) & \sin\left(\frac{\pi}{2} - \alpha_r\right) \\ 0 & -\sin\left(\frac{\pi}{2} - \alpha_r\right) & \cos\left(\frac{\pi}{2} - \alpha_r\right) \end{bmatrix} \begin{bmatrix} 0 & 1 & 0 \\ -1 & 0 & 0 \\ 0 & 0 & 1 \end{bmatrix} \quad (7)$$

545 where α_r is the altitude of the MTCR.

546 (6) $\mathbf{M}_{10}$ and $\mathbf{M}_{11}$ are the transformation matrixes from $X_r Y_r Z_r$ to $X_t Y_t Z_t$:

$$547 \quad \mathbf{M}_{10} = \begin{bmatrix} \cos(A_{t,r} + \pi/2) & \sin(A_{t,r} + \pi/2) & 0 \\ -\sin(A_{t,r} + \pi/2) & \cos(A_{t,r} + \pi/2) & 0 \\ 0 & 0 & 1 \end{bmatrix} \quad (8)$$

$$548 \quad \mathbf{M}_{11} = \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos(\pi/2 - \alpha_{t,r}) & \sin(\pi/2 - \alpha_{t,r}) \\ 0 & -\sin(\pi/2 - \alpha_{t,r}) & \cos(\pi/2 - \alpha_{t,r}) \end{bmatrix} \quad (9)$$

549 where $\alpha_{t,r}$ and $A_{t,r}$ are the altitude and azimuth of the tube in $X_r Y_r Z_r$, respectively, as shown in Fig. 3.

550 For present MTCR, $\alpha_{t,r}=90^\circ$ and $A_{t,r}=-90^\circ$ for all the tubes.

551 (7) $\mathbf{M}_{12}$ is the transformation matrix from $X_l Y_l Z_l$ to $X_t Y_t Z_t$:

$$\mathbf{M}_{12} = \begin{bmatrix} \cos \theta_t & 0 & \sin \theta_t \\ 0 & 1 & 0 \\ -\sin \theta_t & 0 & \cos \theta_t \end{bmatrix}, \theta_t = \begin{cases} \arccos(z_{P,t} / r_t), & x_{P,t} \geq 0 \\ -\arccos(z_{P,t} / r_t), & x_{P,t} < 0 \end{cases} \quad (10)$$

where $\mathbf{P}_{t,t} = [x_{P,t} \ y_{P,t} \ z_{P,t}]^T$ the intersection a ray and a tube in $X_t Y_t Z_t$; θ_t is the angle shown in Fig. 3, r_t is the tube radius.

(8) $\mathbf{M}_{13}$ and $\mathbf{M}_{14}$ are the transformation matrixes from $X_t Y_t Z_t$ to $X_r Y_r Z_r$:

$$\mathbf{M}_{13} = \begin{bmatrix} 1 & 0 & 0 \\ 0 & \cos(\pi/2 - \alpha_{t,r}) & -\sin(\pi/2 - \alpha_{t,r}) \\ 0 & \sin(\pi/2 - \alpha_{t,r}) & \cos(\pi/2 - \alpha_{t,r}) \end{bmatrix}$$

$$\mathbf{M}_{14} = \begin{bmatrix} \cos(A_{t,r} + \pi/2) & -\sin(A_{t,r} + \pi/2) & 0 \\ \sin(A_{t,r} + \pi/2) & \cos(A_{t,r} + \pi/2) & 0 \\ 0 & 0 & 1 \end{bmatrix} \quad (11)$$

557

558 Nomenclature

<i>A, B, C, D, E</i>	aiming points of the heliostats
A_s	solar azimuth (rad, °)
A_h	azimuth of heliostat's center normal (rad, °)
DNI	Direct Normal Irradiance ($\text{W} \cdot \text{m}^{-2}$)
d	aiming point coordinate value (m)
e_p	power carried by each photon (W)
$E_t(i)$	power absorbed by i th tube
<i>G</i>	tower base
<i>H</i>	center of each heliostat
H_o	height of aperture center (m)
<i>I, N, R</i>	incident / normal / reflection vector
$\mathbf{M}_{1 \sim \mathbf{M}_{14}}$	matrix
L_h	height of the heliostat (m)
n_t, n_h	number of absorber tube / heliostat
N_p	total number of the photon traced in the field
N_{day}	the number of the day in a year
<i>O</i>	aperture center
<i>P</i>	point

Q	solar power (W)
q_l	local solar flux ($\text{W}\cdot\text{m}^{-2}$)
R_{te}	tracking error (rad)
S_e	area of each element (m^2)
t_s	solar time (h)
W_h	width of the heliostat (m)
X, Y, Z	Cartesian coordinates (m)

Greek symbols

α_s	solar altitude (rad, °)
α_h	altitude of heliostat's center normal (rad, °)
α_r	altitude of the MTCR (rad, °)
α_t, α_w	absorptivity of coating / cavity wall
δ	declination (rad, °)
η	efficiency (%)
η_{att}	atmospheric attenuation (%)
θ, θ_t	angle variables on the tubes(°)
θ_i	incident angle on surface (rad, °)
θ_h	heliostat azimuth in the field (rad, °)
ξ	uniform random number between 0 and 1
$\rho_{t,s}, \rho_{t,d}$	specular / diffuse reflectance of coating
ρ_{h1}, ρ_{h2}	reflectance / cleanliness of heliostat
$\rho_{w,s}, \rho_{w,d}$	specular / diffuse reflectance of the wall
σ_E	energy maldistribution index among the tubes (%)
σ_{te}, σ_{se}	standard deviation of tracking / slope error (mrad)
φ	local latitude (rad, °)
ω	hour angle (°)

Subscripts

g, h, r, t, w, l	ground / heliostat / receiver / tube / wall / local parameter
i	instantaneous or incident parameter
d,y	daily/yearly parameter
T,H,R	tube / heliostat field/ receiver symbol for efficiency

559 **References**

560 [1] McGlade C, Ekins P. The geographical distribution of fossil fuels unused when limiting global warming to 2 degrees
561 C. Nature. 2015;517:187-90.

562 [2] Li YS. A liquid-electrolyte-free anion-exchange membrane direct formate-peroxide fuel cell. *Int J Hydrogen Energ.*
563 2016;41:3600-4.

564 [3] Li MJ, Song CX, Tao WQ. A hybrid model for explaining the short-term dynamics of energy efficiency of China's
565 thermal power plants. *Appl Energ.* 2016;169:738-47.

566 [4] Zheng ZJ, He Y, He YL, Wang K. Numerical optimization of catalyst configurations in a solar parabolic trough
567 receiver-reactor with non-uniform heat flux. *Sol Energ.* 2015;122:113-25.

568 [5] Li MJ, He YL, Tao WQ. Modeling a hybrid methodology for evaluating and forecasting regional energy efficiency in
569 China. *Appl Energ.* 2015:DOI:10.1016/j.apenergy.2015.11.082.

570 [6] Daabo AM, Al Jubori A, Mahmoud S, Al-Dadah RK. Development of three-dimensional optimization of a
571 small-scale radial turbine for solar powered Brayton cycle application. *Appl Therm Eng.* 2017;111:718-33.

572 [7] Cheng ZD, He YL, Du BC, Wang K, Liang Q. Geometric optimization on optical performance of parabolic trough
573 solar collector systems using particle swarm optimization algorithm. *Appl Energ.* 2015;148:282-93.

574 [8] Yan J. *Handbook of clean energy systems Volume 1: Renewable Energy*. 1st ed. New York: Wiley; 2015.

575 [9] Salomé A, Chhel F, Flamant G, Ferrière A, Thierry F. Control of the flux distribution on a solar tower receiver using
576 an optimized aiming point strategy: Application to THEMIS solar tower. *Sol Energ.* 2013;94:352-66.

577 [10] Yu Q, Wang Z, Xu E, Li X, Guo M. Modeling and dynamic simulation of the collector and receiver system of
578 1MWe DAHAN solar thermal power tower plant. *Renew Energ.* 2012;43:18-29.

579 [11] Zheng ZJ, He YL, Li YS. An entransy dissipation-based optimization principle for solar power tower plants. *SCI*
580 *CHINA SER E.* 2014;57:773-83.

581 [12] Cui FQ, He YL, Cheng ZD, Li YS. Study on combined heat loss of a dish receiver with quartz glass cover. *Appl*
582 *Energ.* 2013;112:690-6.

583 [13] Wang F, Guan Z, Tan J, Ma L, Yan Z, Tan H. Transient thermal performance response characteristics of
584 porous-medium receiver heated by multi-dish concentrator. *Int Commun Heat Mass.* 2016;75:36-41.

585 [14] Daabo AM, Mahmoud S, Al-Dadah RK. The optical efficiency of three different geometries of a small scale cavity
586 receiver for concentrated solar applications. *Appl Energ.* 2016;179:1081-96.

587 [15] Daabo AM, Mahmoud S, Al-Dadah RK. The effect of receiver geometry on the optical performance of a
588 small-scale solar cavity receiver for parabolic dish applications. *Energy.* 2016;114:513-25.

589 [16] Cheng ZD, He YL, Qiu Y. A detailed nonuniform thermal model of a parabolic trough solar receiver with two
590 halves and two inactive ends. *Renew Energ.* 2015;74:139-47.

591 [17] Wang FQ, Tang ZX, Gong XT, Tan JY, Han HZ, Li BX. Heat transfer performance enhancement and thermal strain
592 restrain of tube receiver for parabolic trough solar collector by using asymmetric outward convex corrugated tube.
593 *Energy.* 2016;114:275-92.

594 [18] Wang FQ, Lai QZ, Han HZ, Tan JY. Parabolic trough receiver with corrugated tube for improving heat transfer and
595 thermal deformation characteristics. *Appl Energ.* 2016;164:411-24.

596 [19] Bellos E, Tzivanidis C, Antonopoulos KA, Gkinis G. Thermal enhancement of solar parabolic trough collectors by
597 using nanofluids and converging-diverging absorber tube. *Renew Energ.* 2016;94:213-22.

598 [20] Qiu Y, He YL, Wu M, Zheng ZJ. A comprehensive model for optical and thermal characterization of a linear
599 Fresnel solar reflector with a trapezoidal cavity receiver. *Renew Energ.* 2016;97:129-44.

600 [21] Abbas R, Montes MJ, Rovira A, Martínez-Val J. Parabolic trough collector or linear Fresnel collector? A
601 comparison of optical features including thermal quality based on commercial solutions. *Sol Energ.* 2016;124:198-215.

602 [22] Bellos E, Mathioulakis E, Tzivanidis C, Belessiotis V, Antonopoulos KA. Experimental and numerical investigation
603 of a linear Fresnel solar collector with flat plate receiver. *Energ Convers Manag.* 2016;130:44-59.

604 [23] Vignarooban K, Xu X, Wang K, Molina EE, Li P, Gervasio D, et al. Vapor pressure and corrosivity of ternary
605 metal-chloride molten-salt based heat transfer fluids for use in concentrating solar power systems. *Appl Energ.*
606 2015;159:206-13.

607 [24] Li P, Van Lew J, Karaki W, Chan C, Stephens J, Wang Q. Generalized charts of energy storage effectiveness for
608 thermocline heat storage tank design and calibration. *Sol Energ.* 2011;85:2130-43.

609 [25] Behar O, Khellaf A, Mohammedi K. A review of studies on central receiver solar thermal power plants. *Renew Sust*
610 *Energ Rev.* 2013;23:12-39.

611 [26] Cheng ZD, He YL, Cui FQ. Numerical investigations on coupled heat transfer and synthetical performance of a
612 pressurized volumetric receiver with MCRT-FVM method. *Appl Therm Eng.* 2013;50:1044-54.

613 [27] Zheng ZJ, Li MJ, He YL. Thermal analysis of solar central receiver tube with porous inserts and non-uniform heat
614 flux. *Appl Energ.* 2015;DOI:10.1016/j.apenergy.2015.11.039.

615 [28] Lim JH, Hu E, Nathan GJ. Impact of start-up and shut-down losses on the economic benefit of an integrated hybrid
616 solar cavity receiver and combustor. *Appl Energ.* 2016;164:10-20.

617 [29] Xu C, Wang ZF, Li X, Sun FH. Energy and exergy analysis of solar power tower plants. *Appl Therm Eng.*
618 2011;31:3904-13.

619 [30] Rodríguez-Sánchez MR, Soria-Verdugo A, Almendros-Ibáñez JA, Acosta-Iborra A, Santana D. Thermal design
620 guidelines of solar power towers. *Appl Therm Eng.* 2014;63:428-38.

621 [31] Du BC, He YL, Zheng ZJ, Cheng ZD. Analysis of thermal stress and fatigue fracture for the solar tower molten salt
622 receiver. *Appl Therm Eng.* 2016;99:741-50.

623 [32] He YL, Wang K, Du BC, Qiu Y, Liang Q. Non-uniform characteristics of solar flux distribution in the concentrating
624 solar power systems and its corresponding solutions: A review (in Chinese). *Chin Sci Bull.* 2016;61:3208-37.

625 [33] Yellowhair J, Ortega JD, Christian JM, Ho CK. Solar optical codes evaluation for modeling and analyzing complex
626 solar receiver geometries. In *SPIE Opt Eng Appl: International Society for Optics and Photonics*; 2014. 91910M-M-9.

627 [34] Vant-Hull LL, Izygon ME, Pitman CL. Real-time computation and control of solar flux density on a central receiver
628 (Solar Two)(protection against excess flux density). *American Solar Energy Society.* Boulder, CO. 1996.

629 [35] Garcia P, Ferriere A, Beziau JJ. Codes for solar flux calculation dedicated to central receiver system applications: A
630 comparative review. *Sol Energ.* 2008;82:189-97.

631 [36] He YL, Xiao J, Cheng ZD, Tao YB. A MCRT and FVM coupled simulation method for energy conversion process
632 in parabolic trough solar collector. *Renew Energ.* 2011;36:976-85.

633 [37] Rinaldi F, Binotti M, Giostri A, Manzolini G. Comparison of linear and point focus collectors in solar power plants.
634 *Enrgy Proced.* 2014;49:1491-500.

635 [38] Mecit AM, Miller FJ, Whitmore A. Optical analysis and thermal modeling of a window for a small particle solar
636 receiver. *Enrgy Proced.* 2014;49:457-67.

637 [39] Yao Z, Wang Z, Lu Z, Wei X. Modeling and simulation of the pioneer 1MW solar thermal central receiver system
638 in China. *Renew Energ.* 2009;34:2437-46.

639 [40] Yu Q, Wang Z, Xu E, Zhang H, Lu Z, Wei X. Modeling and simulation of 1MWe solar tower plant's solar flux
640 distribution on the central cavity receiver. *Simul Model Pract Th.* 2012;29:123-36.

641 [41] Sanchez-Gonzalez A, Santana D. Solar flux distribution on central receivers: A projection method from analytic
642 function. *Renew Energ.* 2015;74:576-87.

643 [42] Cheng ZD, He YL, Cui FQ. A new modelling method and unified code with MCRT for concentrating solar
644 collectors and its applications. *Appl Energ.* 2013;101:686-98.

645 [43] Xu E, Yu Q, Wang Z, Yang C. Modeling and simulation of 1 MW DAHAN solar thermal power tower plant. *Renew*

646 Energ. 2011;36:848-57.

647 [44] Osuna R. Solar thermal industry, success stories and perspectives. Renewable energy for Europe, research in action.

648 European Commission, Brussels 2005.

649 [45] Zang C, Gong B, Wang Z. Experimental and theoretical study of wind loads and mechanical performance analysis

650 of heliostats. Sol Energ. 2014;105:48-57.

651 [46] Yu Q, Wang Z, Xu E. Simulation and analysis of the central cavity receiver's performance of solar thermal power

652 tower plant. Sol Energ. 2012;86:164-74.

653 [47] Badescu V. Theoretical derivation of heliostat tracking errors distribution. Sol Energ. 2008;82:1192-7.

654 [48] Collado FJ. One-point fitting of the flux density produced by a heliostat. Sol Energ. 2010;84:673-84.

655 [49] Qiu Y, Li MJ, He YL, Tao WQ. Thermal performance analysis of a parabolic trough solar collector using

656 supercritical CO₂ as heat transfer fluid under non-uniform solar flux. Appl Therm Eng.

657 2016;DOI:10.1016/j.applthermaleng.2016.09.044.

658 [50] Stine W, Geyer M. Power From The Sun. <http://www.powerfromthesun.net/>. 2001.

659 [51] Qiu Y, He YL, Cheng ZD, Wang K. Study on optical and thermal performance of a linear Fresnel solar reflector

660 using molten salt as HTF with MCRT and FVM methods. Appl Energ. 2015;146:162-73.

661 [52] He YL, Cui FQ, Cheng ZD, Li ZY, Tao WQ. Numerical simulation of solar radiation transmission process for the

662 solar tower power plant: From the heliostat field to the pressurized volumetric receiver. Appl Therm Eng.

663 2013;61:583-95.

664 [53] Xu Y, Cui K, Liu D. The development of a software for solar radiation and its verification by the measurement

665 results on the spot. Energ Tech. 2002;26:237-9.

666 [54] Belhomme B, Pitz-Paal R, Schwarzbözl P, Ulmer S. A new fast ray tracing tool for high-precision simulation of

667 heliostat fields. J Sol Energ. 2009;131:031002.

668 [55] Schmitz M, Schwarzbözl P, Buck R, Pitz-Paal R. Assessment of the potential improvement due to multiple

669 apertures in central receiver systems with secondary concentrators. Sol Energ. 2006;80:111-20.

670 [56] Wang K, He YL, Qiu Y, Zhang YW. A novel integrated simulation approach couples MCRT and Gebhart methods

671 to simulate solar radiation transfer in a solar power tower system with a cavity receiver. Renew Energ. 2016;89:93-107.

672 [57] Cui FQ, He YL, Cheng ZD, Li YS. Modeling of the dish receiver with the effect of inhomogeneous radiation flux

673 distribution. Heat Transfer Eng. 2014;35:780-90.

674 [58] Wang F, Shuai Y, Tan H, Yu C. Thermal performance analysis of porous media receiver with concentrated solar

675 irradiation. Int J Heat Mass Tran. 2013;62:247-54.

676 [59] Binotti M, De Giorgi P, Sanchez D, Manzolini G. Comparison of different strategies for heliostats aiming point in

677 cavity and external tower receivers. J Sol Energ. 2016;138:021008.

678