

Comparison of adsorption systems using natural gas fired fuel cell as heat source, for residential air conditioning

Marc Clausse, Frédéric Meunier, Julien Coulié, Elodie Herail

► To cite this version:

Marc Clausse, Frédéric Meunier, Julien Coulié, Elodie Herail. Comparison of adsorption systems using natural gas fired fuel cell as heat source, for residential air conditioning. International Journal of Refrigeration, 2009, 32 (4), pp.712-719. 10.1016/j.ijrefrig.2009.01.009 . hal-02078634

HAL Id: hal-02078634 https://hal.science/hal-02078634

Submitted on 25 Mar 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

COMPARISON OF ADSORPTION SYSTEMS USING NATURAL GAS FIRED FUEL CELL AS HEAT SOURCE, FOR RESIDENTIAL AIR CONDITIONING

M. Clausse^{1*}, F. Meunier¹

J. Coulié², E. Herail²

1: LGP2ES, Cnam-IFFI (EA21), case 331, 292 rue Saint-Martin, 75141 Paris Cedex 03, France; * corresponding author: e-mail: marc.clausse@cnam.fr, tel: (+33) (0)1 58 80 85 49, fax: (+33) (0)1 40 27 20 47

2: N-GHY, Site Industriel Saint Antoine – ZI Montplaisir
51 rue Isaac Newton, 81000 Albi, France
tel: (+33) (0)5 63 45 73 70, e-mail: elodie.herail@n-ghy.com

ABSTRACT

This article aim is to evaluate the performances of an adsorption system driven thanks to the heat rejected by the post-combustion exhaust gases of a reformer/fuel cell system for residential air-conditioning application. Three adsorption pairs were compared: activated carbon/methanol, silica gel/water and zeolite/water. Taking into account both cooling power and sensitivity to performances of the heat rejection and recovery exchangers, it appears that zeolite 13X/water is

the adsorption pair giving the best performance for this application. Nevertheless, a more detailed model would be of interest to better quantify the heat transfer impact on performance.

Keywords: adsorption, residential air-conditioning, fuel cell, combined heat and power (CCHP)

NOMENCLATURE

c, c _p	specific heat capacity	$(J.kg^{-1}.K^{-1})$
СОР	Coefficient of Performance	(-)
D	Coefficient in Dubinin Astakov eq. (1)	(K ⁻¹)
ΔΗ	heat of adsorption	(J.kg ⁻¹)
L	heat of vaporization	(J.kg ⁻¹)
М	mass	(kg)
ṁ	mass flow rate	(kg.s ⁻¹)
n	Coefficient in Dubinin Astakov eq. (1)	(-)
Р	pressure	(Pa)
q	adsorption capacity	$(kg.kg_{ads}^{-1})$
Ż	heat flux	(W)
Т	temperature	(K)
UA	overall heat transfer coefficient	(W.K ⁻¹)
Greek		
λ	thermal conductivity	$(W.m^{-1}.K^{-1})$
ρ	density	(kg.m ⁻³)
subscripts		
0	saturation	
a	adsorber	
ads	adsorbent	

cd	condenser	
CW	chilled water	
d	desorber	
ev	evaporator	
fl	adsorbate	
gas	fuel cell exhaust gases	
HW	hot water	
1	liquid	
met	metal	
v	volumic	
v	vapor	
Wrej	heat rejection unit fluid	

1 INTRODUCTION

Compared to classical cogeneration systems, fuel cells can prevail from various advantages for residential applications: low noise level, potential for low maintenance, excellent part load management, low emissions and a potential to achieve an overall efficiency of 85-90% even with small units (Onovwiona and Ugursal, 2006). However, only electricity/heating cogeneration has been considered most of the time although few studies can be found on electricity/heat/cold production using absorption units (Weber et al., 2006).

The aim of this paper is to explore the theoretical performances of natural gas fired fuel cell systems using adsorption-based systems for cooling. In the reformer/fuel cell system, various heat fluxes are available at different temperature levels (more than 300 °C for the reformer exhaust gases to 80°C for the PEMFC cooling loop for example). Hence, various options are

available to drive the adsorption system. The adsorption system is designed as simple as possible (no heat/mass recovery) in order to minimize the capital cost and the complexity because of residential application.

This study presents a numerical investigation of the potential performance of such a system in terms of cooling capacity and COP but also in terms of volumic and specific cooling capacity. Three different adsorption pairs are considered (water/zeolite, water/silica gel, methanol/activated carbon).

2 MODEL DESCRIPTION

2.1 Fuel Cell System

The fuel cell system consists of the fuel cell coupled to the reformer where natural gas (NG) is converted to hydrogen. The energy inputs and outputs are represented on Figure 1 for a system tested at N-GHY facilities:

As it can be seen on figure 1, two heat sources can be used to drive an adsorption unit:

- The first one comes from the cooling loop of the fuel cell stack. However, the available power is limited (3.7 kW_h) and the temperature rather low (65 °C). Hence, this source will not be considered but it has to be pointed out that it could be used for hot water production in residential applications.
- The exhaust gases are the second available heat source. The temperature is high (1026 °C) as they come form the post-combustion unit where the remaining hydrogen, which was not used in the fuel cell, is burned. The gases composition is (% volume

basis): N_2 (71.4), CO_2 (11.2), H_2O (17.2) and various trace gases (CO, O_2 , etc.) and the pressure is close to atmospheric.

The heat will be recovered from the exhaust gases by means of an intermediate heat exchanger (HX) between the adsorbers and the gas stream.

2.2 Adsorption unit

The adsorption unit is made of two adsorbers alternately connected to the evaporator or the condenser. The heat is recovered from the post-combustion exhaust gases thanks to the heat recovery heat exchanger (HX_{rec}) while the heat rejection heat exchanger (HX_{rej}) is used to reject the heat to the ambient. The basic cycle for refrigeration by adsorption with no mass or heat recovery is used to keep the system as simple and robust as possible. Hence, the adsorption cycle is divided into four steps: pre-heating, desorption, pre-cooling and adsorption. Whatever the adsorption pair, the components of the adsorption unit are the same (given geometry). They are presented on Figure 2 and their mathematical model described hereafter:

adsorption pair

Three adsorption pairs are tested (adsobent/adsorbate-refirgerant): activated carbon AC35/methanol, zeolithe 13X/water and silica gel RD/water. For the activated carbon AC35/methanol the Dubinin-Astakhov model is used (Passos, 1986 cited by Leite and Daguenet, 2000):

$$q = q_0 \cdot \rho_1(T) \cdot \exp\left(-D\left[T \cdot \ln\left(\frac{P_{sat}}{P}\right)\right]^n\right)$$
(1)

where q_0 is equal to 0.407 dm³/kg_{ads}, D to 3.22 10⁻⁷ K⁻¹ and n to 2.195.

For the silica gel RD/water, the data given by Chua et al. (2002) are used. The authors used Toth model to predict the adsorption equilibrium:

$$q = \frac{K_0 \cdot e^{\Delta H/RT} \cdot P}{\left(1 + \left(\frac{K_0}{q_0} \cdot e^{\Delta H/RT} \cdot P\right)^t\right)^{1/t}}$$
(2)

where K_0 is equal to 7.30 10^{-10} kg.kg_{ads}⁻¹.kPa⁻¹, Δ H to 48474 J.mol⁻¹ (isosteric heat of adsorption), q_0 to 0.45 kg.kg_{ads}⁻¹ and t to 12.

For the 13X/water pair, a three term Langmuir equation is used (Ben Amar, 1993):

$$q = \frac{q_{0,1} \cdot b_1 \cdot P}{1 + b_1 P} + \frac{q_{0,2} \cdot b_2 \cdot P}{1 + b_2 P} + \frac{q_{0,3} \cdot b_3 \cdot P}{1 + b_3 P}$$
(3)

where
$$q_{0,1} = \sum_{i=1}^{3} \frac{a_i}{T^i}; q_{0,2} = \sum_{i=1}^{3} \frac{c_i}{T^i}; q_{0,3} = 0.374 - q_{0,1} - q_{0,2}; b_i = b_{0,i} \exp\left(\frac{E_i}{T}\right)$$

The value of the parameters a_i , c_i , $b_{0,I}$ and E_i are given in Table 1.

The sorption isosteres of the three pairs are plotted together on Figure 3.

adsorber

The heat exchanger of the adsorber consists of fins (aluminum) and tubes (copper). The outer dimensions are: height 0.27 m, width 0.33 m and length 0.65 m. The fin pitch is 7 mm corresponding with a total number of 78 fins. The total heat exchange area is 13 m^2 and the

inner volume is equal to 0.058 m^3 . The tube total mass is equal to 11.47 kg while it is 2.49 kg for the fins which corresponds to an overall Mc_{met} equal to 6630 J.K^{-1} per adsorber. The themal inertia of the adsorber shell is not taken into account as usually its temperature cycling is quite smaller than that of the heat exchanger and the adsorbent.

The temperature inside the adsorber is assumed homogeneous so that the energy balance during the desorption step is given by:

$$\frac{d}{dt} \left\{ \left(Mc_{met} + Mc_{ads} + M_{ads}q_{d}c_{p,fl} \right) T_{d} \right\} - \Delta H_{fl} \cdot M_{ads} \frac{dq_{d}}{dt} =$$

$$\dot{m}_{HW}c_{p,HW} \left(T_{HW,in} - T_{HW,out} \right)$$
(4)

The outlet temperature of rejection fluid is calculated thanks to the following equation:

$$T_{HW,in} = T_{d} + (T_{HW,out} - T_{d}) \cdot e^{-UA_{ads} / (\dot{m}_{HW} c_{p,HWj})}$$
(5)

During the adsorption step, the sensible heat to increase the vapour from the evaporation temperature to the adsorption temperature is taken into account. The mass flow rate of the heat rejection unit is assumed to be equally distributed between the condenser and the adsorber.

$$\frac{d}{dt} \left\{ \left(Mc_{met} + Mc_{ads} + M_{ads}q_{a}c_{pl,fl} \right) T_{a} \right\} - \Delta H_{fl} \cdot M_{ads} \frac{dq_{a}}{dt} = dt$$

$$Mc_{ads}c_{pv,fl} \frac{dq_{a}}{dt} \left(T_{ev} - T_{a} \right) + \frac{\dot{m}_{Wrej}}{2} c_{p,Wrej} \left(T_{Wrej,out} - T_{Wrej,in} \right)$$
(6)

The outlet temperature of rejection fluid is calculated thanks to the following equation:

$$T_{\text{Wrej,in}} = T_a + (T_{\text{Wrej,out}} - T_a) \cdot e^{-UA_{ads} / \left(\frac{\dot{m}_{wrej}}{2}c_{p,wrej}\right)}$$
(7)

where

$$\frac{1}{\mathrm{UA}_{\mathrm{ads}}} = \frac{1}{\mathrm{h}_{\mathrm{Wrej}}\mathrm{A}_{\mathrm{Wrej}}} + \frac{\mathrm{e}_{\mathrm{ads}}}{\lambda_{\mathrm{ads}}\mathrm{A}_{\mathrm{ads}}} + \frac{1}{\mathrm{h}_{\mathrm{ads}}\mathrm{A}_{\mathrm{ads}}}$$
(10)

The values of heat transfer coefficient for the adsorbent can be found in the literature (Meunier, 1998, Poyelle et al., 1999, Chua et al., 2002) while the values for the cooling medium side were calculated. The different parameter values are reported for the different configurations in Table 2. The heating fluid is pressurized glycol-water for AC35/MeOH and RD/H₂O systems, while oil (Therminol 66, SwanTek) is used for 13X/H₂O when the aim is to heat up the adsorber above 170 °C.

Thanks to its higher density, the silica gel RD loaded mass (40.2 kg) is 50 % and 28 % higher than that of the AC35 (26.7 kg) and that of the 13X (34.2 kg), respectively. This is of course a good point as the refrigerant mass depends directly on the adsorbent mass. However, this extra amount of adsorbent mass will increase the thermal inertia of the adsorbers: +97 % for the RD and +52 % for the 13X compared to the AC35.

As it can be seen as well, silica gel RD exhibits an overall heat transfer coefficient close to that of AC35 whereas it is about twice lower for the 13X. This will impact directly the time to heat up or cool down the adsorber and hence the achievable cooling power. However, using oil instead of glycol water as secondary fluid has nearly no impact, which confirms that the heat transfer is limited by the adsorbate side in all cases.

heat recovery heat exchanger (HX_{rec})

In order to avoid hot spots in the adsorbers (which could be deleterious with the use of methanol as working fluid) it was chosen to use a gas/liquid heat exchanger to connect the adsorbers to the warm heat source. As the temperature on the gas side is high, it will be of parallel flow type. Considering the composition of the exhaust gas, the dew point temperature is about 58 °C so that water condensation could not occur, $T_{gas,out}$ staying above this value thanks to the parallel flow configuration. The outlet gas temperature $T_{gas,out}$ is calculated thanks to the following equation:

$$T_{gas,out} = T_{gas,in} + \frac{T_{gas,in} - T_{HW,in}}{r} \cdot \psi_{rec}$$
(11)

where

$$\psi_{\text{rec}} = \frac{r(1 - e^{-m})}{r - 1}; r = -\frac{\dot{m}_{\text{gas}} c_{\text{p,gas}}}{\dot{m}_{\text{HW}} c_{\text{p,HW}}}; m = \frac{UA_{\text{rec}}(1 - r)}{\dot{m}_{\text{gas}} c_{\text{p,gas}}}$$
(12)

Three values for UA_{rec} will be used: 25, 50, 100 W.K⁻¹, which could be converted to heat transfer areas of 0.5, 1 and 2 m² assuming an overall gas/liquid heat transfer coefficient of 50 W.m⁻².K⁻¹.

heat rejection heat exchanger (HX_{rej})

The heat rejection unit is of air coil type, with no fan in order to minimize the electricity consumption of the unit. Hence, on the airside, free convection dominates the heat transfer with heat transfer area of 130 m^2 . The outlet temperature for the liquid is given by:

$$T_{\text{Wrej,out}} = T_{\text{air}} + (T_{\text{Wrej,in}} - T_{\text{air}}) \cdot e^{-UA_{\text{rej}} / (\dot{m}_{\text{wrej}} c_{p,\text{wrej}})}$$
(13)

The coefficient UA_{rec} is determined thanks to usual correlations for forced and free convection. Assuming a temperature pinch of 10 K and a temperature between 30 and 40 °C for the air, the average UA_{air} is 1066 W.K⁻¹ if secondary fluid is glycol-water and only 900 W.K⁻¹ if oil is used.

condenser

For the condensation a plate heat exchanger is used. The plate height is 0.46 m with a width of 0.2 m and fourteen plates are used. The energy balance is written as:

$$\frac{d}{dt} \left(Mc_{cd} T_{cd} \right) + L \cdot M_{ads} \frac{dq_d}{dt} =$$

$$+ M_{ads} c_{pv,fl} \frac{dq_d}{dt} \left(T_{cd} - T_d \right) + \frac{\dot{m}_{Wrej}}{2} c_{p,Wrej} \left(T_{Wrej,out} - T_{Wcd,out} \right)^{(15)}$$

For the thermal inertia, only the metal mass is taken into account, all the fluid being stored in the evaporator ($M_{cd} = 14$ kg and $Mc_{cd} = 5443$ J.kg⁻¹). The temperature $T_{Wcd,out}$ is given by:

$$T_{\text{Wcd,out}} = T_{\text{cd}} + (T_{\text{Wrej,out}} - T_{\text{cd}}) \cdot e^{-UA_{\text{cd}} / \left(\frac{\dot{m}_{\text{Wrej}}}{2}c_{p,\text{Wrej}}\right)}$$
(16)

 UA_{cd} is calculated thanks to the correlations given by Würfel and Ostrowski (2004) for the determination of the heat transfer coefficient on condensing and secondary fluid sides. Values for the different fluids are reported in Table 3 for a flow rate of 0.5 kg.s⁻¹ for the secondary fluid and a condensing temperature of 40 °C.

Using methanol instead of water results in a heat transfer coefficient decrease of about 46-50 %, depending on the flow rate. As it will be seen in section 3, as the condenser geometry is given, the condensing temperature will be higher for MeOH than for water.

Thanks to early estimation of the refrigerant flow rate, its impact on the heat transfer coefficient was studied. Decreasing the refrigerant flow rate by a factor of 2.5 decreases the heat transfer coefficient by 26 % for methanol and 19 % for water. To take into account this parameter while keeping a rather simple model, a mean value will be used in the calculations.

Using oil instead of glycol water as secondary fluid lowers the performances by about 80 %. Again, this will result in higher condensing temperature.

evaporator

A tube and shell heat exchanger is used as evaporator (length: 1.5 m, 34 tubes of 6 mm outer diameter and an inner diameter of 90 mm for the shell). It is equipped with a pump to recirculate the refrigerant. The chilled water return temperature $T_{CW,in}$ is assumed constant (12°C) while the outlet temperature $T_{CW,out}$ will be determined thanks to an equation equivalent to eq. (16). The evaporator energy balance is given by:

$$\frac{d}{dt} \left\{ \left(Mc_{ev,M} + MC_{ev,fl} \right) T_{ev} \right\} + L \cdot M_{ads} \frac{dq_a}{dt} =$$

$$+ M_{ads} c_{pl,fl} \frac{dq_d}{dt} \left(T_{ev} - T_{cd} \right) + \dot{m}_{CW} c_{p,CW} \left(T_{CW,in} - T_{CW,out} \right)$$
(17)

Thanks to a recirculation pump the evaporation can take place on falling film mode, so that the correlations given by Liu et al. (2002) are used for the determination of UA_{ev} . The recirculation rate is taken equal to five and UA_{ev} values are reported in Table 3.

The same behaviour than for the condenser is found, with heat transfer coefficient decreased when using methanol instead of water. However, the decrease is only about 25-29 % compared to nearly 50 % for the condenser. In the same way, the impact of the mass flow rate is rather limited: between -10 and -14 %. Hence, as for the condenser, average values will be used during the calculation.

3 RESULTS

The set of ODE/DAE is solved using DASPK 2.0 solver. Performances and operating temperature as a function of the half cycle time for the three adsorption pairs are reported in Figure 4 for the cooling power and COP and on Figure 5 for the chilled water and condensation average temperature (cycle basis) and for the maximum temperature reached in the adsorber (end of desorption step). For convenience, the reduced half-cycle time was used; it is equal to the ratio of the half-cycle time to the maximum one (2000 s for RD/H₂O and AC35/MeOH and 4000 s for $13X/H_2O$).

From the three pairs, the silica gel RD/H₂O one appears to be the less competitive one. The maximum cooling power is 3.27 kW for a COP of 0.42 compared to 4 kW for COP = 0.51 and 3.78 kW for COP = 0.52 for AC35/MeOH and 13X/H₂O, respectively. This could be explained by the limited mass cycled because of isotherm characteristics. To highlight this point, the theoretical cycles obtained at maximum cooling power (i.e., the condensing and evaporating temperature are the averaged values given on figure 5) were plotted on figure 6. For RD the amount adsorbed is equal to 38 g.kg_{ads}⁻¹ at the end of the adsorption step and 8.8 g.kg_{ads}⁻¹ at the end of the desorption step. So, the corresponding cycled mass is almost equal to 30 g.kg_{ads}⁻¹. At optimal operation, these values are equal to 348 ; 86 and 262 g.kg_{ads}⁻¹, respectively for 13X. Hence, the ratio is about 8.7 in terms of cycle mass per kg of adsorbent. The higher density and global heat transfer coefficient of RD over 13X are not sufficient to overcome this aspect. It has

to be noticed as well that RD is designed to work at low driving temperature (figure 6), which could explain as well its rather poor performance in our case.

The AC35/MeOH exhibits the greatest performances. However, as the adsorbent temperature should not exceed 130 °C because of component chemical stability, it is not possible to operate at maximum cooling power. Referring to Figure 5, 130 °C is reached at the end of desorption step for a reduced half-cycle time of 0.45 (900 s). The corresponding cooling power and COP are 3.8 kW and 0.48, respectively, which is still competitive compared to 13X performances. It should be noticed that the condensing temperatures are higher for AC35/MeOH compared to the two others: about 44 °C compared to 41 °C. This is directly linked to lower condensing heat transfer coefficient for methanol compared to water (cf. Table 3).

Concerning the 13X/H₂O pair, longer cycle times are needed in order to reach desorption temperature high enough to allow cold production. Hence, for the first reported cycle (half-cycle time of 800 s) the temperature at the end of desorption step is worth already 125 °C while the maximum cooling power is achieved for a temperature of 226 °C. For such high temperature, it is more suitable to use oil than pressurized glycol-water for secondary fluid. However, with oil, the heat transfer coefficients are smaller as it can be seen in section 2. The results are presented on Figures 7 and 8 for the three adsorption pairs for an external temperature of 40 °C.

The increase by 10 K of the air temperature has the following consequences:

- the installation with AC35/MeOH cannot operate because end of desorption temperature above 130 °C
- for 13X and RD the maximum cooling power is decreased by 11% and 22%, respectively for COP values of 0.5 and 0.34.

 using oil instead of pressurized glycol-water results in a diminution by 11% of 13X/H₂O system performances. This is directly linked to the worst heat transfer coefficient for the condenser and the heat rejection unit: the condensation temperature increases by 10 K reaching 60 °C.

The influence of the global heat transfer coefficient for the heat rejection and heat recovery HXs' were addressed. The results for the maximum cooling power are presented in Table 4. The heat rejection unit appears to be the key element of the installation as it can severely limit the system performances: for example an increase of 38% of UA_{rej} allows increasing by 11 to 20% the cooling power for AC35/MeOH depending on UA_{rec} value. At given UA_{rej}, the interest of increasing UA_{rec} remains limited as it can result in performance degradation for MeOH (because of the maximum operating temperature at 130 °C) or limited increase: for 13X at UA_{rej} = 820 W/K, multiplying UA_{rec} by four increases the cooling power by only 5%. From these results, it can be concluded that if the AC32/MeOH delivers the highest cooling power (3.96 kW for UA_{rej} = 1312 W/K and UA_{rec} = 100 W/K) it is more sensitive to the heat exchangers performances than the 13X/H₂O. Indeed, its cooling power ranges from 3.28 kW to 3.96 kW while it ranges only from 3.55 to 3.82 kW for the 13X. It means that the 13X/H₂O system will offer rather stable performances whatever the ambient outdoor temperature, which will make easier to meet the specification.

4 CONCLUSION

A model of a poly-generation installation based on a fuel cell system was built. This model takes into account the thermodynamic aspects but also heat transfer as they can easily limit the performances of an adsorption system.

The AC35/MeOH offers the best performance in terms of cooling power and compactness. However, a control system would have to control the maximum desorption temperature to avoid rapid degradation of the unit because of methanol dissociation. In all cases, the performances are highly sensitive to the performances of the heat rejection unit.

Hence, the best choice appears to be the $13X/H_2O$ system, which exhibits robust performances whatever the heat exchanger performance. Furthermore, the control of such a system will be easier than that of the AC35 one as there is no need to control precisely the adsorber temperature.

To go further, taking into account more precisely the temperature dependency of the thermophysics properties could enhance the model. This can have a high impact on heat transfer coefficient value. Furthermore, different strategies could be compared with the use of storage tank between the heat recovery HX and the adsorber in order to lower the driving temperature.

Reference

Ben Amar, N., 1993. Modélisation de pompes à chaleur à propagation de front de température,Ph. D. thesis, Université de Compiègne

Ben Amar, N., Sun, L.M., Meunier, F., 1996. Numerical analysis of adsorptive temperature wave regenerative heat pump, Applied Thermal Engineering, 16, 405-418

Chua, H.T., Ng, K.C., Chakraborty, A., Oo, N.M., Othman, M., 2002. Adsorption Characteristics of Silica Gel + Water Systems, Journal of Chemical Engineering Data 47, 1177-1181 Leite, A.P.F., Daguenet, F., 2000. Performance of a new solid adsorption ice maker with solar energy regeneration, Energy Conversion Management 41, 1625-1647

Onovwiona, H.I., Ugursal V.I., 2006. Residential cogeneration systems: Review of the current technology. Renewable and Sustainable Energy Reviews, 10, 389-431

Lamari, M., Aoufi, A., Malbrunot, P., 2000. Thermal effect in dynamic storage of hydrogen by adsorption. AIChE Journal 46, 632-646

Liu, Z.-H., Zhu, Q.-Z., Chen, Y.-M., 2002. Evaporation heat transfer of falling water film on a horizontal tube bundle. Heat Transfer-Asian Research 31, 42-54

Meunier, F., 1998. Solid sorption heat powered cycles for cooling and heat pumping applications. Applied Thermal Engineering 18, 715-729

Passos, E.F., 1986, Etude des couples charbon-actif méthanol et leur application à la réfrigération solaire. Ph.D. Thesis, Federal Polytechnic College of Lausanne, Switzerland

Poyelle, F., Guilleminot, J.-J., Meunier, F., 1999. Experimental tests and predictive model of an adsorptive air conditioning unit. Industrial Engineering and Chemistry Research 39, 298-309

Weber, C., Maréchal, F., Favrat, D., Kraines, S., 2006, Optimization of an SOFC-based decentralized polygeneration system for providing energy service in an office-building in Tokyo. Applied Thermal Engineering 26, 1409-1419

Würfel, R., Ostrowski, N., 2004, Experimental investigations oh heat transfer and pressure drop during the condensation process within plate heat exchangers of the herringbone-type, International Journal of Thermal Sciences 43, 59-68

Figure Captions

Figure 1: Energy inputs and outputs of the fuel cell system

Figure 2: Description of the adsorption unit

Figure 3: Sorption isosteres of the three adorbent/adsorbate pairs: A Activated carbon

AC35/MeOH; ◆ Silica Gel RD/H₂O ■ Zeolite 13X/H₂O

Figure 4: Evolution of cooling power and COP for different half-cycle times

Figure 5: Evolution of the operating temperatures for different half-cycle times

Figure 6: RD/H₂O (\blacklozenge) and 13X/H₂O (\blacksquare) theoretical cycles based on averaged condensing and evaporating temperatures

Figure 7: Evolution of cooling power and COP for different half-cycle times with $T_{air} = 40 \text{ }^{\circ}\text{C}$

Figure 8: Evolution of the operating temperatures for different half-cycle times with $T_{air} = 40^{\circ}C$