Optimal sizing of distributed generation in gas/electricity/heat supply networks

Bei Li, Robin Roche, Damien Paire, Abdellatif Miraoui

► To cite this version:

Bei Li, Robin Roche, Damien Paire, Abdellatif Miraoui. Optimal sizing of distributed generation in gas/electricity/heat supply networks. *Energy*, 2018, 151, pp.675 - 688. hal-02131089

HAL Id: hal-02131089

<https://hal.science/hal-02131089>

Submitted on 16 May 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Optimal sizing of distributed generation in gas/electricity/heat supply networks

Bei Li^{a,c,*}, Robin Roche^{a,c}, Damien Paire^{a,c}, Abdellatif Miraoui^{b,c}

^aFEMTO-ST, CNRS, Univ. Bourgogne Franche-Comte, UTBM, rue Thierry Mieg, F-90010 Belfort Cedex, France

^bUniv. Bourgogne Franche-Comte, UTBM, rue Thierry Mieg, F-90010 Belfort Cedex, France

^cFCLAB, CNRS, Univ. Bourgogne Franche-Comte, rue Thierry Mieg, F-90010 Belfort Cedex, France

Abstract

Multi-energy supply systems are expected to play an important role in smart grids. Today's energy supply systems are large nodes networks, and different types of energy are needed at each node to satisfy the different energy demands. These different types of energy can then be converted to each other through specific devices. How to decide the ratings of these devices at each node to make the system cost-effective is addressed in this paper. The focus is set on a gas/electricity/heat hybrid network. A hydrogen storage system (fuel cell, electrolyzer, and tanks) is used as electricity storage system, a combined heat and power device is used to produce heat and electric power, etc. A mixed integer linear programming algorithm is used to determine the optimal operation schedule of the system, where the goal is to minimize shed load. A genetic algorithm is also used to search for the best size of each component, where the goal is to minimize the total investment costs. In order to resist to contingency events, betweenness centrality (describing the relative importance of each node) is then used to find the worst case under contingency events. This worst case scenario is used to research about the influence of contingencies on the sizing results. At last, two cases (modified 13-node network and IEEE 30 + Gas 20 + Heat 14 nodes system) are tested using the proposed sizing method. The results show that the renewable energy location, investment cost of components, and the structure of the whole system influence the sizing results. When the installed capacity of photovoltaic panels is reduced by 50%, the capacity of the electrolyzer decreases by 3%, the capacity for the hydrogen tanks increases by 2%; when the investment cost of the fuel cell and electrolyzer decreases by 50%, the capacity of photovoltaic increases by 14%, the electrolyzer increases by 13%, and hydrogen tanks increase by 2%. After considering the worst case contingency event, for case I, the capacity of photovoltaic and fuel cell increase by 12% and 11%, and the electrolyzer increases by 34%; for case II, the capacity of photovoltaic and fuel cell increase by 8% and 11%, and the electrolyzer increases by 57%.

Keywords: sizing, multi-energy system, gas/electricity/heat, hydrogen storage system, optimization

1 Nomenclature

2 Acronyms

3 CCHP combined cooling heat and power

4 CHP combined heat and power

5 DG distributed generation

6 EA evolutionary algorithm

7 EH energy hub

8 GA genetic algorithm

9 MG microgrid

10 MILP mixed integer linear programming

11 MINLP mixed integer nonlinear programming

12 Parameters

13 α penalty values for load shedding of gas demands

14 β penalty values for load shedding of electricity demands

15 γ penalty values for load shedding of heat demands

16 C_{inv} investment cost of each component

17 eff_{CHP} gas utilization efficiency of CHP to consume gas

18 eff_{ch} efficiency to produce H_2 through the electrolyzer

19 eff_{ETH} efficiency of ETH to produce heat

20 eff_{GTH} efficiency of GTH to produce heat

21 eff_{heat} fuel cell efficiency to produce heat

22 eff_{re} heat recovery efficiency of CHP

23 $L_{el}^{i,t}$ electricity load demands at node i and time t (MW)

24 $L_{gas}^{i,t}$ gas load demands at node i and time t (MW)

25 $L_{heat}^{i,t}$ heat load demands at node i and time t (MW)

*Corresponding author.

Email addresses: bei.li@utbm.fr (Bei Li), robin.roche@utbm.fr (Robin Roche), damien.paire@utbm.fr (Damien Paire), abdellatif.miraoui@utbm.fr (Abdellatif Miraoui)

26	$P_{line}^{el,m,n,max}$	maximum electricity power flow from m to n
27	$P_{line}^{gas,m,n,max}$	maximum gas power flow from m to n
28	$P_{line}^{heat,m,n,max}$	maximum heating power flow from m to n
29	Variables	
30	C_{gs}^i	capacity of H ₂ storage tanks at node i (MWh)
31	$LS_{el}^{i,t}$	load shedding of electricity demands at node i and time t
32		
33	$LS_{gas}^{i,t}$	load shedding of gas demands at node i and time t
34	$LS_{heat}^{i,t}$	load shedding of heat demands at node i and time t
35	$onoff_{ele}^{i,t}$	ON/OFF state of the electrolyzer at node i and time t
36	$onoff_{fc}^{i,t}$	ON/OFF state of the fuel cell at node i and time t
37	$P_{CHP}^{i,max}$	capacity of a CHP at node i (MW)
38	$P_{ele}^{i,max}$	capacity of a electrolyzer at node i (MW)
39	$P_{ETH}^{i,max}$	capacity of an ETH at node i (MW)
40	$P_{fc}^{i,max}$	capacity of a fuel cell at node i (MW)
41	$P_{GTH}^{i,max}$	capacity of a GTH at node i (MW)
42	$P_{line}^{el,m,n,t}$	electricity power flow from node m to node n at time t
43	$P_{line}^{gas,m,n,t}$	gas power flow from node m to node n at time t
44	$P_{line}^{heat,m,n,t}$	heating power flow from node m to node n at time t
45	P_{PV}^i	capacity of a PV source at node i (MW)
46	$S_{gs}^{i,t}$	state of the H ₂ storage tanks at node i and time t
47	$Z_{CHP}^{i,t}$	output power of the CHP at node i and time t
48	$Z_{ele}^{i,t}$	output power of the electrolyzer at node i and time t
49	$Z_{ETH}^{i,t}$	output power of the ETH at node i and time t
50	$Z_{fc}^{i,t}$	output power of the fuel cell at node i and time t
51	$Z_{GTH}^{i,t}$	output power of the GTH at node i and time t
52	$Z_{PS}^{el,i,t}$	output power of the electric generator at node i and time t
53		
54	$Z_{PS}^{gas,i,t}$	output power of the gas source at node i and time t
55	$Z_{PS}^{heat,i,t}$	output power of the heating source at node i and time t

1. Introduction

Today's energy supply systems mostly consist of large transmission networks, such as the electricity network and gas supply network. Normally, these energy supply networks are planned separately. Load demands often include several types of energy in the same time step. For example, when people use gas to cook, they also need electricity to serve electronic devices, and heat energy to heat the room. These large energy supply systems can co-operate together to improve the efficiency of the whole energy supply system. Co-operating can indeed make the whole system operate in an optimal state, while ensuring the power balance of different energy supplies. The main interest of this approach is that at each interconnection node, different types of energy can be converted to each other through power devices. For example, fuel cells can be used to convert H₂ to electricity, electrolyzers can be used to convert electricity to H₂, gas turbines can be used to convert gas to heat, etc. At each node, renewable energy can also be connected, such as with photovoltaic (PV) panels and wind turbines.

This paper intends to contribute to addressing the following problem: how to determine the ratings of these power devices and renewable energy sources at each interconnection node, based on a given multi-energy network topology? In this work, a modified 13-node network is considered, and three types of gas/electricity/heat load demands are served. The selected electricity network is the IEEE 13-node network [1], and the gas and heating networks are assumed to have the same structure, as shown in Fig. 1). In this figure, HS represents a hydrogen storage system (fuel cell, electrolyzer and tanks), which has several advantages, such as a high storage capacity, and a high energy per unit of volume [2]; CHP is a combined heat and power device; ETH is a device that converts electricity to heat, a heat boiler for example; GTH is a device that converts gas to heat, a gas boiler heater for example. Black lines represent the gas supply system, blue lines the electricity supply system, and red lines the heat supply system.

At each node, the devices and load demands can be formed as a microgrid (MG) or an energy hub (EH). In [3], authors design a combined cooling/heat/power and hydrogen MG system, and present a combined genetic algorithm (GA) and mixed integer linear programming (MILP) method to size such multi-energy supply MG. GA is used to search for the sizing values, MILP is used to control the operation of MG. In [4], authors present a smart EH framework to deploy an integrated demand response program (considering electricity and natural gas demands). The goal is to maximize the natural gas and electricity utility companies' profit and to minimize the customers' consumption cost. The problem is formulated as a non-cooperative game.

For MG, the emphasis is on islanded operation ability, which can improve the system resilience when the utility grid is damaged under natural disasters. Authors in [5] use gas-based and hydrogen-based MG to improve resilience to disasters. A hybrid energy supply (electricity/gas/hydrogen) system is built, and Monte Carlo simulation is used to simulate the influence of disasters. For EH, the emphasis is on the energy dispatching efficiency, which can reduce the waste of fuel and improve the

energy utilization efficiency, or act as a load serving entity to deploy integrated demand response [4].

In this paper, renewable energy is integrated and an MG is formed at each node. The detailed structure of the MG at node is shown in Fig. 2.

Figure 1: Gas/electricity/heat network structure.

Figure 2: Microgrid structure at each node.

A multi-energy MG can interconnect with the utility grid, and can also operate in islanded mode. When the utility grid is severely damaged under natural disasters, the islanded MG can still operate to supply the load demands using the local renewable energy and the storage systems. If the utility grid is partially destroyed, the MG power imports from the utility grid are limited, due to damage on transmission lines or pipelines. This paper discusses how such large power devices and PV panels should be installed and sized in each MG. A combined algorithm is presented to size the components in MG to resist to contingency events (namely, some transmission lines are destroyed). Firstly, an optimization method is used to describe the power flow in the whole system, where the objective function is to minimize the investment cost and the unserved load. The constraints are to ensure the power balance and meet capacity limitations. Then, a GA is used to search for the optimal sizing value of each component. After that, two cases are simulated: the first case is a modified 13-node hybrid system, and the second case is a IEEE20 + gas20 + heat14-node hybrid system. Graph theory is used to find the worst case based on betweenness centrality, when the electric system is damaged under con-

tingency events.

The remainder of this paper is organized as follows. Section 2 introduces related work. Section 3 describes the problem formulation, and Section 4, 5 the simulation results. Finally, Section 6 concludes the paper.

2. Related work

In this section, related works about the optimal sizing problem of multi-energy supply systems are presented. This problem includes two aspects: 1) the operation problem, which describes the power flow in the whole system; 2) the sizing problem, which determines the sizing values of each component.

2.1. Operation problem

To decide the sizing values of each component, firstly, one needs to describe the operation of the whole system. Many works have been done about the optimal operation of multi-energy supply system. The operation problem is often described as a mixed integer programming problem.

In [6], authors present a mixed integer nonlinear programming (MINLP) model for short-term 24-h scheduling of an EH, in which the objective is to fulfill the daily cooling/heating/electric demands with maximum profit. [7] presents a mathematic model for the operational schedule of residential energy supply (electricity and heat) based on microgeneration. The objective function is to minimize the total cost. Results show that the microgeneration-based energy supply system overwhelms other counterparts (boiler systems, standalone operation). [8] presents a smart home energy management model, which is formulated as an MILP problem. The objective is to minimize the overall energy cost as well as peak demand from the main grid. The appliance consumption cycle is initiated based on its starting probability, and a new discomfort index is proposed, which is defined as the load deviation from the most desired load. [9] presents a short-term scheduling problem of single domestic-size microgrids. The problem is described as an MILP model and extended to a unit commitment problem. Two time models are compared: a discrete time model and a hybrid time formulation model. In the discrete time-based model, decisions related to energy production and consumption are taken at the beginning of each time interval. In the hybrid time representation model, energy production decisions are the same as in the previous model, but the decisions related to energy consumption can be taken continuously. Further, authors in [10] present a 30-minute scheduling approach for electricity and heat demands in a microgrid. Delays in the starting times and eventual interruptions during the performance of tasks are allowed to exploit the benefits of flexibility in the energy demand. The problem is formulated as an MILP problem to minimize the operation costs of the microgrid. [11] presents a multi-objective energy management algorithm to schedule the consumption in smart homes. The two conflicting objectives are to minimize the daily energy cost and CO₂ emissions. The model is described as an MILP problem. The ϵ -constraint method is used to solve the multi-objective optimization problem.

The above papers discuss the operation problem of EH, residential supply, smart homes and microgrids. Some variables need to be considered, such as on/off states (binary variables) and output/input powers (continuous variables), which makes the problem challenging. MILP problems consider both binary and continuous variables and can be solved using a linear programming-based branch-and-bound algorithm [12]. The optimal scheduling set points are determined based on current and future conditions, which can guarantee obtaining the global optimal results.

2.2. Sizing problem

Many works have also been presented about the optimal sizing and siting of distributed generation (DG) in electric power systems. [13] reviews classical and heuristic approaches for optimal sizing and placement of DG units in distribution networks. In [14], DG allocation problems are reviewed from the viewpoint of the used optimization algorithms, objectives, decision variables, DG type, applied constraints, and kind of uncertainty models. Papers show that metaheuristic-based approaches are effective in solving the DG allocation problem and are the most common approaches for solving this problem, but these approaches may converge into false local optima rather than the global optimum.

In [15], authors propose an independent system operator (ISO) model for coordinating transmission expansion planning with competitive generation capacity planning in electricity markets. The security-constrained planning problem consists of three problems: transmission capacity planning (maximizing the investment profits), security assessment (minimizing real power mismatch at each bus) and optimal operation (maximizing the revealed surplus based on submitted bids for generation, demand, and incremental transmission). At last, a modified IEEE 30-bus system is used to evaluate the method. [16] presents an algorithm for microgrid planning as an alternative to the co-optimization of generation and transmission expansion planning in electric power systems. The problem is decomposed into a planning problem and an annual reliability subproblem. When the annual reliability limits are violated, the planning decisions are revised using proper feasibility cuts. The method is tested on a modified IEEE 118-bus system. In [17], authors present a microgrid planning model. This problem is decomposed into an investment master problem and an operation subproblem. These problems are linked via the benders decomposition method. [18] describes an approach to address the microgrid expansion planning problem. The master problem is to maximize the profit of individual investors, the second layer problem is to check the reliability criteria, and the third layer problem is to minimize the operation cost. The proposed method is examined on a four-bus test system. [19] presents an electric expansion planning approach, which includes three options for network expansion as generating units (i.e., wind, solar, and diesel), ESS, and lines. The problem is described as a two-level MINLP problem, where the first level is to minimize the planning cost, and the second level is to minimize the operation cost. Both problems are solved by a hybrid metaheuristic optimization technique which collects the benefits of

particle swarm optimization (PSO), cultural algorithm, and co-evolutionary algorithms at the same time.

The above papers use co-optimization methods to solve the microgrid planning problem. This method decomposes the planning problem into a master problem and a subproblem which can consider two time scales: long term planning and short term operation. The master problem aims to search for the planning results, and the subproblem is to evaluate the correctness of the operation problem. In this paper, the sizing problem of multi-energy supply system is similar to the planning problem, which can be solved effectively by the co-optimization method.

Some works about the sizing problem of multi-energy microgrids have also been published. In [20], authors present an MILP model for the optimal design of DG systems coupled with heating, cooling, and power distribution networks, aiming to minimize the annual overall cost. In [21], authors present a deterministic linear programming model to obtain the optimal size of a residential combined heat and power (CHP) plant, and the objective function is to minimize the annual cost of the system. A constant ratio is used to represent the relation between electricity output and heat output. In [22], a multi-objective MINLP model is formulated for the simultaneous system synthesis, technology selection, unit sizing, and operation optimization of a large scale combined cooling heat and power (CCHP) system. The objective function is to minimize the total annual cost and the annual global CO₂ emissions. The augmented ϵ -constraint method is applied to determine the Pareto frontier of the design configuration. [23] presents a two-stage optimal planning and design method for a CCHP MG system. In the first stage, a multi-objective genetic algorithm based on NSGA-II is applied to solve the optimal design problem. The objective function is to minimize the total net present cost and carbon dioxide emissions. In the second stage, an MILP algorithm is used to solve the optimal dispatching problem, where the objective function is to minimize the operation cost. [24] presents a multi-objective optimization approach based on GA for a CHP system within an MG. The two objectives are to minimize the total cost and the total gas emissions from the main grid, boiler and DG units. The operation strategies are 'following electrical load' and 'following thermal load'.

Works about the co-planning of natural gas and power electric systems are also researched. In [25], an integrated electricity and natural gas transportation system planning algorithm is proposed for enhancing the power grid resilience in extreme conditions. The first stage problem is to minimize the investment and the operation costs for the integrated electricity and natural gas. The second stage problem is to minimize load curtailment after the occurrence of the most severe event. The test results on the IEEE RTS1979 system point out that the integrated planning of electricity and natural gas can improve power system resilience. [26] proposes a long-term co-optimization planning model which incorporates natural gas infrastructure planning with power system planning. The investment problem is formulated to optimally determine appropriate candidates for generating units, transmission lines, and natural gas pipelines. The second subproblem is the power

system feasibility and optimality (minimizing the load curtailment). The third subproblem is the natural gas transportation feasibility (minimizing the nodal natural gas load imbalance). At last, the power system reliability is evaluated. [27] proposes an integrated expansion planning framework for gas and power systems. The model aims to maximize the benefit/cost ratio by calculating benefits in operation reduction, carbon emissions reduction and reliability improvement against augmentation investment costs. [28] presents a long term, multiarea, and multi-stage model for supply/interconnections expansion planning of an integrated electricity and natural gas system. The proposed model is formulated as an optimization problem, which minimizes the investment and operation costs to determine the optimal location, technologies, and installation times of any new facility for power generation, power interconnections, and the complete natural gas chain value (supply/transmission/storage) as well as the optimal dispatch of existing and new facilities over a long range planning horizon.

As shown by the above papers, the co-planning method can consider the characteristics of the power system and the natural gas system at the same time, which includes the interactions between both systems on supply and demand sides, and help achieve higher market efficiency in the cost benefit analysis [27].

Based on the above researches on electric power system expansion planning, sizing problems of multi-energy microgrids, and co-planning of gas/electricity systems, some conclusions can be drawn: 1) for the design problem, the time horizon ranges from 18 months to 10 years, or even more, and for the planning problem, the time horizon is from 1 month to 18 months; 2) the planning results must be checked for the operation problem feasibility, with a short time scale and usually a 1-h resolution; 3) the uncertainty on load demand, output of renewable energy and contingency events (such as line damage, natural disasters, etc.) must also be considered.

The following shortcomings can be highlighted concerning the previous studies in the field of multi-energy supply system planning:

1. The previous approaches considered the uncertainty on load demand, output of renewable energy, but do not consider contingency events (such as line damage, natural disasters, etc.).
2. For a multi-energy supply system, the interconnection structure of different types of energy systems must also be considered, because it can influence the energy flow in the whole system, which will then influence the utilization of the power devices, and at last, the planning results will be different.

However, research works about the sizing problem of gas/electricity/heat hybrid systems have not been given a lot of attention so far. [29] researched about the sizing problem of an electricity/heat system, and showed that a single-node aggregate approach (namely, ignore the interconnection structure inside the microgrid) cannot capture the internal energy transfers and the limitations of the electrical/thermal networks.

In our previous paper [30], a co-optimization method combining an evolutionary algorithm (EA) and MILP was used to size a full-electric islanded microgrid. Next, in [3], this method was used to size a multi-energy supply microgrid considering the degradation of hydrogen storage system. In this paper, the co-optimization method is adopted to provide a sizing solution for a hybrid gas/electricity/heat network. The main contributions of this paper are as follows:

1. A multi-node gas/electricity/heat network model is presented, where a hydrogen storage system is used to keep the power balance;
2. An MILP model is used to control the operation of the whole system, and is combined with an EA to solve the sizing problem;
3. Network theory, namely, betweenness centrality, is used to describe the relative importance of nodes;
4. The most important node is destroyed, as the worst case scenario to research about the influence of contingencies on the sizing results;
5. The method is tested on two multi-energy networks (a 13-node hybrid network and a IEEE30 + gas20 + heat14-node network), and shows that the renewable energy location, investment cost of components, and the structure of the whole system influence the sizing values of each component.

3. Problem formulation

The proposed sizing problem approach can be summarized with the diagram shown in Fig. 3. The sizing problem returns the sizing values of each component, and then these values are used to test the correct operation of the system. Based on the results of the operation problem, new sizing values are updated, and this process is repeated until the stopping criterion is satisfied. In this paper, the stopping criterion is the maximum iteration number of GA.

Figure 3: Sizing problem approach diagram.

Assume that a hybrid multi-energy supply network contains N nodes, and at each node $i = 1, \dots, N$, PV panels are connected. The capacity of a PV source at each node is noted P_{PV}^i ; a fuel cell is used to convert H_2 energy to electricity and the capacity

of the fuel cell at each node is $P_{fc}^{i,max}$; an electrolyzer is used to convert electricity to H_2 and the capacity of an electrolyzer at each node is $P_{ele}^{i,max}$; H_2 storage tanks are used to store H_2 and the capacity of H_2 storage tanks at each node is C_{gs}^i ; an ETH device is used to convert electricity to heat and the capacity of an ETH at each node is $P_{ETH}^{i,max}$; a GTH is used to convert gas energy to heat and the capacity of GTH at each node is $P_{GTH}^{i,max}$; a CHP device is used to produce heat and power and the capacity of CHP at each node is $P_{CHP}^{i,max}$. In short, the goal of the proposed method is to decide the sizing or capacity values of the above components.

3.1. Operation problem

For the operation problem, the goal is to minimize the load shedding of gas/electricity/heat demands, and ensure the reliability of the whole system. The objective function can then be written as:

$$C_{op}^{all} = \alpha \cdot \sum_{i=1}^N \sum_{t=1}^T LS_{gas}^{i,t} + \beta \cdot \sum_{i=1}^N \sum_{t=1}^T LS_{el}^{i,t} + \gamma \cdot \sum_{i=1}^N \sum_{t=1}^T LS_{heat}^{i,t} \quad (1)$$

where α, β , and γ are penalty values for load shedding of gas/electricity/heat demands, and $LS_{gas}^{i,t}$, $LS_{el}^{i,t}$ and $LS_{heat}^{i,t}$ are the load shedding of gas/electricity/heat demands at node i and time t .

The power devices constraints are:

$$\begin{aligned} -P_{line}^{gas,m,n,max} &\leq P_{line}^{gas,m,n,t} \leq P_{line}^{gas,m,n,max} \\ -P_{line}^{el,m,n,max} &\leq P_{line}^{el,m,n,t} \leq P_{line}^{el,m,n,max} \\ -P_{line}^{heat,m,n,max} &\leq P_{line}^{heat,m,n,t} \leq P_{line}^{heat,m,n,max} \\ onoff_{fc}^{i,t} \cdot P_{fc}^{i,min} &\leq Z_{fc}^{i,t} \leq onoff_{fc}^{i,t} \cdot P_{fc}^{i,max} \\ onoff_{ele}^{i,t} \cdot P_{ele}^{i,min} &\leq Z_{ele}^{i,t} \leq onoff_{ele}^{i,t} \cdot P_{ele}^{i,max} \\ onoff_{fc}^{i,t} + onoff_{ele}^{i,t} &\leq 1 \\ 0 &\leq Z_{ETH}^{i,t} \leq P_{ETH}^{i,max} \\ 0 &\leq Z_{GTH}^{i,t} \leq P_{GTH}^{i,max} \\ 0 &\leq Z_{CHP}^{i,t} \leq P_{CHP}^{i,max} \\ 0 &\leq Z_{PS}^{gas,i,t} \leq Z_{PS}^{gas,i,max} \\ 0 &\leq Z_{PS}^{el,i,t} \leq Z_{PS}^{el,i,max} \\ 0 &\leq Z_{PS}^{heat,i,t} \leq Z_{PS}^{heat,i,max} \end{aligned} \quad (2)$$

where $P_{line}^{gas,m,n,t}$ is the gas power flow from node m to node n at time t ; $P_{line}^{gas,m,n,max}$ is the maximum gas power flow from m to n ; $onoff_{fc}^{i,t}$ is the ON/OFF state of the fuel cell at node i and time t ; $P_{fc}^{i,min}$ and $P_{fc}^{i,max}$ are the minimum and maximum output of the fuel cell at node i ; $P_{ele}^{i,min}$ and $P_{ele}^{i,max}$ are the minimum and maximum input of the electrolyzer at node i ; $Z_{fc}^{i,t}$, $Z_{ele}^{i,t}$, $Z_{ETH}^{i,t}$, $Z_{GTH}^{i,t}$ and $Z_{CHP}^{i,t}$ are the output power of the fuel cell, electrolyzer,

ETH, GTH, CHP at node i and time t ; $Z_{PS}^{gas,i,t}$, $Z_{PS}^{el,i,t}$, and $Z_{PS}^{heat,i,t}$ are the output power of the gas source, electric generator, and heating source at node i and time t .

The state of H_2 storage tanks can be described as:

$$S_{gs}^{i,t} = S_{gs}^{i,t-1} + (Z_{ele}^{i,t} \cdot eff_{ch} - Z_{fc}^{i,t}) \cdot \Delta t / C_{gs}^i \quad (4)$$

where $S_{gs}^{i,t}$ is the state of the H_2 storage tanks at node i and time t , and Δt is the time interval. eff_{ch} is the efficiency to produce H_2 through the electrolyzer.

The H_2 storage tanks constraint is:

$$S_{gs}^{i,min} \leq S_{gs}^{i,t} \leq S_{gs}^{i,max} \quad (5)$$

where $S_{gs}^{i,min}$, $S_{gs}^{i,max}$ are the minimal and maximal state of the H_2 storage system at node i .

For the CHP, the following characteristics are used [31]. First, the power generation:

$$Z_{CHP} = \alpha^{GE} Q_{CHP} + \beta^{GE}; \quad (6)$$

Available waste heat value of flue gas:

$$q^{GAS} = \alpha^{GAS} Q_{CHP} + \beta^{GAS}; \quad (7)$$

Available waste heat value of cylinder water:

$$q^{WA} = \alpha^{WA} Q_{CHP} + \beta^{WA}; \quad (8)$$

Recovery heat from CHP:

$$q_{CHP} = eff_{re} \cdot \{q^{GAS} + q^{WA}\} \quad (9)$$

α^{GE} and β^{GE} are the coefficient values to generate electricity; α^{GAS} , β^{GAS} are the coefficient values to produce waste heat from flue gas; α^{WA} , β^{WA} are the coefficient values to produce waste heat from cylinder water; eff_{re} is the heat recovery efficiency; q^{GAS} is the available waste heat value of flue gas; q^{WA} is the available waste heat value of cylinder water; q_{CHP} is the recovery heat from CHP.

The gas power balance constraint is:

$$\begin{aligned} Z_{PS}^{gas,i,t} - Z_{GTH}^{i,t} / eff_{GTH} - Q_{CHP}^{i,t} / eff_{CHP} \\ - (L_{gas}^{i,t} - LS_{gas}^{i,t}) = P_{line}^{gas,X \rightarrow i,t} \end{aligned} \quad (10)$$

The electricity power balance constraint is:

$$\begin{aligned} Z_{PS}^{el,i,t} + P_{PV}^{i,t} + Z_{fc}^{i,t} + Z_{CHP}^{i,t} - Z_{ele}^{i,t} - Z_{ETH}^{i,t} \\ - (L_{el}^{i,t} - LS_{el}^{i,t}) = P_{line}^{el,X \rightarrow i,t} \end{aligned} \quad (11)$$

The heat power balance constraint is:

$$\begin{aligned} Z_{PS}^{heat,i,t} + eff_{heat} \cdot Z_{fc}^{i,t} + eff_{ETH} \cdot Z_{ETH}^{i,t} \\ + Z_{GTH}^{i,t} + q_{CHP}^{i,t} - (L_{heat}^{i,t} - LS_{heat}^{i,t}) = P_{line}^{heat,X \rightarrow i,t} \end{aligned} \quad (12)$$

where $P_{line}^{gas,X \rightarrow i,t}$ is the gas power flow from node X to i at time t , with X representing all nodes that connect with node i . eff_{GTH} is the efficiency of GTH to produce heat; eff_{CHP} is the gas utilization efficiency of CHP to consume gas; eff_{heat} is the fuel cell efficiency to produce heat; eff_{ETH} is the efficiency of ETH to produce heat. $L_{gas}^{i,t}$, $L_{el}^{i,t}$, $L_{heat}^{i,t}$ are the gas/electricity/heat load demands at node i and time t .

3.2. Sizing problem

For the sizing problem, the objective is to minimize the total investment cost. So the objective function can be written as:

$$C_{inv}^{all} = \sum_{i=1}^N \{C_{inv}^{PV} \cdot P_{PV}^i + C_{inv}^{fc} \cdot P_{fc}^{i,max} + C_{inv}^{ele} \cdot P_{ele}^{i,max} + C_{inv}^{gs} \cdot C_{gs}^i + C_{inv}^{ETH} \cdot P_{ETH}^{i,max} + C_{inv}^{GTH} \cdot P_{GTH}^{i,max} + C_{inv}^{CHP} \cdot P_{CHP}^{i,max}\} \quad (13)$$

where C_{inv} is the investment cost of each component.

$\mathbf{U}$ is used to represent the set of the sizing problem variables, namely, $\mathbf{U} = \{P_{PV}^i, P_{fc}^{i,max}, P_{ele}^{i,max}, C_{gs}^i, P_{ETH}^{i,max}, P_{GTH}^{i,max}, P_{CHP}^{i,max}\}$, with $i = 1, \dots, N$. $\mathbf{S}$ represents the set of the operation problem variables.

In summary, the sizing problem of the hybrid gas/electricity/heat system can be written as follows:

$$\min_{\mathbf{U}} \left\{ C_{inv}^{all} + \min_{\mathbf{U}^*, \mathbf{S}} \{ C_{op}^{all} \} \right\} \quad (14)$$

s.t. (2), (3), (4), (5), (6), (7), (8), (9), (10), (11), (12)

3.3. Considering the contingency events

In large nodes hybrid networks, contingency events must be considered to maximize reliability. In this section, the influence of contingency events on the sizing results is developed. A large number of contingency events can be listed, and it is impossible to consider all cases. So a robust method can be used to find the worst case. The sizing problem can then be described as follows:

$$\min_{\mathbf{U}} \left\{ C_{inv}^{all} + \max_{\mathbf{V}} \min_{\mathbf{U}^*, \mathbf{S}} \{ C_{op}^{all} \} \right\} \quad (15)$$

s.t. (2), (3), (4), (5), (6), (7), (8), (9), (10), (11), (12)

where $\mathbf{V}$ represents the set of contingency events. In other words, the goal is to search for the best sizing values $\mathbf{U}^*$ from $\mathbf{U}$, which can enable the whole system to operate with minimal costs, and at the same time, ensure that it resists to the worst contingency event.

For this two stage optimization problem, the column-and-constraint generation method [32] is used. In [33], authors use this method to solve a robust MG planning problem. In [34], authors also use this method to solve a distribution network planning problem to minimize the system damage against natural disasters.

In this paper, the worst case is obtained based on graph theory. For a large nodes hybrid network system, the relative importance of each node is ranked. The case where the most important node is destroyed under the contingency event is the worst case. The relative importance of each node in the graph is described using betweenness centrality [35]:

$$C_B(i) = \sum_{n_l \neq n_k \neq n_i} \frac{n_k \rightarrow n_l, n_i}{n_k \rightarrow n_l} \quad (16)$$

where $n_k \rightarrow n_l, n_i$ is 1 if the shortest path between nodes n_k to n_l goes through n_i , and 0 if n_k to n_l does not pass through n_i .

Under the worst case, the new structure of the whole system can be obtained. Then the sizing problem (14) is solved based on this new structure, and new sizing values can be obtained.

4. Simulation results for Case I

In this section, the method is tested on the modified 13-node case. Three sub-cases are compared. For the operation problem, the time step is 1 hour, and the time horizon is one day (24 hours).

4.1. System setup

The penalty values are arbitrarily chosen as $\alpha = \beta = \gamma = 10^{10}$ to make sure that the penalty cost of load shedding is larger than that of the total investment cost. Investment costs are shown in Tab. 1. The cost parameters are adopted from [1, 30]. The model is implemented in MATLAB and solved with YALMIP [36] and Gurobi. Simulations were run on a computer with an Intel Xeon CPU E3-1220@3.1GHz.

Table 1: Investment costs [1, 30]

Device	Cost
PV	2 M€/MW
Fuel cell	4 M€/MW
Electrolyzer	3.2 M€/MW
H ₂ tank	1200 €/MWh
ETH	0.06 M€/MW
GTH	0.15 M€/MW
CHP	1.6 M€/MW

Load demands (peak load) at each node are shown in Tab. 2. Sources ratings data is shown in Tab. 3. The capacity of lines is shown in Tab. 4, where the unit is MW. The efficiency parameters are shown in Tab. 5. Here the capacity of pipelines in the heat network are assumed to be the same as power lines. In order to reduce the computation time, four typical days (spring, summer, autumn, winter) are used as the load block. In each hour of the typical day, the operation problem (minimizing load shedding) is checked based on the sizing problem. If the constraints of the operation problem are violated, then new sizing values are generated. The simulation flow chart can be seen in Fig. 4.

Table 2: Load demand (peak load) [1]

Bus	L_{el} [MW]	L_{heat} [MW]	L_{gas} [MW]
1	4.8334	3.8323	1.8251
2	7.0342	6.0123	1.0789
6	5.1668	4.1532	1.1652
7	5.8746	4.8056	1.8487
10	7	6.5642	1.0023
12	5.1668	4.1756	1.1695
13	4.9254	3.9652	1.9362

In the following, three cases are compared:

Table 3: Sources ratings data [1]

Bus	$Z_{PS}^{el,max}$ [MW]	$Z_{PS}^{heat,max}$ [MW]	$Z_{PS}^{gas,max}$ [MW]
1	5	4	6
8	0	0	90
12	8	7	8

Table 4: Line data [1]

Line	P_{line}^{el}	P_{line}^{gas}	Line	P_{line}^{el}	P_{line}^{gas}
1	4.9	11	7	23.6	50
2	7.2	15	8	17.4	37
3	12.2	26	9	7.2	15
4	11.6	24	10	10.8	22
5	5.4	11	11	5.4	11
6	6.2	13	12	5.4	11

Table 5: Efficiency values

Efficiency	Value	Efficiency	Value
eff_{ch}	0.5	eff_{GTH}	0.9
eff_{heat}	0.19	eff_{CHP}	0.9
eff_{ETH}	0.9	eff_{re}	0.8

Figure 4: Simulation flow chart.

- Case 1: all nodes include PV panels;
- Case 2: different candidate buses are chosen to install PV panels;
- Case 3: the investment cost of hydrogen storage system is reduced by 50%.

Case 1 and case 2 are used to evaluate the influence of PV location on the sizing results. Buses 3/4/5/8/9/11 are chosen to install PV panels, because these buses are not load demand central, which have place to install the PV panels. Case 1 and case 3 are used to evaluate the influence of hydrogen storage investment costs on the results.

4.2. Genetic algorithm based sizing results

A genetic algorithm [30] is used to search for the sizing results. GA is based on the natural selection process similar to biological evolution, which includes three steps, mutation, crossover and selection. With these steps, a new population is generated. In the simulation, the population size is 20, and the maximum number of iterations is 100. In the example, there are 13 nodes, and at each node there are 7 components, so the number of variables is 91. Each population gives the 91 values of each component, then the operation optimization problem is run. Based on the operation results (load shedding) and investment costs, the population is updated.

Tab. 6 shows the results of case 1. Tab. 7 shows the results of case 2. Tab. 8 shows the results of case 3. The unit of each component (PV panels, fuel cell, electrolyzer, ETH, GTH, CHP) in each table is *MW*, and the unit of H_2 tanks is *MWh*.

Table 6: Case 1 results

Node	P_{PV}	P_{fc}^{max}	P_{ele}^{max}	P_{ETH}^{max}	P_{GTH}^{max}	P_{CHP}^{max}	C_{gs}
1	7.10	2.41	0.21	0.29	0.72	3.33	84.77
2	2.53	0.60	0.73	3.53	1.52	0.72	57.99
3	4.77	0.02	0.95	1.64	3.49	0.39	4.91
4	3.13	2.60	4.26	0.38	0.32	0.60	63.94
5	3.53	0.01	2.95	2.55	2.72	1.01	89.28
6	8.16	4.45	1.40	0.08	3.14	0.48	89.50
7	5.91	1.92	2.67	0.04	3.65	4.59	13.97
8	2.29	0.20	0.89	2.50	0.03	0.23	19.34
9	3.90	1.47	3.66	2.80	0.16	1.08	76.84
10	6.03	3.11	1.08	2.76	1.71	3.08	15.64
11	4.79	0.81	3.09	1.72	0.98	3.97	78.53
12	6.01	3.96	1.13	4.70	2.16	2.94	30.58
13	2.65	2.20	1.78	2.24	3.41	0.07	50.46
Total	60.78	23.76	24.80	25.23	24.00	22.50	675.76

Table 7: Case 2 results

Node	P_{PV}	P_{fc}^{max}	P_{ele}^{max}	P_{ETH}^{max}	P_{GTH}^{max}	P_{CHP}^{max}	C_{gs}
1	0.00	0.31	1.16	2.73	1.44	3.89	77.93
2	0.00	1.65	0.27	1.38	4.35	3.42	18.82
3	3.24	2.18	0.74	0.41	1.89	1.48	3.69
4	6.96	0.09	0.01	3.60	4.98	0.38	18.97
5	9.41	0.36	3.78	3.71	3.97	2.68	19.75
6	0.00	2.79	4.00	1.12	2.97	1.01	82.38
7	0.00	3.15	0.76	3.43	2.53	0.32	62.97
8	2.57	1.01	3.07	2.40	1.74	0.22	90.56
9	7.74	2.51	0.93	0.71	4.35	2.10	52.50
10	0.00	2.77	0.69	1.64	0.66	4.28	81.83
11	3.03	0.19	4.17	3.26	2.66	2.58	81.33
12	0.00	1.03	0.12	2.67	4.56	0.09	56.10
13	0.00	3.95	4.46	2.09	0.37	0.99	47.04
Total	32.95	22.00	24.15	29.15	36.46	23.43	693.85

Fig. 5 shows a comparison of these three cases. In case 2, PV is limited to be installed at some nodes which are not the load demand central, so the PV output power must be transferred to load demand central based on the power transmission lines, but the capacity of power transmission lines will limit the

Node	P_{PV}	P_{fc}^{max}	P_{ele}^{max}	P_{ETH}^{max}	P_{GTH}^{max}	P_{CHP}^{max}	C_{gs}
1	3.19	0.56	0.83	3.16	1.08	1.06	13.99
2	8.45	1.58	3.16	2.46	0.05	1.37	59.46
3	8.25	2.95	3.24	4.62	0.84	3.79	83.83
4	3.19	1.13	1.34	4.96	1.21	4.46	64.00
5	6.26	1.65	3.51	0.14	3.96	1.22	7.27
6	4.19	1.42	0.64	3.87	2.44	3.31	81.91
7	6.13	1.69	0.20	1.58	3.48	0.34	64.67
8	2.22	2.45	1.35	4.29	2.26	3.15	2.34
9	5.40	0.81	4.09	0.85	0.28	1.11	79.54
10	4.20	2.58	1.49	2.63	0.25	0.33	77.67
11	4.94	0.67	4.09	3.78	3.96	4.59	95.33
12	6.79	1.55	3.06	2.67	1.00	1.34	59.40
13	6.06	3.70	0.97	0.22	0.40	1.27	1.78
Total	69.27	22.75	27.96	35.23	21.20	27.32	691.20

Figure 5: Comparison of the three cases.

transferred power. The installed PV power is smaller than that in case 1 (decreased by 50%). This leads to a smaller capacity for the electrolyzer, which is used to store surplus PV output, and decreases by 3%. The smaller capacity of PV leads to a larger capacity for the H₂ tanks (increases by 2%) and the CHP (increases by 4%). The smaller capacity for the electrolyzer leads to a larger capacity for the ETH (increases by 15%) because both devices are used to consume the electricity, and the surplus energy can either be stored in tanks through the electrolyzer or through the ETH to supply the heating demand.

Comparing case 1 and case 3, it can be seen that in case 3, the capacity of PV is larger than that in case 1 (increases by 14%). This is because the hydrogen storage system is competitive and can be used frequently. This is due to the reduction in the investment cost of the fuel cell and the electrolyzer, which makes the hydrogen storage more competitive. Then more PV panels can be installed, which leads to a larger capacity for the electrolyzer (increases by 13%). More power can in turn be produced by PV, which leads to a larger capacity for the ETH (increases by 40%). A larger capacity for the ETH also leads to a smaller GTH (decreases by 13%).

Comparing these three cases, it can be seen that the sizing results of PV, ETH, GTH, and CHP change, obviously. This is because their costs are more competitive than that of the fuel

cell and the electrolyzer, which has a larger ability to minimize the objective function.

Based on the above simulation results, it can be seen that PV panels' location and the investment cost of hydrogen storage system are important parameters to influence the sizing values of each component.

Figure 6: Electric power scheduling at node 7 (line L6).

Figure 7: Heating power scheduling at node 7 (line L6).

Figs. 6, 7, 8, 9 show one day scheduling results of the three energy systems in a typical spring day. In Fig. 6, at node 7, electric energy is exchanged with the other nodes through power line L6. During the night, the fuel cell and CHP produce electricity to supply the loads. During the day, PV and imported energy are used to supply the loads. The electrolyzer is used to store the surplus energy. In Fig. 7, the CHP and GTH produce the main heat energy, and the fuel cell and ETH produce the remaining heat. Imported/exported heating energy through pipeline 6 is also important to keep the energy balance at node 7. Fig. 8 shows that gas imports through gas pipeline 6 are the main method to supply gas loads at node 7. Fig. 9 shows the

Figure 8: Gas scheduling at node 7 (line L6).

Figure 9: SOC at 13 nodes.

graph is described using the betweenness centrality value [35] of the node.

Figure 10: Graph structure of the 13-node hybrid network.

Figure 11: Betweenness centrality of the 13-node hybrid network.

state of hydrogen tanks at all nodes. It can be seen that the storage system can be used to keep the power balance in the whole system: through the fuel cell, hydrogen tanks can produce electricity and heat to supply the load demand, and through the electrolyzer, the surplus electricity can be stored in hydrogen tanks using H_2 .

From the scheduling results, the output of some power devices change fast, especially the lines. For example, in Fig. 7, at 2am, the heat pipeline exports heating energy, but at 3am, it switches to imports. The reason for this phenomenon is that the ramp up and ramp down constraints of all components are not limited.

4.3. Influence of contingencies on the sizing results

Based on section 3.3, the worst case can be obtained using graph theory. For this 13-node hybrid network system, the relative importance of each node is ranked. The case where the most important node is destroyed under the contingency event is the worst case. The relative importance of each node in the

Fig. 10 shows the graph connection of the 13-node hybrid network. Fig. 11 shows the betweenness centrality of the 13-node hybrid network. It can be seen that the most important node of the whole system is node 4. The worst case for this network is thus when the connections between node 4 and the other nodes are removed.

As the failure probability of gas pipelines and heat pipelines are much smaller than that of overhead electric power lines [5], for the worst case, only the removal of electric power lines is considered. Then, the sizing problem needs to consider eight cases: the normal condition with four typical days of each season, and the worst case condition with four typical days. Tab. 9 shows the sizing results of the whole system when the electric connections between node 4 and the other nodes are removed, namely, by removing electric lines $en3 \leftrightarrow en4$, $en5 \leftrightarrow en4$, $en8 \leftrightarrow en4$. This case is defined as case 4.

Fig. 12 shows a comparison of results for case 1 and case 4. It can be seen that: 1) at node 4, because the electric loads cannot import/export energy from/to the other nodes, so the capacity of PV and fuel cell is larger than that in case 1 (they increase by 12% and 11% respectively); 2) on the

Table 9: Case 4 results

Node	P_{PV}	P_{fc}^{max}	P_{ele}^{max}	P_{ETH}^{max}	P_{GTH}^{max}	P_{CHP}^{max}	C_{gs}
1	5.55	0.01	2.83	2.55	0.33	3.56	49.85
2	5.58	2.02	3.42	0.74	1.62	0.21	32.59
3	3.98	0.91	2.01	4.44	1.88	0.36	31.51
4	7.30	2.72	4.83	4.67	0.20	0.22	12.83
5	6.05	3.71	0.37	1.88	1.22	1.25	87.38
6	7.25	1.67	2.00	0.77	1.77	2.37	56.29
7	4.09	4.04	3.76	3.95	3.19	1.29	61.96
8	3.92	1.76	1.37	3.09	3.02	2.91	25.46
9	6.03	3.45	3.49	4.73	1.69	1.60	19.71
10	4.86	0.52	0.25	3.81	0.62	1.59	64.03
11	2.09	0.87	3.21	4.10	4.95	3.81	27.16
12	3.45	4.12	2.96	4.20	1.91	0.93	68.01
13	7.69	0.27	2.68	2.43	3.81	1.68	3.89
Total	67.85	26.07	33.19	41.37	26.20	21.78	540.66

Figure 12: Comparison of case 1 and case 4.

other hand, this worst case divides the electric supply network into four parts: $\{en1, en2, en3\}$, $\{en4\}$, $\{en5, en6, en7\}$, and $\{en8, en9, en10, en11, en12, en13\}$. Each part cannot receive electric power from the other parts through electric power lines, which means that the important task of keeping electric power balance is taken on by the fuel cell, the CHP device (the main controllable power sources) and PV panels. Larger PV panels lead to a larger capacity of electrolyzer (increases by 34%) and ETH (increases by 64%) to consume the surplus energy.

The above simulation shows that the structure of the whole system also influences the sizing results of each component. This is because the interconnection structure of the system can influence the energy flow in the whole system, which will then influence the utilization of the power devices, and at last, the sizing results will be different.

4.4. Discussion

Case 1 to case 3 show that the PV panels location and investment cost of hydrogen storage system influence the sizing value of each component. When the installed capacity of PV panels is reduced by 50%, the capacity of the electrolyzer decreases by 3%, capacity for the H_2 tanks increases by 2%, the CHP increases by 4%, and ETH increases by 15%. When the investment costs of the fuel cell and the electrolyzer decrease

by 50%, the capacity of PV increases by 14%, the electrolyzer increases by 13%, ETH increases by 40%, and GTH decreases by 13%.

To resist to contingency events, betweenness centrality is used to find the most important node (worst case). The simulation results (case 4) show that the controllable power sources (fuel cell, CHP), PV panels and the H_2 tanks are the main components to ensure the system power balance. The capacity of PV and fuel cell increase by 12% and 11%, and the electrolyzer increases by 34% while the ETH increases by 64%. After the hybrid network is damaged by contingency events, the whole system is divided into small parts, namely, smaller 'islanded' microgrids. In each part, the main controllable power sources are the fuel cell and CHP. So the size of the PV panels and H_2 tanks is important to enable the whole system to operate normally.

5. Simulation results for Case II

In this section, a benchmark hybrid gas/electricity/heat system is presented. The electricity network is the IEEE 30-node network [37] shown in Fig. 13. At nodes e1 and e2, two gas generators are connected. MG1, MG2, MG3 and MG4 are connected at nodes e23, e17, e14 and e7, respectively. The gas network is a 20-node system, whose parameters can be found in [38, 39], as shown in Fig. 14. The gas generators are connected at nodes g12 and g19. The heating source is supplied by gas at nodes g11, g12 and g14. MG1, MG2, MG3 and MG4 are connected at nodes g7, g6, g15 and g10, respectively. The heating network is a 14-node system [37], shown in Fig. 15. Nodes h1 and h6 and h11 are heating sources. MG1, MG2, MG3 and MG4 are connected at nodes h9, h10, h4 and h13, respectively. The configuration of this hybrid system is summarized in Tab. 10.

Two cases are simulated:

1. Case 5: normal operation state, namely, no connection node is removed;
2. Case 6: operation under contingency events, namely, the most important node is removed.

Table 10: Configuration of the studied system

Unit	Electrical bus	Gas node	Heat node
Generator 1	e1	g12	-
Generator 2	e2	g19	-
Heating 1	-	g14	h1
Heating 6	-	g12	h6
Heating 11	-	g11	h11
MG1	e23	g7	h9
MG2	e17	g6	h10
MG3	e14	g15	h4
MG4	e7	g10	h13

The sizing results for these four MG are shown in Tab. 11. Figs. 16, 17, 18, and 19 show one day scheduling results of

Figure 13: IEEE 30-node network.

Figure 14: Gas 20-node network.

Figure 15: Heating 14-node network.

Node	P_{PV}	P_{fc}^{max}	P_{ele}^{max}	P_{ETH}^{max}	P_{GTH}^{max}	P_{CHP}^{max}	C_{gs}
MG1	3.25	0.97	1.90	1.21	3.78	0.88	3.02
MG2	3.75	0.20	3.22	4.40	1.07	1.32	0.68
MG3	4.29	2.40	0.07	1.73	0.16	0.73	2.87
MG4	3.60	0.46	1.57	4.89	0.21	0.90	4.02
Total	14.89	4.03	6.75	12.24	5.21	3.82	10.59

Figure 16: Electric power scheduling in MG 3.

Figure 17: Heating power scheduling in MG 3.

the worst case based on graph theory, as for case I. Fig. 22 shows the graph structure of the hybrid system. Fig. 23 then shows the betweenness centrality, which shows that the most important node is e6 (electrical network node 6). The worst case of this hybrid network is then defined, which is when the connections between node 6 and the other nodes are removed. Here, for the operation problem, 8 cases are considered: the normal condition with four typical days of each season, and the worst case condition with four typical days.

Figure 18: Gas scheduling in MG 3.

Figure 21: Heating flow in heat system.

Figure 19: SOC in four MGs.

Figure 22: Graph structure of the hybrid system.

Figure 20: Gas flow in gas system.

Figure 23: Betweenness centrality of the hybrid system.

682 Tab. 12 shows the sizing results when the connections between
683 node 6 and other nodes is removed, namely, remove
684 $e6 \leftrightarrow e2$, $e6 \leftrightarrow e4$, $e6 \leftrightarrow e7$, $e6 \leftrightarrow e8$, $e6 \leftrightarrow e9$, $e6 \leftrightarrow e10$,
685 and $e6 \leftrightarrow e28$. Fig. 24 shows the comparison of case 5 and
686 case 6. It can be seen that after considering the damage on the

Figure 24: Comparison of case 5 and case 6.

electrical network, more PV panels (increased by 8%), fuel cell (increases by 11%) and CHP are needed to supply the electricity demands in MG. The total sizing value of the GTH is decreased, but the sizing value of the ETH is increased by 18%, because the ETH is used to fill up the position of the GTH to supplement the remaining heating demands. The total volume of hydrogen tanks is also increased by 14% to supply the electrical demands through fuel cells.

Table 12: Case II under disasters results

Node	P_{PV}	P_{fc}^{max}	P_{ele}^{max}	P_{ETH}^{max}	P_{GTH}^{max}	P_{CHP}^{max}	C_{gs}
MG1	4.40	2.23	0.03	4.12	0.66	3.54	2.85
MG2	3.62	1.03	3.89	2.98	1.22	0.94	3.75
MG3	4.00	0.36	4.05	3.93	0.37	0.75	3.87
MG4	4.01	0.85	2.62	3.45	0.57	2.38	1.58
Total	16.02	4.48	10.60	14.47	2.82	7.60	12.06

6. Conclusion

In this paper, a co-optimization method is presented to size distributed generation in a hybrid gas/electricity/heat network. Mixed integer linear programming is used to control the operation of the whole system, which aims to minimize load shedding. GA is used to search for the sizing values of each component. Case 1 and case 2 show that the PV panels location influence the sizing results of each component. This is because the PV panels operating as uncontrollable power sources are playing an important role to ensure the power balance of the whole system. The controllable power devices are all operating encompassly the PV panels. At last, with different capacities of PV panels, the sizing results of each component are also different. When the installed capacity of PV panels is reduced by 50%, the capacity of the electrolyzer decreases by 3%, the capacity for the H₂ tanks increases by 2% and the CHP increases by 4% while the ETH increases by 15%.

Case 1 and case 3 show that the investment cost of the hydrogen storage system also influences the sizing results. This is because the investment costs impact the competitiveness of each component to minimize the objective function. When the investment cost of the fuel cell and the electrolyzer decrease by

50%, the capacity of PV increases by 14%, the electrolyzer increases by 13%, ETH increases by 40%, and the GTH decreases by 13%.

A new method based on betweenness centrality is then proposed to find the worst case under contingency events. Case 4 shows that the controllable power sources (fuel cell, CHP), PV panels and H₂ tanks are the main factors that influence whether the whole system can operate normally or not. After considering the worst case contingency event, for case 4, the capacity of PV and fuel cell increase by 12% and 11%, and the electrolyzer increases by 34%, while the ETH increases by 64%.

At last, an IEEE30 + Gas20 + Heat14-node network is tested (case 5 and case 6). Case 6 shows that the structure of the power system influences the energy exchanges between the grid and MG, and influence the sizing values in each MG. The results indicate that more power is imported from the gas network when power supply network exports are limited. After considering the worst case contingency event, for case II, the capacity of PV and fuel cell increase by 8% and 11%, and the electrolyzer increases by 57% while the ETH increases by 18%.

This co-optimization method can be used as a guidance for utility companies to build large nodes hybrid gas/electricity/heat supply networks.

7. References

- [1] J. Mitra, M. R. Vallem, C. Singh, Optimal deployment of distributed generation using a reliability criterion, *IEEE Transactions on Industry Applications* 52 (3) (2016) 1989–1997.
- [2] L. B. Jaramillo, A. Weidlich, Optimal microgrid scheduling with peak load reduction involving an electrolyzer and flexible loads, *Applied Energy* 169 (Supplement C) (2016) 857 – 865. doi:https://doi.org/10.1016/j.apenergy.2016.02.096.
- [3] B. Li, R. Roche, D. Paire, A. Miraoui, Sizing of a stand-alone microgrid considering electric power, cooling/heating, hydrogen loads and hydrogen storage degradation, *Applied Energy* 205 (2017) 1244 – 1259. doi:https://doi.org/10.1016/j.apenergy.2017.08.142.
- [4] A. Sheikhi, S. Bahrani, A. M. Ranjbar, An autonomous demand response program for electricity and natural gas networks in smart energy hubs, *Energy* 89 (2015) 490–499.
- [5] B. Li, R. Roche, A. Miraoui, System resilience improvement using multiple energy supply systems under natural disasters, in: *Industrial Electronics Society, IECON 2016-42nd Annual Conference of the IEEE, IEEE, 2016*, pp. 3912–3917.
- [6] I. G. Moghaddam, M. Saniei, E. Mashhour, A comprehensive model for self-scheduling an energy hub to supply cooling, heating and electrical demands of a building, *Energy* 94 (2016) 157–170.
- [7] G. M. Kopanos, M. C. Georgiadis, E. N. Pistikopoulos, Energy production planning of a network of micro combined heat and power generators, *Applied energy* 102 (2013) 1522–1534.
- [8] E. Shirazi, S. Jadid, Cost reduction and peak shaving through domestic load shifting and ders, *Energy* 124 (2017) 146–159.
- [9] J. Silvente, A. M. Aguirre, M. A. Zamarripa, C. A. Méndez, M. Graells, A. Espuña, Improved time representation model for the simultaneous energy supply and demand management in microgrids, *Energy* 87 (2015) 615–627.
- [10] J. Silvente, L. G. Papageorgiou, An milp formulation for the optimal management of microgrids with task interruptions, *Applied Energy* 206 (2017) 1131–1146.
- [11] D. Zhang, S. Evangelisti, P. Lettieri, L. G. Papageorgiou, Economic and environmental scheduling of smart homes with microgrid: Der operation and electrical tasks, *Energy Conversion and Management* 110 (2016) 113–124.
- [12] gurobi, gurobi (2017). URL <http://www.gurobi.com/resources/getting-started/mip-basics>

- [13] P. Prakash, D. K. Khatod, Optimal sizing and siting techniques for distributed generation in distribution systems: A review, *Renewable and Sustainable Energy Reviews* 57 (2016) 111–130.
- [14] A. R. Jordehi, Allocation of distributed generation units in electric power systems: A review, *Renewable and Sustainable Energy Reviews* 56 (2016) 893–905.
- [15] J. H. Roh, M. Shahidehpour, Y. Fu, Market-based coordination of transmission and generation capacity planning, *IEEE Transactions on Power Systems* 22 (4) (2007) 1406–1419.
- [16] A. Khodaei, M. Shahidehpour, Microgrid-based co-optimization of generation and transmission planning in power systems, *IEEE transactions on power systems* 28 (2) (2013) 1582–1590.
- [17] A. Khodaei, S. Bahramirad, M. Shahidehpour, Microgrid planning under uncertainty, *IEEE Transactions on Power Systems* 30 (5) (2015) 2417–2425.
- [18] A. Khayatian, M. Barati, G. J. Lim, Market-based and resilient coordinated microgrid planning under uncertainty, in: *Transmission and Distribution Conference and Exposition (T&D)*, 2016 IEEE/PES, IEEE, 2016, pp. 1–5.
- [19] R. Hemmati, H. Saboori, P. Siano, Coordinated short-term scheduling and long-term expansion planning in microgrids incorporating renewable energy resources and energy storage systems, *Energy*.
- [20] Y. Yang, S. Zhang, Y. Xiao, Optimal design of distributed energy resource systems coupled with energy distribution networks, *Energy* 85 (2015) 433–448.
- [21] O. Shaneb, G. Coates, P. Taylor, Sizing of residential μ chp systems, *Energy and Buildings* 43 (8) (2011) 1991–2001.
- [22] Q. Zhu, X. Luo, B. Zhang, Y. Chen, Mathematical modelling and optimization of a large-scale combined cooling, heat, and power system that incorporates unit changeover and time-of-use electricity price, *Energy Conversion and Management*.
- [23] L. Guo, W. Liu, J. Cai, B. Hong, C. Wang, A two-stage optimal planning and design method for combined cooling, heat and power microgrid system, *Energy Conversion and Management* 74 (2013) 433–445.
- [24] A. Zidan, H. A. Gabbar, A. Eldessouky, Optimal planning of combined heat and power systems within microgrids, *Energy* 93 (2015) 235–244.
- [25] C. Shao, M. Shahidehpour, X. Wang, X. Wang, B. Wang, Integrated planning of electricity and natural gas transportation systems for enhancing the power grid resilience, *IEEE Transactions on Power Systems*.
- [26] X. Zhang, M. Shahidehpour, A. S. Alabdulwahab, A. Abusorrah, Security-constrained co-optimization planning of electricity and natural gas transportation infrastructures, *IEEE Transactions on Power Systems* 30 (6) (2015) 2984–2993.
- [27] J. Qiu, Z. Y. Dong, J. H. Zhao, K. Meng, Y. Zheng, D. J. Hill, Low carbon oriented expansion planning of integrated gas and power systems, *IEEE Transactions on Power Systems* 30 (2) (2015) 1035–1046.
- [28] C. Unsuhay-Vila, J. Marangon-Lima, A. Z. de Souza, I. J. Perez-Arriaga, P. P. Balestrassi, A model to long-term, multiarea, multistage, and integrated expansion planning of electricity and natural gas systems, *IEEE Transactions on Power Systems* 25 (2) (2010) 1154–1168.
- [29] S. Mashayekh, M. Stadler, G. Cardoso, M. Heleno, A mixed integer linear programming approach for optimal der portfolio, sizing, and placement in multi-energy microgrids, *Applied Energy* 187 (2017) 154–168.
- [30] B. Li, R. Roche, A. Miraoui, Microgrid sizing with combined evolutionary algorithm and milp unit commitment, *Applied Energy* 188 (2017) 547–562.
- [31] S. Xinwei, H. Yingduo, Z. Shouzheng, J. Zheng, L. Qingsheng, N. Jing, Comprehensive power-supply planning for active distribution system considering cooling, heating and power load balance, *Journal of Modern Power Systems and Clean Energy* 3 (4) (2015) 485–493.
- [32] B. Zeng, L. Zhao, Solving two-stage robust optimization problems using a column-and-constraint generation method, *Operations Research Letters* 41 (5) (2013) 457–461.
- [33] Z. Wang, B. Chen, J. Wang, J. Kim, M. M. Begovic, Robust optimization based optimal dg placement in microgrids, *IEEE Transactions on Smart Grid* 5 (5) (2014) 2173–2182.
- [34] W. Yuan, J. Wang, F. Qiu, C. Chen, C. Kang, B. Zeng, Robust optimization-based resilient distribution network planning against natural disasters, *IEEE Transactions on Smart Grid* 7 (6) (2016) 2817–2826.
- [35] S. Chanda, A. K. Srivastava, Defining and enabling resiliency of electric distribution systems with multiple microgrids, *IEEE Transactions on Smart Grid* 7 (6) (2016) 2859–2868.
- [36] J. Löfberg, Automatic robust convex programming, *Optimization methods and software* 27 (1) (2012) 115–129.
- [37] A. Shabanpour-Haghighi, A. R. Seifi, Simultaneous integrated optimal energy flow of electricity, gas, and heat, *Energy Conversion and Management* 101 (2015) 579–591.
- [38] D. De Wolf, Y. Smeers, The gas transmission problem solved by an extension of the simplex algorithm, *Management Science* 46 (11) (2000) 1454–1465.
- [39] A. Martinez-Mares, C. R. Fuerte-Esquivel, A unified gas and power flow analysis in natural gas and electricity coupled networks, *IEEE Transactions on Power Systems* 27 (4) (2012) 2156–2166.