Energy droughts from variable renewable energy sources in European climates

Raynaud D.^{1,2}, Hingray B.^{1,3}, François B.⁴, Creutin J.D.^{1,3}

1 : Univ. Grenoble Alpes, IGE UMR 5001, Grenoble, F-38000, France

2: Grenoble-INP, IGE UMR 5001, Grenoble, F-38000, France

3: CNRS, IGE UMR 5001, Grenoble, F-38000, France

4: Department of Civil and Environmental Engineering, University of Massachusetts, Amherst, Massachusetts, USA

Corresponding author: HINGRAY Benoît, benoit.hingray@univ-grenoble-alpes.fr, IGE Domaine Universitaire 70 rue de la physique 38 400 Saint Martin d'Hères FRANCE

Manuscript accepted for publication in Renewable Energy

Citation : Raynaud, D., Hingray, B., François, B., Creutin, J.D. 2018. Energy droughts from variable renewable sources in European climates. Renewable Energy. 125: 578-589,

<https://doi.org/10.1016/j.renene.2018.02.130>

Abstract

The increasing share of variable renewable energy sources in the power supply system raises questions about the reliability and the steadiness of the production. In this study, we assess the main statistical characteristics of “energy droughts” for wind, solar and run-of-the-river hydro power in Europe. We propose two concepts of energy droughts, considering either: Energy Production Droughts (EPD) as sequences of days with low power production or Energy Supply Droughts (ESD) as sequences of days with a high production/demand mismatch.

Using a set of adhoc weather-to-energy conversion models, we characterize energy droughts in 12 European regions from 30-yr series of daily wind, solar, hydro power and energy demand. The characteristics of EPD are very different between sources with short but frequent wind power droughts and rare but long hydro power ones. Solar power droughts are very region-dependent with much longer droughts in Northern Europe. ESD are next characterized in a 100% renewable energy scenario. The features of EPD and ESD differ significantly, highlighting the interplay with the energy demand. Moreover, both duration and frequency of energy droughts decrease when mixing energy sources or when some storage capacity balances the temporal production / demand mismatch.

Keyword: Energy droughts; Variable renewable energy; Energy demand; Hydro-climatic variability; Europe; Wind, Solar; Hydropower

1. Introduction

During the 21st Conference of Parties (COP21), the 2015 United Nations Climate Change Conference in Paris, , 175 countries agreed on limiting the temperature increase due to global warming to 2°C above preindustrial levels. Such an ambitious goal necessitates a deep transformation of our societies and first and foremost a reduction of the anthropogenic greenhouse gas emissions. Many countries have already started their energy transition. In Europe, increasing the share of renewables in the electricity production mix is one of the main targets for the next decade. The European Climate Foundation even set a 100% renewable mix objective to be met by 2050 [1]. In Europe, just like in most regions worldwide, this goal is at least physically realistic, since the resource in renewable energy balances the energy demand several times [2].

Variable renewable energies (VRE) and especially those driven by weather, namely wind, solar and hydro-power from river flow, are expected to play a key role in increasing the share of renewables. Indeed, the installed capacity of VRE is quickly growing worldwide [3]. Exploitable roughly everywhere, wind and solar resources are, for instance, already important contributors of the energy mix in Europe. For some countries, they largely contributed to the early achievement of the 27 % share of renewables targeted for 2030 by the European Council [4]. Hydropower from river flow, classically obtained from run-of-the river power plants (further referred to as RoR power plants), is often given less consideration, especially when compared to the key role of hydropower from large water reservoirs [5]. Even if individual RoR plants have fairly no balancing capacity and only small to very small power capacity (e.g. often smaller than a few MW), the overall RoR production is far from negligible in some regions [6][7]. It is also expected to increase significantly in the next years worldwide with the construction of new plants, the upgrade of old ones and the deployment of new technologies such as river hydrokinetic turbines [8][9].

Wind power, solar power and hydro-power from river flow are by definition very sensitive to weather conditions, and thus present high space/time variability [10]. Moreover, wind and solar power are highly intermittent. Consequently, the integration of VRE in the power system is often difficult. They also make power systems rather vulnerable to the hydro-climatic variability and hydro-meteorological extreme events. These issues become even more critical for high shares of VRE [11][12].

In the last decade, many studies have focused on the intermittency of VRE production at small time scales [13][14][15]. These fluctuations result from the strong variability of weather variables and, to a lower extend, from the cut-in and cut-off thresholds of power generators that only function for a specific range of meteorological conditions (e.g. wind-speed based cut-in and cut-off thresholds for wind turbines). Covering timescales ranging from seconds to several hours, these high-frequency variations in power production lead to a number of critical operational issues (e.g. maintaining the system's stability in order to avoid the system collapse). This especially calls for the support of sufficient mechanical inertia in the system, fast responding back-up power and flexible storage facilities as well as demand-side management [16].

Low VRE production conditions can be also problematic. They result from weather or hydrometeorological configurations with low VRE resources or from situations for which a production curtailment is necessary to avoid damage on power production units (e.g. when wind speed exceeds the cut-off threshold of wind turbines). They can induce critical situations in term of reliability of the power supply potentially and require the use of large back-up sources or

energy storage facilities [17][18]. Low VRE production conditions have been the centre of attention of numerous studies. They either aim to assess the risks related to low production sequences, in terms of probability of occurrence or duration for both current and future climate conditions, or to improve their predictability, with the objective of supporting the operational management of transmission system operators and guarantee system reliability.

Low river flows affect the hydropower production and a number of other water-related systems. Consequently, a large number of studies focused on the characterization of these conditions in terms of occurrence, durations and severity from local to continental scales (e.g. [19] for the European domain). A lot of effort is also made to improve their predictability from daily to seasonal scale [20][21]. The persistence of wind calms and/or the characteristics of low-wind speed periods (for various thresholds) have been similarly analysed for a number of sites worldwide [22][23][24]. Recent studies also consider the occurrence of simultaneous low wind conditions across large areas in the context of modern transmission grids [25][26][27]. Similarly, low solar power periods due to overcast conditions, persistent low level clouds or dust outbreaks have been recently analysed [28][29][30].

The impact of low VRE production periods is also likely to be increased if they co-occur with high energy demand [31][32][33], a situation which can result from the fluctuation of some large scale climate phenomenon such as the North Atlantic Oscillation [34].

In this study, we propose to complement and enlarge these analyses by characterizing and comparing the periods of low VRE production in Europe for the three main renewable power sources, namely wind, solar and hydro power from river flows. We consider the three sources separately and also combined in an energy mix. For the three sources, we use a same analysis framework and focus on what we call “energy droughts” whose concept rests on the analogy with the classical hydro-meteorological droughts, defined as long periods of very low river flows [22] or periods with no or fairly no precipitation [35][36]. We here propose two definitions of “energy droughts”, considering either 1) Energy Production Droughts as uninterrupted sequences of days with low power production or 2) Energy Supply Droughts as uninterrupted sequences of days with a high production/demand mismatch. We here characterize Energy Supply Droughts within a hypothetical 100% VRE system where electricity generation comes from wind, solar and/or run-of-the-river hydro-power only. We do not base our analysis on site measurements but on high resolution gridded hydrometeorological datasets obtained for a 30-year historical period from satellite observations and from outputs of weather and hydrological models. This allows us to conduct our study on different European regions (12) and thus explore how the characteristics of energy droughts also depend on the climatic spatial variability.

The meteorological datasets and the different weather-to-energy conversion models are presented in section 2 together with the two definitions of energy droughts. Section 3 gathers the results of this study and a comparison of the two droughts definitions. The results are discussed in Section 5 and section 6 concludes our study.

2. Datasets and models

2.1 Hydro-meteorological data

We consider twelve regions homogeneously spread over Europe and Maghreb and having a surface area of about 40000km² (**Fig.1**). As discussed in François et al. [12], they draw a picture of the large variety of climatic conditions existing in Europe with four main influences: a North-South gradient from Scandinavian to Mediterranean climate and a West-East contrast from Oceanic to continental influences.

Fig.1: Locations and boundaries of the 12 test regions. The two letters are further used as regional IDs.

Several meteorological variables are required to simulate electricity production and demand time series. Temperature and precipitation data are based on on-site measurements and are extracted from the European Climate Assessment & Dataset (ECAD, [37]) at a daily time step and on 0.25 degrees grid spacing. Solar radiation series comes from the Surface Solar Radiation Dataset - Heliosat (SARAH) which relies on satellite measurement [38]. It has a 0.05° grid and data are also extracted on a daily basis. Finally, we use pseudo-observations of wind speed derived from simulations of the Weather Research and Forecasting Model which has been forced by the ERA-Interim reanalysis [39]. All these data are available on a 30-yr long research period, extending from 1983 to 2012.

River discharges are highly regulated in most regions of Europe. In order to free ourselves from this anthropogenic influence and only depend on the hydro-climatic variability, we use unregulated discharge estimates. They are obtained with a distributed version of the GSM-Socont hydrological model [40] on a 0.25° grid from each test region [12]. Using the previous precipitation, temperature, and wind speed series, this model simulates the main hydrological processes which drive river discharge (e.g. snowpack dynamics, evapotranspiration, infiltration, runoff transfer).

2.2 Weather-to-energy conversion models

Daily time series of solar, wind and RoR power are simulated from weather and river discharge thanks to “weather to energy” conversion models. These models are based on generic production systems obtained from generic wind turbine, photovoltaic panel or RoR plant. For each energy source, we assume that all grid cells of the considered region have the same level of equipment. The overall regional production is obtained by summing the simulated production values of all grid cells.

For each grid, solar power (P_{PV}) time series is derived from global solar irradiance I_{eff} (Wm^{-2}) and air temperature T_a ($^{\circ}C$) following Perpiñan et al. [41]. The conversion of wind speed into wind power relies on a two-step process. Firstly, the 10m wind speed series are extrapolated to 80m (height of the generic turbine hub), assuming a logarithmic increase in wind speed with increase in altitude. Daily wind speed is then converted into wind power with the idealized power curve described in Francois et al. [12]. To estimate RoR hydro power from river discharge P_{RoR} (kW), we use a classic conversion function (Eq.1) using the water head h (m) defined as the altitude difference between the current grid cell and the lowest point of the region.

$$P_{RoR}(t) = \eta_H g h \rho q(t) \quad (1)$$

where η_H the efficiency of the turbine (%), q the flow passing through the turbine ($m^3.s^{-1}$), g the acceleration of gravity ($=9.81 m.s^{-2}$), ρ the water density ($=1000 kg.m^{-3}$). The water flowing through the turbine is modelled as a non-linear function of the river discharge as described in Francois et al. [12]. The local runoff produced in any given grid is assumed to be ideally harnessed from its location of origin to the catchment’s outlet.

The daily energy load required here to analyse the Energy Supply Droughts is finally estimated for each grid cell from daily temperature (Eq.2). Thus, we put aside all non-weather related influences on the demand, and only focus on the effects of temperature fluctuations. In this way, results from different regions are easily comparable whatever the population or their economic development. The daily energy load L (Wh) is estimated as:

$$\begin{cases} L(t) = a_{T_{Heat}} \times [T_{Heat} - T(t)] + b & \text{if } T(t) < T_{Heat} \\ L(t) = 1 & \text{if } T_{Heat} < T(t) < T_{Cool} \\ L(t) = a_{T_{Cool}} \times [T(t) - T_{Cool}] + b & \text{if } T(t) > T_{Cool} \end{cases} \quad (2)$$

where T_{Heat} and T_{Cool} are the heating and cooling thresholds ($15^{\circ}C$ and $20^{\circ}C$ respectively), b (Wh) is the base load for the temperature-independent range and a_{Theat} ($Wh^{\circ}C^{-1}$), a_{TCool} ($Wh^{\circ}C^{-1}$) are the weather sensitivity coefficients for heating and cooling respectively. The parameters were estimated using observed data of electricity demand from the European Network of Transmission Systems Operators of Electricity (ENTSOE, <https://www.entsoe.eu/home/>) (more details in François et al. [12]).

3. Definition of energy droughts

3.1 Energy Production Droughts (EPD)

We define a low production period as a contiguous sequence of days during every day of which the production is below a given low-production threshold. This analysis requires the calculation of a daily Deficiency Index (DI) time series for each region and energy source. The

DI time series simply reduces the power production to a binary time series equals to 0, when the daily production (P) is greater than the low-production threshold (P_0), or to 1 when lower (**Eq.3**).

$$DI(j) = 1 \text{ if } P(j) \leq P_0 \quad (3)$$

$$DI(j) = 0 \text{ if } P(j) > P_0$$

In our case, the threshold is set to a given percentage of the mean daily production estimated over the whole period of analysis, i.e. 1983-2012. The duration of a low production period is defined as the number of consecutive days for which the DI index equals 1 (**Fig.2a**).

Our definition is different from the one classically used for the analysis of hydrological droughts. In the latter case, the threshold changes periodically in time and usually corresponds to a given percentile of observed discharge data (e.g. the 90% percentile). It is usually estimated by using a moving seasonal window and all available observations falling within [42][43]. In our study, the threshold is time-invariant. Thus, droughts events are defined per-se and not as events that are unusual when compared to a calendar climatology. This definition allows the comparison of droughts regimes and severity obtained for different energy sources or different regions.

We will consider in turns two thresholds which correspond respectively to 0.2 and 0.5 times the mean daily production of the considered region/VRE source. We will refer to the corresponding low productions as moderate and severe “Energy Production Droughts” respectively (EPD in the following).

EPD are defined with respect to the mean daily production obtained for the considered region. They are thus defined per-se and do not depend on the electricity demand. Hence, they only represent a signature of weather and hydrometeorological variability.

3.2 Energy Supply Droughts (ESD)

As mentioned in Section 1, the severity of “energy droughts” can be reinforced (resp. reduced) if they occur during higher (resp. lower) than usual demand periods.

An impact oriented assessment of energy droughts leads to consider Energy Supply Droughts, where the production/demand (im-)balance is accounted for. For the present analysis, we account for the production/demand (im-)balance that would be obtained for each region individually. We thus consider that each region is “autonomous”, i.e. that there is no energy exchanges with the neighbouring regions. We further consider that all the regional production comes from solar, wind and/or RoR hydro power only and that the 30-yr mean regional VRE production equals the 30-yr mean regional electricity demand. This configuration corresponds to the so-called 100 % renewable scenario considered in a number of recent works (e.g. [11][12]). We finally use the “copper plate” assumption within each region and thus consider that there is no energy transmission limitation within each region.

We here also define what we will refer to as low satisfaction periods, as sequences of days for which the non-satisfied demand is greater than a given fraction k of the mean electricity demand. This analysis also requires the calculation of a Supply Deficiency Index (SDI) time series for each energy source and region. This index is estimated on a daily basis as following (**Eq.4**):

$$SDI(j) = 1 \text{ if } (D(j)-P(j)) > k.D_m$$

$$SDI(j) = 0 \text{ if otherwise} \quad (4)$$

Where $D(j)$ is the energy demand on day j , D_m is the mean daily energy demand over the whole 1983-2012 period. The main characteristics of low satisfaction periods are derived from the time series of the SDI index similarly to what has been described for Low Production Periods in Section 3.1 (see **Fig.2b**). We consider two thresholds values, $k=0.5$ and $k=0.8$, which correspond to what we will call moderate and severe Energy Supply Droughts respectively (ESD in the following).

The DI and SDI indices are very similar. Actually, the DI index corresponds to the SDI index for which the electricity demand would be constant in time and equals to the mean production D_m . In our case, it is easy to show that the thresholds considered for the definition of moderate EPD and moderate ESD refer to a same drought intensity level. The same applies to severe EPD and severe ESD. Thus, moderate (resp. the severe) droughts, can be compared for both definitions, making possible to estimate how the production/demand co-variability structure influences the characteristics of energy droughts.

A visual comparison between the two definitions of energy droughts is presented for one year-long time series of simulated hydro power production and energy demand on **Fig.2**.

Fig.2: “Energy Production Droughts” (a) and “Energy Supply Droughts” (b). Illustration for one year of hydropower power production (blue) and energy demand (black) in England. Production and demand time series have been normalized so that the annual average equals 1 for both series. Energy Droughts sequences correspond to the grey shaded bars. In (a) droughts correspond to a production smaller than 0.2 times the mean annual production. In (b) droughts correspond to a difference between demand and production greater than 0.8 (in this configuration the production falls below the dotted line which is

defined from $D(j)-0.8D_m$). These two configurations correspond to the definition of what we call “severe” droughts.

4. Results

For the different energy sources, we now describe the number of days with low production and present the characteristics of EPD and ESD. Some figures only gather information for 3 regions (Norway (NO), Germany (GE), Andalucía (AN)) which draw a rather representative picture of energy droughts features for Europe.

4.1 Days in drought state

Fig.3 presents the cumulative distribution functions (cdfs) of daily power production simulated for wind, solar and hydro power in NO, GE and AN. To make the comparison between energy sources easier, the times series have been scaled dividing them by the mean daily production over the whole 1983-2012 period. The two dashed lines represent the 0.5 and 0.2 thresholds used to identify the days in a moderate or severe drought state respectively.

Wind power classically exhibits the larger range of daily production values with heavy-tailed cdfs (e.g. in GE and AN). The proportion of days in a moderate drought state is rather similar between regions and of about 35%. Conversely, regional differences are much higher for days in a severe drought state with much fewer days in southern Europe (here in AN).

The variability of daily solar power production and the proportion of days in drought state are much higher in Northern Europe than elsewhere. This is obviously a direct consequence of the latitude influence on the space/time daylight variations in Europe. About 25% and 40% days are for instance below the severe and moderate thresholds respectively in NO while only few days are in drought conditions in AN (about 1% for the severe droughts threshold and 10% for the moderate drought one).

For hydropower, the cdf of daily production can have very different shapes from one region to the other. They have similar shapes in Alpine areas, Northern and southern European regions (here NO and AN) with a large proportion of days below the drought thresholds (15% below the 0.2 threshold and about 30% below the 0.5 one). In high elevation or high latitude regions, these days often occur in winter as a result of the typical snow-dominated hydrological regimes of river basins (not shown). The cdfs of hydro power production present less skewness in regions located in plains (here GE), leading to much smaller numbers of days in drought conditions.

Fig.3: Cumulative distribution functions (cdfs) of normalized power production for each VRE source in 3 European regions. Hydro – blue, Wind – orange, Solar – red. See Fig.S1 for results on all 12 regions

4.2 Energy Production Droughts

The characteristics of EPD also depend on the energy source and on the region. **Fig.4** gathers, for the 12 European regions, the mean duration (x axis) and the mean annual frequency (y axis) of energy droughts. Additionally, the background colour scale gives the proportion of days under drought conditions discussed in Sec.4.1. With this representation, all points located on a descending diagonal and for a fixed background colour present the same number of drought days. The representation also makes possible to differentiate configurations with numerous but short droughts (points located in the left/upper side of the diagonal) from situations with rare but long lasting ones (points located in the right/bottom side of a given diagonal).

Fig.5: Reverse cumulative distribution of the duration of Energy Production Droughts for both moderate (top: 50% level) and severe (bottom: 20% level) droughts in NO, GE and AN. Hydro power droughts (blue); wind power droughts (orange), solar power droughts (red). All panels show the percentage of drought events of the 30-yr period that exceed a given duration in days. See Fig.S2.a and Fig.S2.b for results on all 12 regions.

For both moderate and severe droughts, the homogeneity of wind power EPD characteristics is noteworthy: all individual droughts have very short durations (1 to 7 days - Fig.5). The main characteristics of moderate wind power EPD are also very similar from one region to the other (Fig.4). Indeed, whatever the region, moderate droughts are numerous (from 50 to 60 events per year) and last from two to three days in average. The mean duration of severe wind droughts, smaller than 2 days, is also very similar between regions. Conversely, their frequency is more variable with fewer droughts sequences in the Mediterranean regions. This result induces a much lower number of days in severe drought conditions for these regions.

Hydropower droughts are rather rare (less than 5 events per year). Individual hydropower droughts also present a large diversity of duration with relatively short episodes to extremely long ones which can last several months (Fig.5). Conversely to wind EPD, short events (up to a few days) represent a small proportion of hydro-power droughts. Indeed, the hydrological processes and underground storage capacity of river basins work as powerful low-pass filters and ease most of the daily meteorological variability. The characteristics of hydropower droughts depend a lot on the region (Fig.4). The longest droughts are found in Scandinavian and Mediterranean regions. In NO and AN, hydropower droughts can last up to 5 months. However, these EPD occur in different seasons: in summer in TU, AN and GR, in winter in NO, IT and FI (not shown). They respectively result from long periods with no or few precipitation and, for high

elevation/latitude regions, from the storage in snowpack of most winter precipitation. Finally, the characteristics of hydropower droughts also significantly depend on the drought intensity level. Severe hydropower EPD are roughly twice less numerous than moderate ones. They also last 30% to 50% time less. The regional specificities are roughly the same for both drought intensity levels.

The characteristics of solar droughts are in-between those of wind and hydropower droughts (**Fig.4**). The number of solar drought events is medium in all regions. However, there are two different types of droughts with on one hand very short events, and on the other hand 2 to 3 months EPDs (**Fig.5**). Short events correspond to cloudy weather situations, which mainly last a few days. Conversely, long lasting EPDs result from short daylight duration in winter. This effect is logically strengthened in Northern regions (here NO) where it is clearly visible for both moderate and severe EPD. In medium latitude countries, it only impacts moderate droughts whereas no effect can be found in Mediterranean regions.

Whatever the energy source, severe droughts are expected to be less numerous and to present lower mean durations than moderate ones. This is roughly the case for all regions. However, solar EPD in Nordic regions do not respect this rule as a result of the bimodal distribution of drought duration mentioned previously. For these regions, when going from moderate to severe droughts, only short duration events are removed whereas long duration ones remain. It then results in an increase of the mean drought duration.

4.3 Energy Supply Droughts

As mentioned in Sec.1, low production periods can be more (resp. less) critical when co-occurring with high (resp. low) energy demand. **Fig.6** presents the differences in number of days in drought conditions, mean duration and mean annual frequency of droughts between EPD and ESD.

Fig.6: Difference in statistical characteristics from Energy Supply Droughts to Energy production Droughts (ESD-EPD). x-axis: difference in mean duration of drought sequences; y-axis: difference in annual frequency. Colour scale: difference in the number of days in drought state over the simulation period.

For wind power droughts the mean duration of EPD and ESD are very similar whatever the region. The differences in droughts frequencies are also limited for most regions. However, the number of drought days and the annual frequency of drought events tend to be slightly smaller for ESD in Northern regions. It likely results from the partial synchronism between wind

power and demand which both present a seasonal pattern with higher values in winter (higher wind speed and higher demand from heating systems). However, the production / demand co-variability structure can sometimes lead to opposite changes for moderate and severe droughts (e.g. NO).

The characteristics of solar power droughts are strongly impacted by the energy demand. The number of days in drought situation is higher everywhere, except in the southern regions. This result is consistent with the synchronism existing between low winter production due to short day length and high winter energy consumption in northern and central Europe. It is noteworthy that for most regions, higher numbers of drought days are associated with smaller frequencies of drought events (e.g. all regions for moderate droughts and Scandinavian regions for severe droughts). Naturally, this effect is balanced with higher droughts durations. Finally, for some remaining cases (e.g. RO for severe droughts), higher number of drought days result from more droughts sequences but with no changes in mean duration.

For hydro power, the differences between EPD and ESD are strongly region-dependent. The number of droughts days slightly decreases in regions where hydrological regimes present higher river discharge in winter (e.g. FR, GE, GA, GR). ESD tend to be shorter than EPD. This results from the seasonal co-variability between precipitation and electricity demand with higher precipitation, discharge and hydropower production in winter, when heating systems are operating. The opposite co-variability structure happens for the other regions (continental, mountainous and Scandinavian regions) where a higher winter energy demand co-occur with low winter discharges. This latter configuration increases the number of days in drought conditions with shorter and more frequent ESD sequences in NO or longer sequences with similar annual frequency in RO for instance.

Whatever the energy source, small differences exist between EPD and ESD in southern regions. It is probably a consequence of a lower sensitivity of the demand to regional temperature changes. Indeed, the weather is relatively mild from autumn to spring, making the demand roughly weather-independent. In other countries, heating systems tend to boost the winter demand. On the other hand, the summer increase in demand from air conditioning is of relatively small magnitude in our temperature-demand model (Fig.7).

Fig.6: Temperature to energy demand function (dashed broken linear line) **with seasonal and annual distributions of daily temperature** (DJF-blue, MAM-green, JJA-ref, SON-orange, annual-black). See Fig.S3 for results on all 12 regions.

5. Discussion

In Sec.4, we showed that the characteristics of Energy Droughts depend on both energy source and regional climate. They are also expected to depend on non-climatic factors such as technical components and structural choices for power supply systems. In this section we illustrate how Energy Drought's characteristics would be changed for power system using a mix of energy sources or including some storage facilities to balance the production/demand temporal mismatch.

5.1 Energy droughts for an energy mix

Mixing energy sources is known to reduce the variability of the production and classically improves the production/demand match [11]. For the 12 European regions considered here, François et al. [12] estimated energy mixes based on hydro, solar and wind power, which maximize the mean daily production/demand match (c.f. share coefficients in Tab.1). We here illustrate how this mix may also influence the statistical characteristics of Energy Droughts.

Fig.8 presents the characteristics of EPD obtained with these regional mixes for both moderate and severe droughts. It should be compared to **Fig.4** which presents the results of single VRE sources. In all cases, a large decrease in drought severity is obtained with the mix. The number of days under drought conditions is drastically decreased, by a factor 2 to 10 depending on the region and on the single VRE source considered initially. This decrease results in a large reduction of both duration and frequency of energy droughts. For some regions, the combination of VRE sources even leads to the complete removal of severe droughts (e.g. AN). Thus, the complementarity that exists between VRE sources can make power systems much less prone to EPD.

Fig.7: Effect of a VRE mix (see Tab.1) on moderate and severe Energy Production Droughts. Figure to be compared with Fig.4 (caption details in Fig.4).

Tab.1: Regional energy mix proposed by François et al. [12]. Share coefficients are given for solar power (S_{PV}), wind power (S_W) and hydropower (S_{RoR}) for the 12 regions.

	S_{PV} (%)	S_W (%)	S_{RoR} (%)
Finland	15	35	50
Norway	15	50	35
Belarus	5	30	65
England	20	15	65
Germany	35	15	50
France	45	15	40
Italy	30	35	35
Romania	25	35	40
Greece	45	10	45
Galicia	45	10	45
Andalucía	50	10	40
Tunisia	40	20	40

5.2 Energy droughts and storage

Storage systems, such as water reservoirs and batteries, can also ease the integration of VRE; balancing part of the missing production with the energy surplus stored on previous days [44][45][46].

Fig.9 presents the effect of storage on ESD characteristics in NO, GE and AN. Similar results are obtained for the other regions. We consider 4 simplified and idealized storage systems with different storage capacities corresponding respectively to 1, 7, 30 and 90 days of mean energy load. The energy transfer from and toward the storage system is simulated on a daily basis. Depending on the daily production/demand balance, the storage system either fills up, storing the energy surplus, or runs out, to satisfy more demand (see [47] for details). For simplification, we assume a perfect storage (no power loss).

For wind power, the frequency of drought episodes is efficiently lowered even with small storage capacity. When a large storage is involved, only few drought events remain. This result directly comes from the high frequency variations of wind power and the short durations of wind power droughts.

As mentioned previously, hydro power droughts have rather long duration in most regions. Therefore, small size storage systems do not lead to a significant reduction of droughts: the number of drought days does not change much. However, small size storage leads to a

reduction of droughts frequency, which is counterbalanced with an increase in mean drought duration. A significant reduction of drought severity is obtained for storage capacities larger than 30 days of mean demand. The seasonal based size ($S = 90$) is even more efficient but still does not lead to similar improvement as for wind power.

Similar comments apply for solar power. Small storage capacity does not change the number of drought days but often leads to longer and less numerous droughts events. Different modifications occur depending on the regional location in latitude. Even with large storage systems, Northern regions still suffer from long and numerous solar power droughts. Conversely, these critical periods are almost all removed in Mediterranean regions, even with medium storage capacity (here AN).

Fig.8: Effect of storage on Energy Supply Droughts characteristics. Mean number of drought episodes versus mean drought duration. Results are displayed for hydro-power (blue), solar-power (red), wind-power (orange). The points associated to different storage capacities but from the same energy source have been connected in a logical order. They correspond to $S = 1, 7, 30$ and 90 days of mean energy load ($S=1$ in bold). The colour scale gives the mean annual number of days under drought conditions. See Fig.S4.a and Fig.S4.b for results on all 12 regions.

6. Conclusions

The similarities in stochastic nature and characteristics (occurrence, duration, intensity) between low production periods from VRE sources and low flow periods in hydrology call for the introduction of the concept of Energy Droughts.

In this study, we showed the strong variations of Energy Droughts characteristics between sources and within Europe. Wind droughts are very numerous but present very short duration, whatever the location. Solar droughts are of two types: 1) those that directly derive from the seasonal cycle of daylight which are long lasting especially in northern regions 2) those induced by the weather variability (changes in cloud cover) which usually last a few days maximum. Hydropower droughts are much more region and time dependent as a result of the combined effects of meteorological droughts (snow accumulation or lack of rainfall / snow melt) and of the low pass filtering behaviour of river basins. Whatever the region, the complementarity that exists between wind, solar and hydro would make VRE mixes much less prone to energy droughts than systems based on one single VRE source.

The characterization of Energy Droughts is expected to enlighten decision makers in the design of future renewable power systems, including the provision of backup and/or storage solutions. As illustrated in this study, the analysis of Energy Droughts should take into account the electricity demand sensitivity to weather conditions. Indeed, it can potentially increase / decrease the socio-economic impact of drought events, depending on the co-variability structure between production and demand.

Our work is based on a number of assumptions, data and modelling choices, which potentially lead to some uncertainty in our results. The hydro-meteorological data used here are not observations but pseudo-observations (e.g. radiation from satellite products, surface winds from WRF). Of course, such data present limitations. However, conversely to observed data, pseudo-observations are available at high space - time resolution and classically cover rather long periods of time, even in ungauged regions. They allow having a more relevant view of unusual hydro-meteorological events. The temporal and spatial organisation (and next co-variations) of these pseudo-observations is also a priori consistent with the weather conditions of the 1983-2012 period. Thus, our analysis is expected to give a reasonable picture of the main features of energy droughts in different European climates for the last decades and of their specificities for the different types of VRE sources. However, further studies should consider the possibility to use the higher quality datasets (e.g. high resolution reanalyses of surface weather) that should be available in the coming years.

The choice of the weather-to-energy model is also another source of concern. Generic production systems have been considered for all regions. However, a variety of technological solutions which have their own weather-to-energy conversion relationships exist to harvest VREs. These relationships are classically highly non-linear and vary from one plant to the other. For instance, this is the case for wind turbines (cut-in / cut-off thresholds in the wind speed – wind power relationship) or for hydropower-plants which present an even greater variety with site-dependent specificities. Consequently our results are expected to significantly depend on these technical features. Similarly, the weather driven part of the energy demand was estimated with a unique model for all regions. However, the sensitivity of the demand to temperature can strongly vary from one region to the other. For instance, the winter sensitivity in FR and NO is actually twice higher than the average relationship estimated for our 12 European regions; most heating systems being based on electricity in these regions. Similarly, the summer sensitivity is roughly 5 times greater in IT and GR than elsewhere as a result of a much higher proportion of households equipped with air conditioning. The weather sensitivity of the demand obviously determines the differences between Energy Production Droughts and Energy Supply Droughts. Further studies should explore how our results depend on the technical and socio-economic

configuration. However, the main conclusions of our analysis are not expected to drastically change.

As mentioned previously, Energy Production Droughts are a signature of weather and hydrometeorological variability. Thus, they are defined per-se. Conversely, Energy Supply Droughts depend on a number of socio-economic and technical factors, including those pertaining to the energy mix and the power system considered. To provide some insight on Energy Supply Droughts, part of our analysis was carried out with the 100% renewable energy scenario. In this context, we assume that the resource is sufficient to provide the whole energy demand. This is likely not the case for all the configurations we considered. This would depend on the available mean resource itself which can be rather low in some regions (e.g. solar in the north) and on the mean demand which can be rather large in highly populated areas. The operational feasibility of such a 100% scenario is also obviously questionable, as discussed in a number of recent publications (see for instance [48] and [49]). Whatever those possible limitations, the 100% VRE scenario offers a convenient and simple analysis framework able to give informative perspective of a configuration to which a number of countries / regions are prone to head toward [1]. In our analysis, it allows highlighting the interest of mixing of solar/hydro/wind sources, using the space/time complementarity between single sources. It also allows analysing how low resources sequences could interplay with high demand sequences as a result of the co-variability between weather variables. The analysis proposed here thus allows drawing a first but already informative picture of other energy droughts issues. Further works should consider a more realistic representation of the energy mix and power system. We here for instance focused our analysis on specific European regions assumed to be independent from each other. This is obviously not the case owing to the wide European electricity grid which connects regions and makes them less vulnerable to local weather variations. Further works should then consider Energy Droughts in a broader space-time framework to determine the characteristics of Energy Droughts over a continuum of spatial scales from local to European ones. The potential severity of European-wide events is of major interest for building a reliable pan-European power system. On the other hand, Energy droughts should also be studied at a very local scale, for a reliability analysis of mini-grids and stand-alone power systems which are appropriate for remote and isolated communities and/or industries.

Energy Droughts are a key security issue of the energy supply challenge in a context where the share of VRE is continuously increasing worldwide. This call for a detailed characterization of their main statistical properties and extreme return levels similarly to what is classically done for meteorological and/or hydrological extremes. This characterization should account for the likely intensification of the hydrological cycle and of hydro-meteorological extremes expected from the ongoing climate change. Energy droughts will likely also challenge the operational management of the energy systems. To support their real-time management for instance, further works should also explore / understand the large-scale meteorological and/or atmospheric configurations prone to Energy Droughts and assess the possibility to forecast such events. We can likely expect that these different issues will gain increasing attention in the coming years.

7. Acknowledgement

This work is part of the FP7 project COMPLEX (Knowledge based climate mitigation systems for a low carbon economy; Project FP7- ENV-2012 number: 308601; <http://www.complex.ac.uk/>).

8. References

- [1] European Climate Foundation (2010). Roadmap 2050: a practical guide to a prosperous, low carbon Europe. Brussels. Available online: <http://www.roadmap2050.eu/>
- [2] Hoogwijk, M., & Graus, W. (2008). Global potential of renewable energy sources: a literature assessment. Background report prepared by order of REN21. Ecofys, PECSNL072975.
- [3] International Energy Agency, 2016. World Energy Outlook 2016. Paris.
- [4] Šturc, M. (2012). Renewable Energy: Analysis of the Latest Data on Energy from Renewable. Eurostat, European Union: Luxembourg. Available online: <http://ec.europa.eu/eurostat/web/products-statistics-in-focus/-/KS-SF-12-044>.
- [5] Piria, R., Junge, J. (2013). Norway's Key Role in the European Energy Transition. Smart Energy for Europe Platform: Berlin, Germany. Available online : http://jointdeclaration.org/wp-content/uploads/2013/06/Norway-key-role-energy-transition_web.pdf
- [6] BFE, Bundesamt für Energie. (2013). Statistique suisse de l'Electricité 2013, Bern, Switzerland, Technical report, 56pp. Available online at: <http://www.bfe.admin.ch/>.
- [7] GSE, (2011). Statistical Report: Renewable Energy Power Plants in Italy, Technical report Gestore Servizi Energetici; 2010e2011, 64pp. available online at: http://www.gse.it/it/Dati%20e%20Bilanci/GSE_Documenti/ENG/Italy%20RES%20Statistical%20Report%202011%20WEB%20def%2015-11-2012%20%20tag.pdf. Last access November 2014
- [8] Khan, M. J., Bhuyan, G., Iqbal, M. T., & Quaicoe, J. E. (2009). Hydrokinetic energy conversion systems and assessment of horizontal and vertical axis turbines for river and tidal applications: A technology status review. *Applied Energy*, 86(10), 1823-1835.
- [9] Sample, J. E., Duncan, N., Ferguson, M., & Cooksley, S. (2015). Scotland' s hydropower: Current capacity, future potential and the possible impacts of climate change. *Renewable and Sustainable Energy Reviews*, 52, 111-122.
- [10] Engeland, K., Borga, M., Creutin, J.D., François, B., Ramos M.H., Vidal, J. (2017) Space-time variability of climate and hydro-meteorology and intermittent renewable energy production – a review. *Renewable & Sustainable Energy Reviews*, 79, pp.600-617
- [11] Von Bremen, L. (2010). Large-scale variability of weather dependent renewable energy sources. In Management of weather and climate risk in the energy industry (pp. 189-206). Springer Netherlands.

- [12] François, B., Hingray, B., Raynaud, D., Borga, M., & Creutin, J. D. (2016). Increasing climate-related-energy penetration by integrating run-of-the river hydropower to wind/solar mix. *Renewable Energy*, 87, 686-696.
- [13] Lave M, Kleissl J, Arias-Castro E. (2012). High-frequency irradiance fluctuations and geographic smoothing. *Sol Energy*;86:2190–9. <http://dx.doi.org/10.1016/j.solener.2011.06.031>.
- [14] Sørensen P, Cutululis NA, Viguera-Rodríguez A, Jensen LE, Hjerrild J, Donovan MH, et al. (2007). Power fluctuations from large wind farms. *IEEE Trans Power Syst*; 22:958–65. <http://dx.doi.org/10.1109/TPWRS.2007.901615>.
- [15] Sevlian R, Rajagopal R. (2013). Detection and statistics of wind power ramps. *IEEE Trans Power Syst*; 28:3610–20. <http://dx.doi.org/10.1109/TPWRS.2013.2266378>.
- [16] IEA-ETSAP and IRENA. (2015). Renewable Energy Integration in Power Grids. Technology Brief. Available from : www.irena.org/Publications.
- [17] Van Vliet M. et al. (2016). "Impacts of recent drought and warm years on water resources and electricity supply worldwide." *Environmental Research Letters* 11.12.
- [18] Gleick P. (2015) "Impacts of California's ongoing drought: hydroelectricity generation." Oakland, CA.
- [19] Hannaford, J., Lloyd-Hughes, B., Keef, C., Parry, S., & Prudhomme, C. (2011). Examining the large-scale spatial coherence of European drought using regional indicators of precipitation and streamflow deficit. *Hydrological Processes*, 25(7), 1146-1162.
- [20] Lima C and Upmanu L. (2010) Climate informed long term seasonal forecasts of hydroenergy inflow for the Brazilian hydropower system. *Journal of hydrology* 381.1: 65-75.
- [21] Haro-Monteagudo D, Abel S and Joaquín A. (2017). Drought early warning based on optimal risk forecasts in regulated river systems: Application to the Jucar River Basin (Spain). *Journal of Hydrology* 544: 36-45.
- [22] Lavagnini, A., & Martorelli, S. (1987). Wind persistence in 135 Italian localities. II *Nuovo Cimento C*, 10(6), 651-667.
- [23] Poje, D. (1992). Wind persistence in Croatia. *International journal of climatology*, 12(6), 569-586.
- [24] Deaves, D. M., & Lines, I. G. (1998). The nature and frequency of low wind speed conditions. *Journal of Wind Engineering and Industrial Aerodynamics*, 73(1), 1-29.
- [25] Leahy P and Eamon J (2013). Persistence of low wind speed conditions and implications for wind power variability. *Wind Energy* 16.4: 575-586.
- [26] Fisher S et al. (2013). The effects of geographical distribution on the reliability of wind energy. *Applied Geography* 40: 83-89.
- [27] Handschy, M. A., Rose, S., & Apt, J. (2017). Is it always windy somewhere? Occurrence of low-wind-power events over large areas. *Renewable Energy*, 101, 1124-1130.
- [28] Pelland S, et al. (2013). Photovoltaic and solar forecasting: state of the art. IEA PVPS, Task 14: 1-36.

- [29] Köhler C, et al. (2017). Critical weather situations for renewable energies–Part B: Low stratus risk for solar power. *Renewable Energy* 101: 794-803.
- [30] Rieger, D., Steiner, A., Bachmann, V., Gasch, P., Förstner, J., Deetz, K, Vogel, H. (2017). Impact of the 4 April 2014 Saharan dust outbreak on the photovoltaic power generation in Germany. *Atmospheric Chemistry and Physics*, 17(21), 13391.
- [31] Sinden, G. (2007). Characteristics of the UK wind resource: Long-term patterns and relationship to electricity demand. *Energy Policy*, 35(1), 112-127.
- [32] Leahy, P. G., & Foley, A. M. (2012). Wind generation output during cold weather-driven electricity demand peaks in Ireland. *Energy*, 39(1), 48-53.
- [33] Steiner, A., et al. (2017). "Critical weather situations for renewable energies–Part A: Cyclone detection for wind power." *Renewable Energy* 101: 41-50.
- [34] François, B. (2016). Influence of winter North-Atlantic Oscillation on Climate-Related-Energy penetration in Europe. *Renewable Energy*, 99, 602-613.
- [35] McKee, T. B., Doesken, N. J., & Kleist, J. (1993, January). The relationship of drought frequency and duration to time scales. In *Proceedings of the 8th Conference on Applied Climatology* (Vol. 17, No. 22, pp. 179-183). Boston, MA: American Meteorological Society.
- [36] Hayes, M., Svoboda, M., Wall, N., & Widhalm, M. (2011). The Lincoln declaration on drought indices: universal meteorological drought index recommended. *Bulletin of the American Meteorological Society*, 92(4), 485-488.
- [37] Haylock, M. R., Hofstra, N., Klein Tank, A. M. G., Klok, E. J., Jones, P. D., & New, M. (2008). A European daily high-resolution gridded data set of surface temperature and precipitation for 1950–2006. *Journal of Geophysical Research: Atmospheres*, 113(D20).
- [38] Müller, R., Pfeifroth, U., Träger-Chatterjee, C., Cremer, R., Trentmann, J., and Hollmann, R. (2015). Surface Solar Radiation Data Set - Heliosat (SARAH) - Edition 1". Satellite Application Facility on Climate Monitoring.
- [39] Vautard, R., Thais, F., Tobin, I., et al. (2014). Regional climate model simulations indicate limited climatic impacts by operational and planned European wind farms. *Nature Communications*, 5:3196.
- [40] Schaefli, B., Hingray, B., Niggli, M., & Musy, A. (2005). A conceptual glacio-hydrological model for high mountainous catchments. *Hydrology and Earth System Sciences*, 995-109.
- [41] Perpinan, O., Lorenzo, E., & Castro, M. A. (2007). On the calculation of energy produced by a PV grid-connected system. *Progress in Photovoltaics: research and applications*, 15(3), 265-274.
- [42] Hisdal, H., Stahl, K., Tallaksen, L. M., & Demuth, S. (2001). Have streamflow droughts in Europe become more severe or frequent?. *International Journal of Climatology*, 21(3), 317-333.
- [43] Tallaksen, L. M., & Van Lanen, H. A. (2004). Hydrological drought: processes and estimation methods for streamflow and groundwater. 579pp. Amsterdam ; Boston, Elsevier.

- [44] Rasmussen, M. G., Andresen, G. B., & Greiner, M. (2012). Storage and balancing synergies in a fully or highly renewable pan-European power system. *Energy Policy*, 51, 642-651.
- [45] Steinke, F., Wolfrum, P., & Hoffmann, C. (2013). Grid vs. storage in a 100% renewable Europe. *Renewable Energy*, 50, 826-832.
- [46] François, B., Martino, S., Tøfte, L. S., Hingray, B., Mo, B., & Creutin, J. D. (2017). Effects of Increased Wind Power Generation on Mid-Norway's Energy Balance under Climate Change: A Market Based Approach. *Energies*, 10(2), 227.
- [47] Francois, B., Borga, M., Creutin, J. D., Hingray, B., Raynaud, D., & Sauterleute, J. F. (2016). Complementarity between solar and hydro power: sensitivity study to climate characteristics in Northern-Italy. *Renewable Energy*, 86, 543-553.
- [48] Clack, C. T., Qvist, S. A., Apt, J., Bazilian, M., Brandt, A. R., Caldeira, K., & Jaramillo, P. (2017). Evaluation of a proposal for reliable low-cost grid power with 100% wind, water, and solar. *Proceedings of the National Academy of Sciences*, 201610381.
- [49] Jacobson, M. Z., Delucchi, M. A., Cameron, M. A., & Frew, B. A. (2017). The United States can keep the grid stable at low cost with 100% clean, renewable energy in all sectors despite inaccurate claims. *Proceedings of the National Academy of Sciences*, 114(26), E5021-E5023.