Unconditional decentralized structure for the fault diagnosis of discrete event systems

Alexandre Philippot, M Sayed Mouchaweh, Véronique Carré-Ménétrier

► To cite this version:

Alexandre Philippot, M Sayed Mouchaweh, Véronique Carré-Ménétrier. Unconditional decentralized structure for the fault diagnosis of discrete event systems. 1st IFAC Workshop on Dependable Control of Discrete Systems, Jun 2007, Cachan, France. hal-02338135

HAL Id: hal-02338135

<https://hal.science/hal-02338135>

Submitted on 29 Oct 2019

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

See discussions, stats, and author profiles for this publication at: <https://www.researchgate.net/publication/289986699>

Unconditional decentralized structure for the fault diagnosis of discrete event systems

Article · January 2007

CITATIONS

11

READS

20

3 authors:

Alexandre Philippot

Université de Reims Champagne-Ardenne

79 PUBLICATIONS 202 CITATIONS

[SEE PROFILE](#)

M. Sayed Mouchaweh

Institut Mines-Télécom Lille Douai

128 PUBLICATIONS 827 CITATIONS

[SEE PROFILE](#)

Véronique Carré-Ménétrier

Université de Reims Champagne-Ardenne

61 PUBLICATIONS 236 CITATIONS

[SEE PROFILE](#)

Some of the authors of this publication are also working on these related projects:

Special Issue on "Advanced Soft Computing for Prognostic Health Management" [View project](#)

Intelligent Manufacturing Systems [View project](#)

UNCONDITIONAL DECENTRALIZED STRUCTURE FOR THE FAULT DIAGNOSIS OF DISCRETE EVENT SYSTEMS

A. Philippot¹, M.Sayed-Mouchaweh², V. Carré-Ménétrier²

¹ LURPA, ENS de Cachan, 61 avenue du Président Wilson, 94235 CACHAN Cedex, France
alexandre.philippot@lurpa.ens-cachan.fr

² CReSTIC - LAM, Moulin de la Housse B.P. 1039, 51687 REIMS Cedex 2, France
moamar.sayed-mouchaweh@univ-reims.fr, veronique.carre@univ-reims.fr

Abstract: This paper proposes an unconditional decentralized structure to realize the fault diagnosis of Discrete Event Systems (DES), specially manufacturing systems with discrete sensors and actuators. This structure is composed on the use of a set of local diagnosers, each one of them is responsible of a specific part of the plant. These local diagnosers are based on a modular modelling of the plant in order to reduce the state explosion. Each local diagnoser uses event-based, state based and timed models to take a decision about fault's occurrences. These models are obtained using the information provided by the plant, the controller and the actuators reactivity. All local diagnosis decisions are then merged by a Boolean operator in order to obtain one global diagnosis decision. Finally, the diagnosers are polynomial-time in the cardinality of the state space of the system. This approach is illustrated using an example of manufacturing system.
Copyright © 2007 IFAC

Keywords: Diagnosis, Discrete Event Systems, Decentralized approaches, Modelling, Manufacturing systems.

1. INTRODUCTION

The increasing complexity of processes raises their potential to fail regardless how safe the control design is and how better trained the operators are. Thus, diagnosis of industrial systems is a subject that has received a great attention in the past few decades (Boufaïed, 2003, Genc and Lafortune, 2003, Klein, *et al.*, 2005). It is defined as the process of detecting and isolating a failure (Darkhovski and Staroswiecki, 2003). The fault detection is the operation of deciding whether a failure has occurred or not. This latter is followed by the fault isolation in order to determine the kind and the location of the failure. Any abnormal change in the system's behaviour is caused by a fault whereas a complete operational breakdown is denoted as a failure. In this paper, the two terms are used synonymously.

A failure is detected if the predicated state, provided by the model, does not match with the real one characterized by the observations issued of sensors. The diagnosis can be realized using several structures. In the centralized structure, a global diagnoser performs one decision based on a global model, about the normal and/or abnormal functioning of a system. A diagnoser is a special case of an observer that carries fault information by

means of labels. Consequently, the major drawback of centralized structure is the combinatory explosion. In decentralized structure, there are several local diagnosers which operate independently without any communication among each other. The local diagnosis decisions are then merged in order to obtain one global decision equivalent to the one of the centralized diagnoser. This fusion can be realized using unconditional, conditional or coordinated structures. In the unconditional structures (Wang, *et al.*, 2004), the local diagnosis decisions are merged trivially using a simple logical operator. While in conditional (Wang, *et al.*, 2004) or coordinated structures (Debouk, *et al.*, 2000), the local diagnosis decisions are then merged using a set of rules, or an estimation and an intersection of previous and actual diagnosers states. These rules, or state estimation and intersection, are combined by a coordinator. This latter is necessary to solve the decision conflicts or ambiguity among local diagnosers, appeared due to the partial observation of the system.

Communication networks, manufacturing systems, computer networks or power networks are considered in a Discrete Event Systems (DES) framework and are based on a finite-state automaton (Cassandras and Lafortune, 1999). It defines how system states change due to event occurrences. They are

informationally and geographically decentralized. Consequently, decentralized diagnosis structures are well adapted to realize the fault diagnosis. The decentralized approaches, as the ones proposed by (Wang, *et al.*, 2004, Debouk, *et al.*, 2000) and the references therein, suffer of some major drawbacks. Firstly, they need a global model of the system normal and faulty functioning. Since the decentralized approaches are developed for the large scale systems, the construction of a global model entails the state explosion. Secondly, the state space of diagnosers is, in the worst case, exponential in the cardinality of the state space of the system model. Thirdly, these diagnosers are event-based model, i.e., the fault is considered as the execution of an event. Thus, the diagnoser and the system model must be initiated at the same time to allow them both responding simultaneously to events. This synchronisation of initialization is hard to obtain in manufacturing systems. In this paper, a solution to these problems is proposed.

The paper is organized as follows. In section 2, the proposed approach, to realize the fault diagnosis and its structure are presented. Then, the steps required to construct the local diagnosers of this approach are detailed and illustrated using an example of manufacturing system in section 3. Finally, advantages, drawbacks and perspectives for the future works are discussed in section 4.

2. PROPOSED APPROACH

The proposed decentralized approach is based on the use of several local models G_i , $i \in \{1, 2, \dots, n\}$. Each local model G_i represents the behaviour of an actuator and its related sensors, and is associated with a local diagnoser D_i , $i \in \{1, 2, \dots, n\}$. The goal of the use of local models is to reduce the combinatory explosion problem at the design stage and to facilitate the localisation of faulty elements. This approach is modular, i.e., the approach exploits the structure of the system as captured by the individual model and their respective sets of common events (Philippot, 2006).

This approach uses different representation tools (automata, GRAFCET, prediction function and Boolean rules) according to the available information. The goal is to enrich the model using all the available information sources with a suitable representation tool to be able to realize the diagnosis.

Fig. 1. Information sources

Fig. 2. Automated manufacturing system

The sources are (Fig. 1):

- Operational information characterizing the desired behaviour (control model),
- Structural information coming from the process itself and the sensors-actuators spatial distribution (plant model),
- Temporal information coming from the reactivity of the actuators (temporal model).

The local diagnosers are based on the combination of the control, plant and temporal models. The goal is to diagnose all faults violating the desired behaviour. A minimal/maximal interval response times for each actuator is supposed to be known. Each local diagnoser is responsible of a specific part of the plant and uses event-based, state based and timed models to take a decision about fault's occurrences. All local diagnosis decisions are then merged by a Boolean operator in order to obtain one global diagnosis decision.

To illustrate the proposed approach, we use the example of the figure 2 permitting the sorting of small and large pieces. It is composed of:

- One cylinder with three positions indicated by the sensors $p1ar$, $cp2$ and $cp3$. The cylinder moves forward upon the activation of the command $Out1$ and the reverse action is obtained by the command $In1$.
- Two cylinders are used to push the pieces onto their corresponding conveyor (conveyor 2 for small pieces and conveyor 3 for large pieces). These two conveyors are supposed to be in permanent rotation. Each cylinder has two sensors to indicate respectively its home and fully extended positions ($p2ar$ and $ct2$ for the cylinder 2, $p3ar$ and $ct3$ for the cylinder 3). The commands $Out2$ and $Out3$ are respectively for the activation of the forward movement for the cylinders 2 and 3. The two cylinders return back to their home position by the activation of respectively $In2$ and $In3$.
- The pieces are provided by the conveyor 1 which is activated by the command $C1$. This conveyor is in rotation until at least one of the detectors a and b has the logical value 1, due to the detection of a small piece ($a = 1$), a large piece ($b = 1$) or the fully extended position of the cylinder 1 (a or $b = 1$).

3. LOCAL DIAGNOSERS CONSTRUCTION

3.1 Plant model

The plant model construction is a complex operation. Firstly, a plant model is affected by combinatory explosion when a centralized approach is used. Secondly, all technology's specificities must be expressed. To solve these problems, the plant is divided into several components (one for each actuator and its associated sensors) called Plant Element (PE). Consequently, the plant is composed by n Plant Element: PE_i , $i \in \{1, 2, \dots, n\}$. Each PE_i is modelled by an automaton $G_i = (X_i, \Sigma_i, \delta_i, x_{i0})$ with X_i the set of states, Σ_i a set of finite events and it includes the observable and unobservable events, $\delta_i(\sigma, x)$ provides the set of possible next states if the event σ occurs at state x and x_{i0} is the initial state. Thus, the PE are defined as event-based model and use the Balemi interpretation (Balemi, *et al.*, 1993) where “ $\uparrow$ ” is the change of a value from 0 to 1 and “ $\downarrow$ ” is the change of a value from 1 to 0. The detailed explication of the construction of this model can be found in (Philippot, 2006).

For the example of the figure 2, the plant is divided into 6 components: cylinders 1 with sensors $p1ar$, $cp2$ and $cp3$, cylinder 2 with sensors $p2ar$ and $ct2$, cylinder 3 with sensors $p3ar$ and $ct3$, conveyor 1 with sensors a and b , conveyor 2 with sensor $ct2$ and finally conveyor 3 with sensor $ct3$. We explain the construction of the plant model for the cylinder 2, PE_{cy2} . The plant models of the other components are constructed in a similar way and can be found in (Philippot, 2006). For PE_{cy2} , there are 2 commands producing 4 controllable events $\{\uparrow Out2, \downarrow Out2, \uparrow In2, \downarrow In2\}$ and 4 uncontrollable events corresponding to the sensors outputs $p2ar$ and $ct2$. The PE_{cy2} contains 15 states (Fig. 3).

3.2 Control model

The control model defines the global desired behaviour of the system and it is represented by the prefixed closed specification language K . Since the approach is decentralized, the control specification must be locally integrated in each PE_i to obtain a Controlled Plant Element CPE_i with $i \in \{1, 2, \dots, n\}$. Each CPE_i describes the local desired behaviour of the component by an automaton $C_i = (X_{Ci}, \Sigma_i, \delta_i, x_{i0})$ with a local specification language $K_i = L(C_i)$. Consequently, the desired behaviour language of a CPE_i is included in the language of the PE_i ($K_i \subseteq L(G_i)$).

Fig. 3. Plant Element model PE_{cy2} of the cylinder 2

Fig. 4. Algorithm of intersection between Plant Element and Controller

The construction of the CPE is obtained by a local intersection between the PE and a global control model. GRAFCET is used to represent the global control model because it is widely used in industrial applications. However, GRAFCET semantics is different of the one of automata. Consequently, we have defined an algorithm to solve this problem, and it is based on the following three steps (Fig. 4):

- 1) The first step is the construction of an equivalent automaton from the GRAFCET semantics. This automaton is obtained by an extraction algorithm described in (Philippot, 2006) and called Equivalent Graph (EG). The EG is constructed in function of the controllable and uncontrollable events of the system.
- 2) The restriction language for each PE_i is done in the second step. This restriction is obtained by an aggregation of states reached through non observable events by the PE_i . This aggregation corresponds to a projection function or mask $P_{L(G_i)}(EG)$ of EG on the language $L(G_i)$ of PE_i with the suppression of some states to guarantee the liveness of the model. This restriction is so-called Restricted Equivalent Graph for Plant Element i ($REGPE_i$) and is totally described in (Philippot, 2006).
- 3) The third step is a local synchronized composition between the $REGPE_i$ and the corresponding PE_i . The resulting automaton C_i of this composition represents the local desired behaviour of the CPE_i .

The global control model for the example of Fig. 2 is a GRAFCET with 8 steps and 9 transitions. The integration of the global control model locally in the plant model of the cylinder starts by the extraction of the Equivalent Graph EG of the GRAFCET (Fig. 5a). This EG is an automaton of 28 states.

The restriction language step of EG to the observable events by PE_{cy2} gives a Restricted Equivalent Graph for Plant Element of the cylinder 2 ($REGPE_{cy2}$). This latter is an automaton of 6 states where the state 1 is an aggregation of the states $\{1, 2, 3, 4, 5, 6, 7, 9, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28\}$ of the EG because there is non observable events by the cylinder 2. It is the observable event $\uparrow Out2$ which allows the transition to the state 2 (Fig. 5b). The controlled plant elements for the other components can be obtained in a similar way (Philippot, 2006).

Fig. 5. Language restriction for the cylinder 2

Fig. 6. Controlled Plant Element CPE_{cy2} of the cylinder 2

The last step of the algorithm of intersection is the local composition between the REGPE_{cy2} (Fig. 5b) and the PE_{cy2} (Fig. 3). The desired behaviour of each component leads to a Controlled Plant Element CPE_i. For the cylinder 2, the automaton CPE_{cy2} has 8 states (Fig. 6).

3.3 Temporal information

The majority of sensors and actuators in manufacturing systems produces constrained events since state changes are usually effected by a predictable flow of materials (Boufaïed, 2003, Pandalai and Holloway, 2000). Therefore, a timed model centred on the notion of expected event sequencing and timing relationships can be used. The temporal information about events minimal and maximal occurrence instants is represented by the actuator's minimal and maximal response times.

In this paper, we define a Prediction Function PF_x for each state x to evaluate the satisfaction, $PF_x = 0$, or the non satisfaction, $PF_x = 1$, of the temporal relationships between input and output events. Each prediction is constructed for observable correlated events and it describes the next events that should occur and the relative time periods in which they are expected. These pre-defined time periods are determined by experts according to the system dynamic and to the desired behaviour. This prediction has the following form: $PF_{xI} = PF(\alpha_I, \alpha_2) = \{\alpha_I, x_I, (\alpha_2, [t_{\min 1}, t_{\max 2}], x_2, l_I)\}$. When the event α_I

occurs at the state x_I , the event α_2 should happen at the state x_2 and within the interval $[t_{\min 1}, t_{\max 2}]$. If it is the case then the prediction consequent is satisfied, $PF_{xI} = 0$. When it is not the case, the event α_2 has occurred before $t_{\min 1}$ or after $t_{\max 2}$, the prediction consequent is not satisfied and it provides the causes of this non satisfaction through a decision function l_I corresponding to a faulty label (Fig. 7).

Prediction functions take into account the impression contained in the calculation of events occurrences instants. They also provide interesting information for the prediction of future failure, i.e., prognostic ($0 < PF_x < 1$). The value of the prediction function is obtained by:

$$\forall \alpha_I, \alpha_2 \in \Sigma_o, PF(\alpha_I, \alpha_2) = \begin{cases} 1 & \text{if } \tau < t_{\min 1} \\ \frac{\tau - t_{\min 2}}{t_{\min 1} - t_{\min 2}} & \text{if } t_{\min 1} \leq \tau < t_{\min 2} \\ 0 & \text{if } t_{\min 2} \leq \tau \leq t_{\max 1} \\ \frac{\tau - t_{\max 1}}{t_{\max 2} - t_{\max 1}} & \text{if } t_{\max 1} < \tau < t_{\max 2} \\ 1 & \text{if } \tau > t_{\max 2} \end{cases}$$

$\tau = \theta(\alpha_2) - \theta(\alpha_I)$ denotes the delay between the date $\theta(\alpha_I)$ of the event α_I and the date $\theta(\alpha_2)$ of the event α_2 . Adding a prediction function at each state of each CPE_i leads to a new automaton called Temporized Controlled Plant Element TCPE_i with $i \in \{1, 2 \dots n\}$.

For the Controlled Plant Element of the cylinder 2 CPE_{cy2}, it is possible to establish all prediction function for each state. The resulting automaton is called Temporized Controlled Plant Element for the cylinder 2 (TCPE_{cy2}) (Fig. 8). To understand this automaton, let take as example the state x_3 with the prediction function $PF_{x3} = PF(\downarrow p2ar, \uparrow ct2) = \{\downarrow p2ar, x_3, (\uparrow ct2, [5s, 15s], x_4, F4)\}$. This function indicates that after the passage of the sensor $p2ar$ to 0, the sensor $ct2$ must be equal to 1 after a delay belonging to the interval $[5s, 15s]$ in order to reach the state x_4 . If the prediction function is not satisfied, a label F4 is returned to the user to indicate a fault. The other Temporized Controlled Plant Element can be obtained by the same manner (Philippot, 2006).

Fig. 7. Representation of a prediction function

Fig. 8. Temporized Controlled Plant Element TCPE_{cy2} of the cylinder 2

3.4 Local diagnosers

A local diagnoser D_i is constructed and based on each Temporized Controlled Plant Element (TCPE_{*i*}). This local diagnoser carries fault information by labels attached to states. These labels indicate the types of faults that have been occurred. Each local diagnoser is considered as a Moore automaton: $D_i = (X_i \cup X_{DFi}, \Sigma_i, \delta_i, x_{i0}, V_i, h_i, PF_i, l_i)$ where:

- X_i is the set of normal states of TCPE_{*i*},
- X_{DFi} is the set of faulty states
- Σ_{i0} is the set of observable events by PE_{*i*},
- $\delta_i: X_i \times \Sigma_i^* \rightarrow X_i \cup X_{DFi}$ is the transition function,
- x_{i0} is the initial state,
- V_i is an input/output vector with $V_i(x)$ the vector of the state x ,
- $h_i: X_i \cup X_{DFi} \rightarrow \Sigma_{i0}$ is the output function where $h_i(x)$ is the observable event at the output of the state x ,
- $PF_i = \{PF_x, \forall x \in X_i\}$ represents the set of prediction functions of a state x ,
- l_i is the set of decision functions of the local diagnoser D_i with $l_i(x)$ the decision function of the state x which can be one or more fault labels $\{F_j\}$.

The local diagnoser uses a state-based model characterized by the input/output vector in each state. The dimension of this vector corresponds to the number of observable events of the local diagnoser D_i . In the state-based model, a fault is considered as the consequence of reaching at some faulty states. Thus, it does not require to be initiated at the same time with the plant model.

For the local decision, if the label function at a state x is $l_i(x) = \{N\}$, then the diagnoser, when it reaches the state x , can decide with certainty the non presence of faults. If the label function at a state x is $l_i(x) = \{F_j\}$, then the diagnoser indicates with certainty the occurrence of a fault of the type F_j . If $l_i(x)$ contains the label N and any other fault label then the diagnoser, at a state x , cannot decide whether a fault has occurred or the system is in normal function, i.e., ambiguity or indecision case. To define the different labels, we have defined subsets of failures, each one is called fault partition. Then, each fault partition Π_{Fj} is associated with a label Fj indicating the type of failures. We have considered two kinds of faults (Table 1): sensor's faults and actuator's faults. Failures can be modelled as observable or/and unobservable events.

Table 1 Possible faults on a Plant Element

observable sensor fault	Unexpected passage of the sensor value from 0 to 1
	Unexpected passage of the sensor value from 1 to 0
non observable sensor fault	Sensor stuck-off
	Sensor stuck-on
non observable actuator fault	Actuator stuck-off
	Actuator stuck-on

Table 2 Possible faults on the cylinder 2

F1	f_1	Unexpected passage of $p2ar$ from 0 to 1
	f_2	Sensor $p2ar$ stuck-off
	f_3	Unexpected passage of $p2ar$ from 1 to 0
	f_4	Sensor $p2ar$ stuck-on
F2	f_5	Unexpected passage of $ct2$ from 0 to 1
	f_6	Sensor $ct2$ stuck-off
	f_7	Unexpected passage of $ct2$ from 1 to 0
	f_8	Sensor $ct2$ stuck-on
F3	f_9	Cylinder 2 stuck-off
	f_{10}	Cylinder 2 stuck-on

The case of observable events is a trivial one since failures can be detected as soon as they are. In the case of unobservable events, the occurrence of a failure must be inferred from the system model and future observations.

From each PE_{*i*}, we can describe the set of diagnosable faults of the process and define all the fault partitions. Each faulty state of the local diagnoser is obtained by an analysis of all possible faults than can be occurred from a normal state. From a normal state, it is possible to reach a faulty state: (i) for each unexpected passage of a sensor value, (ii) for a non observable fault of a sensor stuck or (iii) for a non observable fault of an actuator stuck (Philippot, 2006). From this, the outputs transitions from a normal to an abnormal state are represented by an event f_i which belongs to a fault partition of the local diagnoser. The faults partitions for the cylinder 2 are defined in Table 2.

The local diagnoser D_{cy2} for the cylinder 2, is established based on TCPE_{*cy2*} and the set of all faults which can be detected from each normal state. This diagnoser is an automaton of 24 states (8 normal states, 8 faulty states reached due to the occurrence of non observable faults and 8 faulty states reached due to the occurrence of observable faults).

Observable faults are directly diagnosed by an "Exclusive OR" operator between the input/output vector $V_i(x)$ of the current faulty state and the estimated one (Philippot, 2006). If a non-expected event is generated, as an example the occurrence of $\uparrow ct2$ when the cylinder 2 is state x_1 , then the current state has an input/output vector $V_{cy2}(x_{13}) = (p2ar, ct2, Out2, In2) = (1100)$ whereas the one of the estimated state, x_2 , is $V_{cy2}(x_2) = (1010)$. The comparison of this two vectors by an "Exclusive OR" operator allows detecting and isolating the observable failure in the sensor $ct2$: $V_{cy2}(x_{13}) \oplus V_{cy2}(x_2) = (0110)$. Indeed the value one in the resulting comparison is not equal to 0 and indicates a faulty element. The localisation of this faulty element is given by the last observable event.

Since the diagnosis of observable faults is trivial, the local diagnoser is simplified to take into account only the non observable faults. The local diagnoser D_{cy2} of the cylinder 2 is presented in figure 9 (Philippot, 2006).

Fig. 9. Simplified diagnoser D_{cy2} for the cylinder 2

3.5 Global decision

Each local diagnoser D_i provides a Local diagnosis Decision LD_i corresponding to the label function l_x at the current state x of D_i . Then, all local diagnosis decisions are merged in order to obtain one Global diagnosis Decision (GD). This fusion is realized using an unconditional structure and based on a Boolean operator “Union”. If one local diagnoser announces a fault, then the global diagnosis decision will be this local decision. For the example of the figure 2, if the local diagnosis decisions of the conveyor 1 is (LD_{C1}), the cylinders 1 is (LD_{cy1}), the cylinder 2 is (LD_{cy2}) and the cylinder 3 is (LD_{cy3}), then the global decision is obtained by: $GD = LD_{C1} \cup LD_{cy1} \cup LD_{cy2} \cup LD_{cy3}$.

4. CONCLUSIONS

In this paper, a decentralized approach is proposed to diagnose manufacturing systems. This approach is based on several local diagnosers to detect and isolate the occurrence of each failure violating the system desired behaviour. This approach exploits all available information sources in order to construct a depth model of the system (plant, control, and actuator's minimal and maximal response times). The local diagnosers are obtained by adding the faulty states, reached due to the occurrence of a failure. They are no need of communication between local diagnosers because this approach uses event-based, state based and timed models to take a decision about fault's occurrences. Consequently, there is no propagation of local faults. Each diagnoser detects faults with earliest to send it local decision which will be merged with the others for a global decision.

To determine if the system can be diagnosed according to its observable events and for the set of defined failures, which can be observable or non observable, an adapted codiagnosability notion has been defined in (Philippot, 2006). This is a timed-event-based codiagnosability notion. In this work, a simulation tool based on *Stateflow* of Matlab® has been constructed to test and validate the proposed approach.

One drawback of the approach is the fact that only the equipments, actuators and sensors, faults are

diagnosed and not the ones due to the parts on the conveyors. To solve this drawback, a solution is to construct a model representing the parts normal and faulty behaviours by using Colored Petri Nets. CPN use the colour in generics models. Consequently, it is not necessary to make a model for each part to follow-up. Another drawback is that this approach was not tested on real applications. One solution is to develop the simulation tool to be applied for the on-line implementation as an OPC (OLE for Process Control) client. Consequently, a connexion to an OPC server from Matlab® allows reaching the Programmable Logic Controller (PLC) variables.

REFERENCES

- Balemi, S., G.J. Hoffmann, P. Gyugyi, H. Wong-Toi, G.F. Franklin (1993). Supervisory control of a rapid thermal multiprocessor. In: *IEEE Transactions on Automatic Control*, Vol. 38, n°7, pp.1040-105.
- Boufaïed, A. (2003). Contribution à la Surveillance Distribuée Des Systèmes à Événements Discrets Complexes. In: *Thesis of PhD, Université Paul Sabatier*, Toulouse.
- Cassandras, C.G., S. Lafortune (1999). Introduction to Discrete Event Systems. In: *Kluwer Academic*, Publisher.
- Darkhovski, B., M. Staroswiecki (2003). A Game-Theoretic Approach to Decision in FDI. In: *IEEE Transactions On Automatic Control*, Vol.48, n°5.
- Debouk, R., S. Lafortune, D. Teneketzis (2000). Coordinated decentralized protocols for failure diagnosis of discrete event systems. In: *Discrete Event Dynamic Systems: Theory and Applications*, Vol. 10, n°1-2, pp.33-86.
- Genc, S., S. Lafortune (2003). Distributed diagnosis of discrete-event systems using Petri nets. In: *International Conference on Application and Theory of Petri Nets*, pp.316-336, Eindhoven, The Netherlands.
- Klein, S., L. Litz, J.J. Lesage (2005). Fault Detection of Discrete Event Systems Using an Identification Approach. In: *16th IFAC World Congress*, CDROM paper n°02643, Praha (CZ).
- Pandalai, D., L.E.N. Holloway (2000). Template Languages for Fault Monitoring of Timed Discrete Event Processes. In: *IEEE Transactions On Automatic Control*, Vol. 45, n°5.
- Philippot, A. (2006). Contribution au diagnostic décentralisé des Systèmes à Événements Discrets : Application aux systèmes manufacturiers. In: *Thesis of PhD, Université de Reims Champagne Ardenne*.
- Wang, Y. T. Yoo, S. Lafortune (2004). New results on decentralized diagnosis of Discrete Event Systems. *Allerton Conferences Urbana-champaign*, IL, USA.