Dynamic business continuity assessment using condition monitoring data

Jinduo Xing, Zhiguo Zeng, Enrico Zio

► To cite this version:

Jinduo Xing, Zhiguo Zeng, Enrico Zio. Dynamic business continuity assessment using condition monitoring data. International Journal of Disaster Risk Reduction, 2019, 41, pp.101334. 10.1016/j.ijdr.2019.101334 . hal-02428516

HAL Id: hal-02428516

<https://hal.science/hal-02428516>

Submitted on 13 Jan 2020

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Dynamic business continuity assessment using condition monitoring data

Jinduo Xing¹, Zhiguo Zeng¹, Enrico Zio^{2,3,4}

¹ Chair System Science and the Energy Challenge, Fondation Electricité de France (EDF), CentraleSupélec,
Université Paris Saclay, Gif-sur-Yvette, France

² MINES ParisTech, PSL Research University, CRC, Sophia Antipolis, France

³ Energy Department, Politecnico di Milano, Milan, Italy

⁴ Eminent Scholar, Department of Nuclear Engineering, College of Engineering, Kyung Hee University,
Republic of Korea

jinduo.xing@centralesupelec.fr, zhiguo.zeng@centralesupelec.fr, enrico.zio@polimi.it

Abstract

Concerns on the impacts of disruptive events of various nature on business operations have increased significantly during the past decades. In this respect, business continuity management (BCM) has been proposed as a comprehensive and proactive framework to prevent the disruptive events from impacting the business operations and reduce their potential damages. Most existing business continuity assessment (BCA) models that numerically quantify the business continuity are time-static, in the sense that the analysis done before operation is not updated to consider the aging and degradation of components and systems which influence their vulnerability and resistance to disruptive events. On the other hand, condition monitoring is more and more adopted in industry to maintain under control the state of components and systems. On this basis, in this work, a dynamic and quantitative method is proposed to integrate in BCA the information on the conditions of components and systems. Specifically, a particle filtering-based method is developed to integrate condition monitoring data on the safety barriers installed for system protection, to predict their reliability as their condition changes due to aging. An installment model and a stochastic price model are also employed to quantify the time-dependent revenues and tolerable losses from operating the system. A simulation model is developed to evaluate dynamic business continuity metrics originally introduced. A case study regarding a nuclear power plant (NPP) risk scenario is worked out to demonstrate the applicability of the proposed approach.

Keywords

Business continuity management (BCM), Dynamic business continuity assessment (DBCA), Condition monitoring, Prognostic and health management (PHM), Particle filtering (PF), Event tree (ET)

29 **Acronyms**

30	BCA	business continuity assessment
31	BCM	business continuity management
32	BCV	business continuity value
33	DBC	dynamic business continuity
34	DBCA	dynamic business continuity assessment
35	DRA	dynamic risk assessment
36	ET	event tree
37	MBCO	minimum business continuity objective
38	MTPD	maximum tolerable period of disruption
39	NPP	nuclear power plant
40	PDF	probability density function
41	PF	particle filtering
42	PRA	probabilistic risk assessment
43	RCS	reactor coolant system
44	RTO	recovery time objective
45	RUL	remaining useful life
46	SGTR	steam generator tube rupture

47 **Notation**

48	a	Crack size
49	$BCV([t, t + T])$	Business continuity value at t with reference to a time horizon T
50	C_o	Operation cost
51	C_p	Repayment cost
52	C_{s1}	First consequence
53	C_{s2}	Second consequence
54	D_p	Down payment
55	$EDBCV$	Expected value of dynamic business continuity at time t
56	$f(\cdot)$	State function

57	$f_{ET}(\cdot)$	Event tree model
58	$h(\cdot)$	Observation function
59	IN_{tol}	Total investment
60	L_d	Direct loss
61	L_{in}	Indirect loss
62	L_{tol}	Tolerable loss
63	N_s	Sample size of PF
64	N_p	Repayment period
65	$P_{BF}([t, t+T])$	Probability of business failure in $[t, t+T]$
66	$P_{BI}([t, t+T])$	Probability of business interruption in $[t, t+T]$
67	P_{ID}	Indirect loss per unit of time
68	q	Time length of condition monitoring
69	Q_0	Initial funding
70	t_{recv}	Recovery time
71	T	Time length of BC estimation
72	$\omega_k^{(i)}$	Weight of particle i
73	ψ	Indicator function
74	ρ	Interest rate
75	δ_k	Observation noise at $t = t_k$
76	λ_{st}	Intensity of rupture event (for static business continuity)
77	ΔK	Stress intensity factor
78	$\Delta\sigma$	Stress range
79		

1. Introduction

Business organizations are faced with threats from various disruptive events, such as natural disasters [1, 2], intentional attacks [3] and hardware failures [4], etc. As reported in [5, 6], 43% of the companies that have suffered from severe disruptive events have been permanently closed. Among these companies, around 30% failed within two years. Being prepared for disruptive events, including prevention in pre-event phase and response in post-event phase, is, then, important for modern businesses [7]. This is the reason why business continuity management (BCM) has received increasing attention in recent years as a holistic risk management method to cope with disruptive events [8-12]. BCM is formally defined in [13] as “holistic management process that identifies the potential threats to an organization and the potential impacts they may cause to business operations those threats, if realized, might cause, and which provides a framework for building organizational resilience with the capability of an effective response that safeguards the interest of its key stakeholders reputation, brand and value-creating activities”. Compared to conventional risk analysis method, BCM not only focuses on the potential hazards and their impacts, but also considers how to mitigate the consequence and quickly recover from the disruption. Therefore, it provides a framework for building organizational resilience that safeguards the interests of the business stakeholders.

Most existing works mainly discuss BCM from a management perspective [14]. For instance, the necessity and benefit of implementing BCM in a supply chain has been discussed in qualitative terms in [11]. In [15], a framework for the design, implementation and monitoring of BCM programs has been proposed. In [16], the evolution of BCM related to crisis management has been reviewed, in terms of practices and drivers of BCM. In [17], BCM has been compared with conventional risk management methods, showing that BCM considers not only the protection of the system against the disruptive event, but also the recovery process during and after the accident. The importance of reliability and simulation in BCM has been discussed in [18]. In [19], a framework for information system continuity management has been introduced. Standards concerning BCM of the Brazilian gas supply chain have been discussed in [20]. A practice on BCM in Thailand has been reviewed and a few suggestions on BCM approaches have been presented in [21]. In [22], the conceptual foundation of BCM has been presented in the context of societal safety.

From an engineering point of view, it is needed to define numerical indexes that support quantitative business continuity assessment (BCA). A few numerical indexes have been defined in [13], e.g., maximum tolerable period of disruption (MTPD), minimum business continuity objective (MBCO) and recovery time objective (RTO). However, these numerical indexes are usually directly estimated based on expert judgements. Only a few attempts exist concerning developing quantitative models to evaluate these numerical indexes. For example, a statistical model

integrating Cox’s model and Bayesian networks has been proposed to model the business continuity process [23]. In [24], a simulation model has been developed to analyze the business continuity of a company considering an outbreak of pandemic disease, where the business continuity is characterized by the operation rate and the plant-utilization rate. In [5], an integrated business continuity and disaster recovery planning framework has been presented and a multi-objective mixed integer linear programming has been used to find efficient resource allocation patterns. In [9], BCM outsourcing and insuring strategies have been compared based on the organization characteristics and the relevant data through a two-step, fuzzy cost-benefit analysis. Moreover, in [10], an enhanced risk assessment framework equipped with analytical techniques for BCM systems has been proposed. Two probabilistic programming models have been developed to determine appropriate business continuity plans, given epistemic uncertainty of input data in [25]. In [26], a new model for integrated business continuity and disaster recovery planning has been presented, considering multiple disruptive incidents that might occur simultaneously. An integrated framework has been developed in [12] for quantitative business continuity analysis, where four numerical metrics have been proposed to quantify the business continuity level based on the potential losses caused by the disruptive events.

Most quantitative BCA models mentioned above are time-static in the sense that the analysis is performed before the system of interest comes into operation, with no further consideration of the changes that occur due to aging and degradation. In particular, in practice, business continuity is influenced by the degradation of safety barriers. On the other hand, the advancing of sensor technologies and computing resources has made it possible to retrieve information on the state of components and systems, by collecting and elaborating condition monitoring data [27, 28]. For example, a condition-based fault tree has been used for dynamic risk assessment (DRA) [29], where the condition monitoring data are used to update the failure rates of specific components and predict their reliability. In [30], a Bayesian reliability updating method has been developed for dependent components by using condition monitoring data. In [4], a holistic framework that integrates the condition monitoring data and statistical data has been proposed for DRA. A sequential Bayesian approach has been developed in [31], for dynamic reliability assessment and remaining useful life prediction for dependent competing failure processes. Usually, information fusion can add values for decision support [32]. A quantitative model for information risks in supply chain has been developed where the proposed model can be updated when new data are available [33].

In this paper, we propose a framework for DBCA that integrates condition monitoring data and allows updating the business continuity analysis using information collected during system operation. It should be noted that in this paper, we focus on “business continuity assessment” rather than “business continuity management”. That is, we are

concerning developing quantitative models to evaluate the numerical business continuity metrics, which are further used in BCM process as quantitative requirements. The developed model contributes to the existing research on BCA in three aspects:

- 1) An integrated DBCA model is proposed, which can provide for BCA updating in time.
- 2) New dynamic business continuity metrics are introduced.
- 3) A simulation-based algorithm is developed to calculate the dynamic business continuity metrics.

The remainder of this paper is organized as follows. In Section 2, numerical metrics for DBCA are proposed. An integrated framework of DBCA is developed in Section 3. Section 4 describes the application of the proposed framework on a nuclear power plant (NPP) accident. Section 5 discusses applicability of the proposed DBCA method. Eventually, Section 6 concludes this work.

2. Numerical metrics for dynamic business continuity assessment

Business process is the process of producing products or supporting services by an organization. The business process of an organization can be characterized by a performance indicator, whose value reflects the degree to which the objective of the business is satisfied. For instance, for a NPP, this indicator can be monthly electricity production. As reviewed in Section 1, there are a few numerical indexes for quantifying the continuity of a business process (MTPD, MBCO, RTO, etc.) [13]. These numerical indexes, however, focus only on one specific phase of the whole process. For example, RTO focuses only on the post-disruption recovery phase., MBCO focuses only on the post-disruption contingency activities. In this paper, we use the numerical business continuity indexes developed in [12], which are defined in a more integrated sense that they are able to cover the whole process, from pre-disruption preventions to post-disruption contingency and recovery.

In the quantitative framework developed in [12], the business continuity is quantified based on the potential losses caused by the disruptive events. The business process is divided into four sequential stages: preventive stage, mitigation stage, emergency stage and recovery stage. Various safety measures are designed in different stages to guarantee the continuity of the business process. Business continuity value (BCV) was formally defined as [12]:

$$BCV([0, T]) = 1 - \frac{L([0, T])}{L_{tol}} \quad (1)$$

where L denotes the loss in $[0, T]$ from the disruptive event; T is the evaluation horizon for the assessment (e.g., the lifetime of the system); L_{tol} is the maximum loss that can be tolerated by an organization, which manifests

165 system tolerance ability against disruptive event [34]. Negative value of BCV means that L is higher than L_{tol} ,
 166 which is unacceptable for the targeted system. When $BCV = 0$, it implies that the loss is exactly what the system
 167 can maximally tolerate. Regarding $BCV = 1$, it means no loss has been generated. Equation (1) measures the
 168 relative distance to a financially dangerous state by taking into account the possible losses generated by the business
 169 disruption. It should be noted that only one business process is considered in this paper, while in practice, an
 170 organization might be involved in multiple business processes at the same time. For multiple-business system, the
 171 developed framework can be naturally extended based on the potential losses and profit generated by the different
 172 business processes together.

173 The business continuity metrics discussed above are time-static in nature. In practice, however, various factors
 174 influencing the business continuity are time-dependent. These dynamic influencing factors can be grouped into
 175 internal factors and external factors. Internal factors are related to the safety barriers within the system of interest,
 176 such as the dynamic failure behavior of the safety barriers (e.g., corrosion [35], fatigue crack [36], and wear [37]).
 177 External factors refer to the influence from external environment. For example, variations in the price of products
 178 will affect the accumulated revenue of the organization, and, then, the tolerable loss in Equation (1). To consider
 179 these factors, the business continuity metrics are extended to the dynamic cases:

$$180 \quad DBCV([t, t+T]) = 1 - \frac{L([t, T+t])}{L_{tol}(t)}, \quad (2)$$

181 where t is the time instant when the dynamic business continuity assessment is carried out; $DBCV([t, t+T])$
 182 represents the business continuity value evaluated at time t , for a given evaluation horizon of T ; $L([t, t+T])$
 183 represents the potential losses in $[t, t+T]$; $L_{tol}(t)$ denotes the maximal amount of losses that the company can
 184 tolerate at t : beyond that level of losses, it will have difficulties in recovering. It is assumed that once an
 185 organization suffer a loss beyond L_{tol} , it is unable to recover from the disruption due to the financial critical
 186 situations. The physical meaning of DBCV is the relative distance to a financial dangerous state at time t , by
 187 considering the possible losses in $[t, t+T]$ due to business disruption; it measures the dynamic behavior of
 188 business continuity in a time interval of interest $[t, t+T]$. By calculating the DBCV at different t , the dynamic
 189 behavior of business continuity can be investigated.

190 In [12], two kinds of losses need to be considered when calculating $L([t, t+T])$: direct loss and indirect loss
 191 Direct loss, denoted by $L_d([t, t+T])$, represents the losses that are caused directly by the disruptive event, including

structural damage of the system. For example, in a NPP leakage event, $L_d[t, t+T]$ includes all equipment damage directly caused by the event. Indirect loss, denoted by $L_{in}([t, t+T])$, is the revenue loss suffered during the shutdown of the plant [38]. Hence, the total loss is calculated by:

$$L([t, T+T]) = L_d([t, t+T]) + L_{in}([t, t+T]). \quad (3)$$

In terms of other types of accident, for instance, workplace accidents, damages to the surroundings, etc. they may also affect the business continuity. Due to page limits, we did not include them in the developed model in this paper. However, the developed method can be naturally generalized by including more initiating events in the analysis.

The DBCV defined in (2) is a random variable. Three numerical metrics are, then, proposed for its quantification:

$$EDBCV = E[DBC] \quad (4)$$

$$P_{BI}([t, t+T]) = \Pr(BCV < 1, t) \quad (5)$$

$$P_{BF}([t, t+T]) = \Pr(BCV < 0, t) \quad (6)$$

$EDBCV$ is the expected value of the dynamic business continuity value. A higher $EDBCV$ indicates higher business continuity. $P_{BI}([t, t+T])$ represents the probability that at least one disruptive event causes business interruption in time interval $[t, t+T]$; $P_{BF}([t, t+T])$ is the probability that business failure occurs in $[t, t+T]$, i.e., of the event that the losses caused by the disruptive event are beyond L_{tol} . It is assumed that once an organization suffers a loss beyond L_{tol} , it is unable to recover from the disruption due to the financial critical situations. In this work, both of current time t and the estimation horizon T have influences on BCV. We manage to propose a real-time BCA by considering the time-dependent variables.

3. An integrated framework for dynamic business continuity assessment

In this section, we first present an integrated modeling framework for the dynamic business continuity metrics defined in Section 2. Then, particle filtering (PF) is used to estimate the potential loss L_{tol} in real time using condition monitoring data (Section 3.2). The quantification of tolerable losses L_{tol} is, then, discussed in Section 3.3.

3.1 The integrated modeling framework

To model the dynamic business continuity, we make the following assumptions:

- 1) The evolution of the disruptive event is modeled by an event tree (ET). Depending on the states of safety barriers, different consequences can be generated from an initialing event. These consequences can be

grouped into different categories based on their severities. Each consequence generates a certain amount of loss. However, it should be noted that different consequences might have the same degree of losses. According to their severities, possible consequences of a disruptive event are classified as $C_i, i = 1, 2, \dots, n$, where n is the number of severity level. The severity and duration of the business interruption corresponds to different losses.

- 2) Some safety barriers in the ET are subject to degradation failure processes. Condition monitoring data are available for these safety barriers at predefined time instants $t_k, k = 1, 2, \dots, q$.
- 3) The other safety barriers have constant failure probabilities.
- 4) Recovery means repairing the failed component and restarting the business. The time for the recovery from consequence C_i is a random variable $t_{recv,i}$, with a probability density function (PDF) $f_{recv,i}$.

An integrated framework for DBCA is presented in Figure 1. The DBCA starts from collecting condition monitoring data, denoted as c_k , which is collected from sensors and can be used to characterize the degradation states of the component. The degradation of the safety barriers is estimated based on the condition monitoring data and used to update the estimated losses. Then, the potential profits are predicted and used to calculate the tolerable losses. Finally, the dynamic business continuity metrics can be calculated.

Figure 1. Integrated modeling framework for DBCA.

3.2 Loss modeling

To capture the dynamic failure behavior of a safety barrier as it ages in time, PF is employed in this work to estimate its degradation and predict its remaining useful life (RUL) based on condition monitoring data [39-41]. PF

is applied because of its capability of dealing with the complex non-linear dynamics and non-Gaussian noises that are often encountered in practice [42, 43].

Suppose the degradation process of a safety barrier can be described by Equation (7), in which the current state x_k at the k -th discrete time step depends on the previous state x_{k-1} . Here, f is a non-linear function and v_k represents process noise that follows a known distribution. In practice, Equation (7) is often determined based on physics-of-failure models [39]:

$$\mathbf{x}_k = f(\mathbf{x}_{k-1}, v_k) \quad (7)$$

A sequence of condition monitoring data $\mathbf{z}_k$ is assumed to be collected at predefined time points t_k . The sequence of measurement values is assumed to be described by an observation function:

$$\mathbf{z}_k = h(\mathbf{x}_k, \boldsymbol{\sigma}_k) \quad (8)$$

where h is the observation function (possibly nonlinear), $\boldsymbol{\sigma}_k$ is the observation noise vector sequence of known distribution. The measurement data $\mathbf{z}_k$ are assumed to be conditionally independent given the state process $\mathbf{x}_k$. Equation (8) quantifies the observation noise from the sensors.

The PF follows two steps [44]:

- 1) Filtering step, where the available condition monitoring data $\mathbf{z}_k$ are used to estimate the current degradation state of the system.
- 2) Prediction step, in which the RUL is predicted based on the estimated degradation state and the condition monitoring data.

In the filtering step, the posterior PDF of variable $\mathbf{x}_k$ is approximated by the sum of weighted particles

$$\{\mathbf{x}_k^{(i)}, \omega_k^{(i)}\}:$$

$$p(\mathbf{x}_k | z_1, z_2, \dots, z_k) \approx \sum_{i=1}^{N_s} \omega_k^{(i)} \delta(\mathbf{x}_k - \mathbf{x}_k^{(i)}) \quad (9)$$

where $p(\mathbf{x}_k | z_1, z_2, \dots, z_k)$ is the estimated posterior PDF of $\mathbf{x}_k$, δ is the Dirac Delta function, $\omega_k^{(i)}$ is the weight assigned to particle $\mathbf{x}_k^{(i)}$ and is generated by sequential importance sampling [32]. When the new measurement z_k is available, the required posterior distribution of the current state x_k can be obtained by updating the prior distribution:

$$p(\mathbf{x}_k | \mathbf{z}_k) = \frac{p(z_k | \mathbf{x}_k) p(\mathbf{x}_k | \mathbf{z}_{k-1})}{\int p(z_k | \mathbf{x}_k) p(\mathbf{x}_k | \mathbf{z}_{k-1}) d\mathbf{x}_k} \quad (10)$$

where $p(z_k | \mathbf{x}_k)$ is the likelihood function that can be derived from the observation function (8). Generally, if the samples $\mathbf{x}_k^{(i)}$ are drawn from the sampling distribution $p(\mathbf{x}_k | \mathbf{z}_k)$, then, the particle weight can be updated with a new observation z_k , as follows [32]:

$$\omega_k^{(i)} = \omega_{k-1}^{(i)} \frac{p(z_k | \mathbf{x}_k^{(i)}) p(\mathbf{x}_k^{(i)} | \mathbf{x}_{k-1}^{(i)})}{p(\mathbf{x}_k^{(i)} | \mathbf{x}_{0:k-1}^{(i)}, \mathbf{z}_k)}. \quad (11)$$

Note that the weights are normalized as $\sum_{i=1}^{N_s} \omega_k^{(i)} = 1$.

Algorithm 1 summarizes the major steps of PF [45].

Algorithm 1: Procedures of PF.

Inputs: $\{\mathbf{x}_{k-1}^{(i)}, \omega_{k-1}^{(i)}, \mathbf{z}_k\}$

Outputs: $\{\mathbf{x}_k^{(i)}, \omega_k^{(i)}\}_{i=1}^{N_s}$

For $i = 1$ to N_s do

$\mathbf{x}_k^{(i)} \sim p(\mathbf{x}_k | \xi_{k-1}^{(i)})$ using (7),

$\omega_k^{(i)} \propto p(z_k | \mathbf{x}_k^{(i)}, \theta_k^{(i)})$ using (11),

End for

For $i = 1$ to N_s do

$\omega_k^{(i)} \leftarrow \omega_k^{(i)} / \sum_{i=1}^{N_s} \omega_k^{(i)}$

End for

$N_{eff} \leftarrow \left(\sum_{i=1}^{N_s} (\omega_k^{(i)})^2 \right)^{-1}$

If $N_{eff} < N_s$ then

$\{\mathbf{x}_k^{(i)}, \omega_k^{(i)}\}_{i=1}^{N_s} \leftarrow \text{resample} \left(\{\mathbf{x}_k^{(i)}, \omega_k^{(i)}\}_{i=1}^{N_s} \right)$

End if

Return $\{\mathbf{x}_k^{(i)}, \omega_k^{(i)}\}_{i=1}^{N_s}$

Then, in the prediction step, the RUL associated to the i -th particle at $t = t_k$ can be estimated through state function (7) by simulating the evolution trajectory of the particles until they reach the failure threshold z_{th} :

$$RUL_k^{(i)} = \left\{ (T_{th}^{(i)} - 1 - k) \mid x_{T_{th}^{(i)}-1}^{(i)} < z_{th}, x_{T_{th}^{(i)}}^{(i)} \geq z_{th} \right\}, \quad (12)$$

273 where $T_{th}^{(i)}$ is the first time the particle reaches the threshold z_{th} . Thus, the PDF of the RUL can be generated by:

$$274 \quad p(RUL|\mathbf{z}_k, z_{th}) \approx \sum_{i=1}^{N_s} \omega_k^{(i)} \delta(RUL - RUL_k^{(i)}). \quad (13)$$

275 The predicted $RUL_k^{(i)}, i=1, 2, \dots, N_s$ can, then, be used in a simulation process to generate samples of the total
 276 loss L , according to Equation (3). The procedures are summarized in Algorithm 2, where P_{ID} is the indirect loss
 277 per unit of time.

Algorithm 2: Generating samples for the losses

Input: $\{RUL_k^{(i)}, \omega_k^{(i)}\}_{i=1}^{N_s}, T$

Output: $L_k^{(i)}$

Initial value $L_k^{(i)} = 0, t = 0, t_1 = 0, T = t_k + T, t_2 = 0;$

$RUL_{pseudo,k} \leftarrow$ randomly select one element from $\{RUL_k^{(i)}\}_{k=1}^{N_p}$, where $RUL_k^{(i)}$ is selected with probability $\omega_k^{(i)}$;

Calculate $T_k^{(i)} = t_k + RUL_{pseudo,k}$

► While $t < T$

$t_1 = t; t_1 = t_1 + TTF_k^{(i)};$

► if $t_1 > T$

$L_k^{(i)} = L_k^{(i)}$

else

Using the event tree determine the consequence;

Using the $f_{recv,i}$ generate the t_{recv} ;

$t_2 = t_1 + t_{recv};$

► If $t_2 > T$

$L_k^{(i)} = L_k^{(i)} + L_d + (T - t_2) \cdot P_{ID}$

else $t = t_2$

$L_k^{(i)} = L_k^{(i)} + L_d + t_{recv} \cdot P_{ID}$

► end if

► end if

► end while

278

279 3.3 Tolerable losses modeling

280 Budget limitations are the primary driver of resilience-enhancing investments [46], which influence protection,
 281 prevention, and recovery capabilities of system. Tolerable losses L_{tol} depend on the cash flow of the company and
 282 also the risk appetite of the decision maker [13]. In this paper, we assume that at t_k , the organization can tolerate
 283 up to α (in percentage) of its cash flow $Q(t_k)$ at t_k :

$$284 \quad L_{tol}(t_k) = Q(t_k) \cdot \alpha \quad (14)$$

For example, $\alpha = 0.1$ means 10% of the current cash flow can be used to withstand potential losses caused by a disruptive event. In practice, the value of α should be determined by the decision maker and reflects his/her risk appetite.

We make the following assumptions to model the dynamic behavior of cash flows:

- (1) At $t = 0$, there is an initial capital of Q_0 .
- (2) Installment is used for the company to purchase the asset, where an equal repayment of C_p is paid each month for N_p months.

It is noteworthy that the cash flow $Q(t)$ depends on the profit earned by the normal operation of the asset:

$$Q(t_k) = Q_0 + I(t_k) - C_o(t_k) - \sum_{i=1}^k (\Psi \cdot C_p(t_i)), \quad (15)$$

where Q_0 is the initial capital, $I(t_k)$ is the accumulated revenues of the organizations up to t_k by selling the product of the asset. For example, in a NPP, $I(t_k)$ is determined by the electricity price; in oil exploitation, $I(t_k)$ depends on the petroleum price [47]. $C_o(t_k)$ is the operational cost in $[0, t_k]$, which is assumed to be not changing over time. $C_p(t_i)$ is the amount of repayment of the installment in $[t_{i-1}, t_i]$, which can be modeled by (see [48] for details):

$$C_p = \frac{(IN_{\text{tol}} - D_p)}{N_p} (1 + \rho)^{N_p}, \quad (16)$$

where IN_{tol} denotes the total investment and equals the whole value of the system, D_p represents the down payment, ρ is the interest rate, Ψ is an indicator function:

$$\Psi = \begin{cases} 1, & \text{if } t \leq N_p \\ 0, & \text{otherwise} \end{cases}, \quad (17)$$

where N_p is the repayment period.

4. Application

In this section, we consider the development of DBCA in a case study regarding a disruptive initialing event for a NPP [49]. The business continuity of the NPP is evaluated at different ages $t = 1, 2, \dots, 40$ (year) and different evaluation horizons $T = 1, 2, \dots, 60$ (year). The evaluation is made with reference to a specific risk scenario, with the initialing event being the steam generator tube rupture (SGTR).

309 The targeted system is briefly introduced in Section 4.1. Subsequently, in Section 4.2, the RUL prediction for a
 310 SGTR and the modeling of the potential losses are conducted. The time-dependent L_{tol} is calculated in Section 4.3.
 311 The results of the DBCA are presented and discussed in Section 4.4.

312 4.1 System description

313 For illustrative purposes, it is assumed that the NPP has one reactor with a capacity of 550 MW. It is also
 314 assumed that the NPP is subject to the threat of only one disruptive event, the SGTR. The whole value of the NPP is
 315 10^9 € and the operator purchases the NPP using an installment, where the down payment is $5 \cdot 10^8$ € and the
 316 repayment period is 10 years with an interest rate of 2%.

317 SGTR is a potential accident that is induced by the degradation of the tubes in the steam generator, which can
 318 lead to tube cracking and rupture [50]. Steam generator tubes transfer the heat from the reactor core to the cooling
 319 water that is transformed into steam to drive turbines and produce electricity [49]. The steam generator tube is often
 320 manufactured with alloy material to attain high structural integrity and prevent leakage of radioactive materials. An
 321 ET has been developed for the probabilistic risk assessment (PRA) of the SGTR for a NPP in South Korea, as shown
 322 in Figure 2. In Figure 2, eight safety barriers ($SB_1 \square SB_8$) are designed to control the accident and mitigate its impact
 323 (Table 1). Depending on the states of the safety barriers, 28 sequences are generated ($S_1 \square S_{28}$). Based on the degree
 324 of their severities, the consequence of the sequences can be categorized into two groups. The first group,

$$325 C_{S1} = \{SE_1, SE_2, SE_4, SE_6, SE_7, SE_9, SE_{11}, SE_{12}, SE_{14}, SE_{16}, SE_{20}, SE_{24}\} \quad (18)$$

326 represents the event sequences in which a SGTR occurs but the consequence is contained by the safety barriers
 327 without causing severe damages. The remaining event sequences form the second group C_{S2} and represent severe
 328 consequences of core damage. Regarding C_{S1} , albeit no severe losses are caused, normal production of the NPP is
 329 disturbed because the ruptured tube has to be repaired. For C_{S2} , it is assumed that the NPP has to be shut down
 330 permanently and the losses incurred are denoted by C_{CD} .

Figure 2. ET for SGTR accident initialing event [49].

Table 1. Safety barriers in the target system [51, 52].

Safety barrier	Failure probability	Description
Reactor trip (RT)	$P_{RT} = 1.8 \times 10^{-4}$	When there is off-normal condition, the protection system automatically inserts control rods into the reactor core to shut down the nuclear reaction.
High pressure safety injection (HPI)	$P_{HPI} = 4.6 \times 10^{-4}$	Inject cool water (at a pressure of about 13.79 MPa) into the reactor coolant system (RCS) to cool the reactor core and provide RCS inventory make-up.
Main steam isolation valve (SGISOL)	$P_{SGI} = 1.0 \times 10^{-4}$	A valve used to isolate the affected steam generator (SG).
Maintain the affected SG pressure (MSGP)	$P_M = 1.5 \times 10^{-4}$	Maintain the affected SG pressure through the pressurizer.
Secondary heat removal (SHR)	$P_{SHR} = 3.4 \times 10^{-5}$	Heat removal by unaffected SG.
Reactor coolant system pressure control (RCSPCON)	$P_{RCSM} = 1.0 \times 10^{-2}$	Open the turbine bypass valve to control the secondary side pressure.
Low pressure safety injection (LPI)	$P_{LPI} = 4.6 \times 10^{-4}$	Inject cool water (at a pressure of about 1.03MPa) to cool down the RCS and provide RCS inventory make-up.
Refill RWT (RWT)	$P_{RWT} = 2.4 \times 10^{-8}$	Refill water storage tank.

The crack growth process that leads to SGTR can be monitored through non-destructive inspection (e.g., ultrasonic testing [53], eddy current testing [54]). In practice, this is done during planned shutdowns of the NPP, often during the refueling stage. The condition monitoring data collected from these inspections are, then, used for the dynamic business continuity assessment.

4.2 Particle filtering and loss modeling

The first step is to update the occurrence probability of the initiating event, based on the condition monitoring data. It is noteworthy that, due to the lack of real data, the condition monitoring data employed in the case study is

340 generated from a known physical model. For illustrative purposes, the evolution of the tube crack growth process is
 341 assumed to follow the Paris-Erdogan model, which has been applied to model SGTR in [52, 55],

$$342 \quad \frac{da}{dt} = C(\Delta K)^m, \Delta K = \Delta \sigma \sqrt{\pi a}, \quad (19)$$

343 where a is the crack length, C and m are constant parameters related to the component material properties,
 344 ΔK is the stress intensity factor, $\Delta \sigma$ is the stress range. The model can be rewritten in the form of a state transition
 345 function [56]:

$$346 \quad a_k = C_k (\Delta \sigma \sqrt{\pi a_k})^{m_k} dt + a_{k-1} \quad (20)$$

347 The crack size a_k at $t = t_k$ is obtained from non-destructive inspection, such as ultrasonic testing; the
 348 corresponding observation z_k is:

$$349 \quad z_k = a_k + \delta_k, \quad (21)$$

350 where δ_k is the observation noise with $\delta_k \sim N(0, \delta_o^2)$.

351 Due to environment and measurement noise, the measured crack lengths are different from the true values. In
 352 this paper, we generate the true value of cracks in Figure 3 using a theoretical model with known parameters and
 353 generate the observation data by adding a random noise. The purpose of using PF is to estimate the true crack length
 354 from the noised observation data and predict the RUL. The number of particles simulated is $N_s = 5000$. It should
 355 be noted that for the tube degradation process, the state vector $\mathbf{x}$ includes the crack size a and the model
 356 parameter variables C , m . The initial values for these variables are drawn uniformly from the intervals of values
 357 listed in Table 2:

$$358 \quad \begin{cases} C_k = C_{k-1} + N(0, \sigma_c^2) \\ m_k = m_{k-1} + N(0, \sigma_m^2) \end{cases} \quad (22)$$

359 Table 2. Initial intervals for the parameters.

Parameters	Initial interval
C	[0.1, 0.2]
m	[1.1, 1.3]
σ_c	$[0.9 \times 10^{-3}, 0.2 \times 10^{-2}]$
σ_m	$[0.9 \times 10^{-3}, 0.2 \times 10^{-2}]$
σ_o	[0.65, 0.85]

The results of PF are shown in Figure 4, where we find that the RUL prediction results become more accurate when more condition monitoring data are available.

Figure 3. Crack growth process.

Figure 4. RUL prediction results.

Afterwards, the loss $L([t, t+T])$ in Equation (2) can be calculated. The losses caused by a SGTR event, include the direct losses and indirect losses. In this case study, the direct losses, denoted by L_d , equal to the value of the damaged equipment. For the consequence C_{S1} , L_d is identical to the value of the ruptured tube. For the consequence C_{S2} , L equals the value of the NPP production since the NPP has to be shutdown. In this paper, we assume that if C_{S2} occurs, we have $L = 5 \cdot 10^9 \in [57]$.

The indirect losses L_{in} are calculated considering the revenue losses during the recovery process, which depends on the recovery time and electricity price. Due to the common use of lognormal distribution for modeling the repair process [58-60], we also assume that the recovery time follows a lognormal distribution with the parameters summarized in Table 3, where ε and β are parameters of the lognormal distribution, whose PDF is

$$f(t_{recv}) = \begin{cases} \frac{1}{\sqrt{2\pi}\beta t_{recv}} e^{-\frac{(\ln(t_{recv})-\varepsilon)^2}{2\beta^2}}, & t_{recv} > 0 \\ 0, & t_{recv} \leq 0. \end{cases} \quad (23)$$

Then, the value of L_{in} is calculated by Monte Carlo simulation.

Table 3. Values of the recovery model parameters.

Parameter	Description	Value
-----------	-------------	-------

ε	The mean value of the lognormal distribution.	1 year
β	The variance value of the lognormal distribution.	0.1 year ²

4.3 Tolerable loss modeling

We assume that the decision-maker of the NPP determines that the organization can tolerate losses up to 10% of the cash flow. Therefore, we have $\alpha = 0.1$. For the NPP, $I(t_k)$ depends on the electricity price, which often exhibits large variabilities. In this paper, we use the following model, as much as possible incorporating the features of electricity price (such as seasonal volatility, time-varying mean reversion and seasonally occurring price spikes) to simulate the stochastic behavior of the electricity price [61]:

$$dx_t = \theta\tau(t)(\mu_p - x_t)dt + \sigma\sqrt{\tau(t)}dW_t + dZ_t \quad (24)$$

where x_t is the electricity price at t , $\theta > 0$ and μ_p is the mean value of the price, W_t is a standard Brownian motion and Z_t is a compound Poisson process with levy measure $\nu(dx) = \lambda g(x)dx$, λ is the jump intensity and g is the density of the jump size distribution, $\tau(t)$ is a positive stochastic process which satisfies:

$$\tau(t) = s(t) + \nu(t) \quad (25)$$

where $s(t)$ is a deterministic, time-dependent and positive seasonal component, which is often modeled by a trigonometric function:

$$S_1(t) = a_1 \sin\left(\frac{a_2 + 2\pi t}{5}\right) + a_3 \left(\frac{a_4 + 2\pi t}{251}\right) + a_5. \quad (26)$$

The value of the seasonal component parameters are shown in Table 4.

Table 4. Values of the seasonal component parameters of the spot prices.

Parameter	Value
a_1	0.41
a_2	1.90
a_3	0.40
a_4	43.11
a_5	0.29

393 $\nu(t)$ is a stochastic process, representing the stochastic part of the time change. The Cox-Ingersoll-Ross process
 394 [62] is used to model $\nu(t)$,

$$395 \quad d\nu(t) = \kappa(\eta - \nu(t))dt + \sqrt{\nu(t)\sigma_2}dW_2(t). \quad (27)$$

396 By using Itô's lemma [61], Equation (24) can be solved and we can derive the following form:

$$397 \quad x(t) = x(0) + \int_0^t \theta(\mu - x(t))dt + \int_0^t \sigma\sqrt{\tau(t)}dB(t) + \int_0^t dZ(t). \quad (28)$$

398 The parameters of the stochastic electricity model are tabulated in Table 5, which is estimated from the German
 399 EEX¹ (a market platform for energy and commodity products), from 12.03.2009 until 31.12.2013. The interested
 400 readers may refer to details and derivations in [61].

401 Table 5. Parameters in the stochastic electricity model [61].

Parameter	Value
x_0	40
θ	0.22
μ	50
σ	5.98
dt	1
λ	0.12
μ_1	1.02
σ_1	1.35

402

403 Eventually, the generated stochastic electricity price trajectory is shown in Figure 5.

¹ <https://www.eex.com>

Figure 5. Simulated time-varying electricity price trajectory for 1500 months.

The operation cost $C_o(t_k)$ in Equation (15) is set as constant 20 €/MWh, which includes the cost of uranium fuel and the cost of disposing used fuel and wastes [63]. Finally, the cash flow at different time points is shown in Figure 6. We can see that the accumulated profit is small at the beginning. This is because this period is still under the repayment period and a large amount of the revenue is used for repaying the installment. After $t = 10$ years, the repayment is paid off and, thus, the profit increases significantly.

Figure 6. Profit trajectory at different estimation points.

4.4 Results

A DBCA is conducted using Algorithm 2. The analyses investigate the dynamic business continuity behavior for the plant at different ages $t = 1, 2, \dots, 40$ (years) and under different evaluation horizons $T = 1, 2, \dots, 60$ (years), as shown in Figures 7~9. To show the difference between DBCA and (time-static) BCA, a comparison is also carried out. For the BCA, the occurrence of SGTR is assumed to follow a Poisson process, where $\lambda_{st} = 7.0 \times 10^{-3}$ per year

416 [49]. The estimated time horizon is chosen to be the lifetime of the NPP, $T = 60$ years. The time-static business
 417 index is defined as:

$$418 \quad BCV(0, T) = 1 - \frac{L(0, T)}{L_{tol}} \quad (29)$$

419 where BCV is the business continuity value; L_{tol} is the tolerable losses and is assumed to be a constant value,
 420 which equals Q_0 (i.e., the initial capital). The recovery time model for the BCA is identical to the one employed in
 421 DBCA.

422 The results from the time-static and time-dependent BCA are compared in Figure 7~9, where the true value is
 423 generated based on a theoretical model with known parameters. Abscissa axis shows the estimation horizon T , and
 424 the vertical axis stands for the different BCV indexes. Therefore, these results show the business continuity of NPPs
 425 at different age (t), if it is operated for different lengths of time (T).

(a) EDBC

(b) P_{BF}

(c) P_{BI}

Figure 7. Business continuity metrics at $t=1$ year.

Figure 8. Business continuity metrics at $t=10$ years.

(c) P_{BI}

Figure 9. Business continuity metrics at $t=40$ years.

- 1) At each t , with the increase of the estimation horizon T , the DBCV decreases. This means that regardless of the age t of the NPP, the longer the NPP is operated, the worse its business continuity: this is logical, as it is primarily caused by the tube's degradation process. No rupture is supposed to occur at the beginning of system operation. Subsequently, as the crack grows, rupture will occur eventually and lead to system failure. In addition, the dynamic business continuity (DBC) indexes curves drop (Figure 7 (a), Figure 8 (a), Figure 9 (a)) or rise (Figure 7 (b, c), Figure 8 (b, c), Figure 9 (b, c)) significantly after a certain value of T . In practice, intervention measures like overhauls need to be taken before this T , in order to prevent serious losses from occurring failures and ensure the business continuity.
- 2) For the same estimation horizon T , with the increase of NPP age t , the EDBCX moves toward left, which means the financial safety margin is narrowing over time t . This is because the steam generator tube is getting closer to a dangerous state as the NPP ages.
- 3) When T is beyond a certain value, the business continuity metrics becomes invariant. This is mainly because when T is sufficiently long, the rupture event will surely happen and after that no loss occurs any more.
- 4) There are plateau sections in the curves of EBCV (Figure 7 (a), Figure 8(a), Figure 9 (a)); the height of these plateaus increases with time t , which makes sense because the system potential profits increase over time t .
- 5) The comparison between DBCA and time-static BCA shows that the time-static BCA grossly underestimates the damage of SGTR on system business and, thus, underestimates the NPP's business loss.

Moreover, the results from the DBCA using condition-monitoring data are closer to the true BCV than those of the time-static BCA. This is because the DBCA using condition monitoring data incorporates the time-dependent behavior of SGTR degradation.

- 6) Confidence interval quantifies the level of confidence that the BCV metrics are captured by the interval. From Figures 7~9, we can see that with more data available, the width of confidence interval is narrowing. That is because, the more condition monitoring, the more precise of the component state estimation and the less uncertainty in the BCA results.

5 Discussion

In this work, although the developed method is only applied on a case study of NPP, it can also be applied in a wide variety of scenarios. To apply the developed method for DBCA, a system needs to satisfy the following premises: (1) the business continuity is related to financial losses; (2) the system behavior and/or the profit of the system are potentially time-dependent; (3) condition monitoring data are available to describe the time-dependent system behaviors. For instance, in the example of oil storage tanks in [4], the profits of the oil storage tank depend on the price of the oil and are therefore time-dependent. Lithium batteries are used to drive some critical safety barriers. As the Lithium battery is subject to degradation, the performance of the safety barriers is also time-dependent. Besides, condition monitoring data are available from the mounted sensors and can be used for online updating the failure probability of the safety barriers. Therefore, the developed methods can be applied for DBCA of the oil tanks. For IT service, the profits also exhibit time-dependent behaviors. The failure behaviors of the hardware in the IT infrastructure are also time-dependent due to the presence of various degradation failure mechanisms. If condition monitoring data are available to monitor the state of the hardware, the developed model can also be applied for a DBCA.

Compared to the original time-static BCA method, the developed model captures the time-dependent features of both profits and system failure behaviors. Therefore, the proposed method can more precisely quantify the business continuity that exhibits time-dependent behaviors. However, the price we need to pay is that our model is more complex in both model development and analysis. In practice, we often need to choose the most appropriate method based on a tradeoff between the complexity of the modelling and the accuracy of the results. For example, for systems whose failure behavior is not time-dependent or not significant to safety, the traditional time-static BCA method might be sufficient. However, for safety critical systems that have significant time-dependency (e.g., NPP), the developed method is preferred due to its potential to provide a more accurate assessment.

It should be noted that in this work, we assume that the operation costs (including the inspection and maintenance cost) do not change over time (as seen in Equation (15)). This assumption is reasonable for NPP, because NPPs are usually designed with a large margin so that even though they reach their designed life, their performance does not degrade very severely. However, for other products, these costs might also be time-dependent and increasing with time. This fact should be considered for a more precise modelling.

Moreover, to illustrate the proposed DBCA model, we use a stochastic electricity model to predict the electricity price as it considers a large variety of features contributing to electricity price variations (such as seasonal volatility, time-varying mean reversion and seasonally occurring price spikes). The predicted electricity price is shown in Figure 5. It should be noted that the predicted values here are used to illustrate the developed method only. There are numerous factors that have the potential influence on the electricity price (such as new energy source and new consumption patterns), which make the predicted results inevitably subject to various sources of uncertainty concerning the long-time span for prediction. Therefore, when the developed method is applied in practice, up-to-date electricity information should be used, instead of this predicted value, in order to reduce the uncertainty and assessment errors.

It should be noted that in this work, we only look at disruptive events that are caused by safety related hazards. In practice, however, the problem of business continuity might also be caused by disruptive events other than safety related hazards, e.g., strike, natural hazards. The developed models can be extended to capture also these disruptive events.

6. Conclusions

In this paper, a DBCA method that integrates condition monitoring data is proposed. Two factors that influence the dynamic behavior of business continuity are considered explicitly. The first one is the dynamics of the degradation-to-failure process affecting the safety barriers. Condition monitoring data are used to update and predict the time-dependent failure behavior by PF. The second factor is the time-dependent profit and tolerable losses. This is quantified by applying a stochastic price model and an installment model. A simulation-based framework is developed to calculate the time-dependent business continuity metrics originally introduced. A case study regarding the analysis of an accident initiated by SGTR in a NPP shows that the proposed framework allows capturing the dynamic character of business continuity.

The outcomes of such dynamic analysis can provide insights to stakeholders and decision-makers, that can help them to identify when best to take actions for preventing serious losses and ensuring business continuity.

Acknowledgement

The work of Ms. Jinduo Xing is supported by China Scholarship Council (No. 201506450020). The work by Professor Enrico Zio has been developed within the research project "SMART MAINTENANCE OF INDUSTRIAL PLANTS AND CIVIL STRUCTURES BY 4.0 MONITORING TECHNOLOGIES AND PROGNOSTIC APPROACHES - MAC4PRO ", sponsored by the call BRIC-2018 of the National Institute for Insurance against Accidents at Work – INAIL in Italy.

References

- [1] Zio, E., *The future of risk assessment*. Reliability Engineering & System Safety, 2018. **177**: p. 176-190.
- [2] Zhou, L., X. Wu, Z. Xu, and H. Fujita, *Emergency decision making for natural disasters: An overview*. International Journal of Disaster Risk Reduction, 2018. **27**: p. 567-576.
- [3] Ouyang, M. and Y. Fang, *A mathematical framework to optimize critical infrastructure resilience against intentional attacks*. Computer - Aided Civil and Infrastructure Engineering, 2017. **32**(11): p. 909-929.
- [4] Zeng, Z. and E. Zio, *Dynamic Risk Assessment Based on Statistical Failure Data and Condition-Monitoring Degradation Data*. IEEE Transactions on Reliability, 2018. **67**(2): p. 609-622.
- [5] Sahebjamnia, N., S.A. Torabi, and S.A. Mansouri, *Integrated business continuity and disaster recovery planning: Towards organizational resilience*. European Journal of Operational Research, 2015. **242**(1): p. 261-273.
- [6] Cerullo, V. and M.J. Cerullo, *Business continuity planning: a comprehensive approach*. Information Systems Management, 2004. **21**(3): p. 70-78.
- [7] Baskerville, R., P. Spagnoletti, and J. Kim, *Incident-centered information security: Managing a strategic balance between prevention and response*. Information & management, 2014. **51**(1): p. 138-151.
- [8] Torabi, S.A., H. Rezaei Soufi, and N. Sahebjamnia, *A new framework for business impact analysis in business continuity management (with a case study)*. Safety Science, 2014. **68**: p. 309-323.
- [9] Rabbani, M., H.R. Soufi, and S.A. Torabi, *Developing a two-step fuzzy cost-benefit analysis for strategies to continuity management and disaster recovery*. Safety Science, 2016. **85**: p. 9-22.
- [10] Torabi, S.A., R. Giahi, and N. Sahebjamnia, *An enhanced risk assessment framework for business continuity management systems*. Safety Science, 2016. **89**: p. 201-218.
- [11] Zsidisin, G.A., S.A. Melnyk, and G.L. Ragatz, *An institutional theory perspective of business continuity planning for purchasing and supply management*. International journal of production research, 2005. **43**(16): p. 3401-3420.
- [12] Zeng, Z. and E. Zio, *An integrated modeling framework for quantitative business continuity assessment*. Process Safety and Environmental Protection, 2017. **106**: p. 76-88.
- [13] ISO, *ISO 22301*, in *Societal Security- Business Continuity Management Systems- Requirements 2012*, International Organization for Standardization: Switzerland.
- [14] Tammineedi, R.L., *Business continuity management: A standards-based approach*. Information Security Journal: A Global Perspective, 2010. **19**(1): p. 36-50.
- [15] Forbes Gibb, S.B., *A framework for business continuity management*. International Journal of Information Management, 2006. **26**: p. 128-141.
- [16] Herbane, B., *The evolution of business continuity management: A historical review of practices and drivers*. Business history, 2010. **52**(6): p. 978-1002.
- [17] Snedaker, S., *Business continuity and disaster recovery planning for IT professionals*. 2013: Newnes.
- [18] Miller, H.E. and K.J. Engemann, *Using reliability and simulation models in business continuity planning*. International Journal of Business Continuity and Risk Management, 2014. **5**(1): p. 43-56.
- [19] Järveläinen, J., *IT incidents and business impacts: Validating a framework for continuity management in information systems*. International Journal of Information Management, 2013. **33**(3): p. 583-590.
- [20] Faertes, D., *Reliability of supply chains and business continuity management*. Procedia Computer Science, 2015. **55**: p. 1400-1409.
- [21] Kato, M. and T. Charoenrat, *Business continuity management of small and medium sized enterprises: Evidence from Thailand*. International journal of disaster risk reduction, 2018. **27**: p. 577-587.
- [22] Hassel, H. and A. Cedergren, *Exploring the Conceptual Foundation of Continuity Management in the Context of Societal Safety*. Risk Analysis, 2019.
- [23] Bonafede, E., P. Cerchiello, and P. Giudici, *Statistical models for business continuity management*. Journal of Operational Risk, 2007. **2**(4): p. 79-96.
- [24] Tan, Y. and S. Takakuwa, *Use of simulation in a factory for business continuity planning*. International Journal of

Simulation Modelling, 2011. **10**(1): p. 17-26.

[25] Rezaei Soufi, H., S.A. Torabi, and N. Sahebjamnia, *Developing a novel quantitative framework for business continuity planning*. International Journal of Production Research, 2018: p. 1-22.

[26] Sahebjamnia, N., S.A. Torabi, and S.A. Mansouri, *Building organizational resilience in the face of multiple disruptions*. International Journal of Production Economics, 2018. **197**: p. 63-83.

[27] Zubair, M. and Z. Zhijian, *Reliability Data Update Method (RDUM) based on living PSA for emergency diesel generator of Daya Bay nuclear power plant*. Safety Science, 2013. **59**: p. 72-77.

[28] Nazempour, R., M.A.S. Monfared, and E. Zio, *A complex network theory approach for optimizing contamination warning sensor location in water distribution networks*. International Journal of Disaster Risk Reduction, 2018. **30**: p. 225-234.

[29] Aizpurua, J.I., V.M. Catterson, Y. Papadopoulos, F. Chiacchio, and G. Manno, *Improved dynamic dependability assessment through integration with prognostics*. IEEE Transactions on Reliability, 2017. **66**(3): p. 893-913.

[30] Liu, J. and E. Zio, *System dynamic reliability assessment and failure prognostics*. Reliability Engineering & System Safety, 2017. **160**: p. 21-36.

[31] Fan, M., Z. Zeng, E. Zio, R. Kang, and Y. Chen, *A Sequential Bayesian Approach for Remaining Useful Life Prediction of Dependent Competing Failure Processes*. IEEE Transactions on Reliability, 2018. **68**(1): p. 317-329.

[32] Coussement, K., D.F. Benoit, and M. Antioco, *A Bayesian approach for incorporating expert opinions into decision support systems: A case study of online consumer-satisfaction detection*. Decision Support Systems, 2015. **79**: p. 24-32.

[33] Sharma, S. and S. Routroy, *Modeling information risk in supply chain using Bayesian networks*. Journal of Enterprise Information Management, 2016. **29**(2): p. 238-254.

[34] Lawler, C.M., M.A. Harper, S.A. Szygenda, and M.A. Thornton, *Components of disaster-tolerant computing: analysis of disaster recovery, IT application downtime and executive visibility*. International Journal of Business Information Systems, 2008. **3**(3): p. 317-331.

[35] Xie, Y., J. Zhang, T. Aldemir, and R. Denning, *Multi-state Markov modeling of pitting corrosion in stainless steel exposed to chloride-containing environment*. Reliability Engineering & System Safety, 2018. **172**: p. 239-248.

[36] Mayén, J., A. Abúndez, I. Pereyra, J. Colín, A. Blanco, and S. Serna, *Comparative analysis of the fatigue short crack growth on Al 6061-T6 alloy by the exponential crack growth equation and a proposed empirical model*. Engineering Fracture Mechanics, 2017. **177**: p. 203-217.

[37] Compare, M., F. Martini, S. Mattafirri, F. Carlevaro, and E. Zio, *Semi-Markov model for the oxidation degradation mechanism in gas turbine nozzles*. IEEE Transactions on Reliability, 2016. **65**(2): p. 574-581.

[38] Franke, U., *Optimal IT service availability: Shorter outages, or fewer?* IEEE Transactions on Network and Service Management, 2011. **9**(1): p. 22-33.

[39] Zio, E. and G. Peloni, *Particle filtering prognostic estimation of the remaining useful life of nonlinear components*. Reliability Engineering & System Safety, 2011. **96**(3): p. 403-409.

[40] Si, X.-S., C.-H. Hu, Q. Zhang, and T. Li, *An integrated reliability estimation approach with stochastic filtering and degradation modeling for phased-mission systems*. IEEE transactions on cybernetics, 2017. **47**(1): p. 67-80.

[41] Corbetta, M., C. Sbarufatti, M. Giglio, and M.D. Todd, *Optimization of nonlinear, non-Gaussian Bayesian filtering for diagnosis and prognosis of monotonic degradation processes*. Mechanical Systems and Signal Processing, 2018. **104**: p. 305-322.

[42] Yu, P., J. Cao, V. Jegatheesan, and L. Shu, *Activated sludge process faults diagnosis based on an improved particle filter algorithm*. Process Safety and Environmental Protection, 2019. **127**: p. 66-72.

[43] Arulampalam, M.S., S. Maskell, N. Gordon, and T. Clapp, *A tutorial on particle filters for online nonlinear non-gaussian Bayesian tracking*. IEEE Transactions on Signal Processing, 2002. **50**(2): p. 174-188.

[44] Hu, Y., P. Baraldi, F.D. Maio, and E. Zio, *Online Performance Assessment Method for a Model-Based Prognostic Approach*. IEEE Transactions on reliability, 2016. **65**(2): p. 718-735.

[45] Tulsyan, A., B. Huang, R.B. Gopaluni, and J.F. Forbes, *On simultaneous on-line state and parameter estimation in non-linear state-space models*. Journal of Process Control, 2013. **23**(4): p. 516-526.

[46] Hosseini, S. and K. Barker, *Modeling infrastructure resilience using Bayesian networks: A case study of inland waterway ports*. Computers & Industrial Engineering, 2016. **93**: p. 252-266.

[47] Lanza, A., M. Manera, and M. Giovannini, *Modeling and forecasting cointegrated relationships among heavy oil and product prices*. Energy Economics, 2005. **27**(6): p. 831-848.

[48] Sullivan, W.G., E.M. Wicks, and J.T. Luxhoj, *Engineering economy*. Vol. 12. 2003: Prentice Hall Upper Saddle River, NJ.

[49] Kim, H., J.T. Kim, and G. Heo, *Failure rate updates using condition-based prognostics in probabilistic safety assessments*. Reliability Engineering & System Safety, 2018. **175**: p. 225-233.

[50] Auvinen, A., J. Jokiniemi, A. Lähde, T. Routamo, P. Lundström, H. Tuomisto, J. Dienstbier, S. Güntay, D. Suckow, and A. Dehbi, *Steam generator tube rupture (SGTR) scenarios*. Nuclear engineering and design, 2005. **235**(2-4): p. 457-472.

[51] Mercurio, D., L. Podofillini, E. Zio, and V.N. Dang, *Identification and classification of dynamic event tree scenarios via possibilistic clustering: Application to a steam generator tube rupture event*. Accident Analysis & Prevention, 2009.

618 41(6): p. 1180-1191.

619 [52] Lewandowski, R., R. Denning, T. Aldemir, and J. Zhang, *Implementation of condition-dependent probabilistic risk*
620 *assessment using surveillance data on passive components*. Annals of Nuclear Energy, 2016. **87**: p. 696-706.

621 [53] Narayanan, M., A. Kumar, S. Thirunavukkarasu, and C. Mukhopadhyay, *Development of ultrasonic guided wave*
622 *inspection methodology for steam generator tubes of prototype fast breeder reactor*. Ultrasonics, 2019. **93**: p. 112-121.

623 [54] Buck, J.A., P.R. Underhill, J.E. Morelli, and T.W. Krause, *Simultaneous multiparameter measurement in pulsed eddy*
624 *current steam generator data using artificial neural networks*. IEEE Transactions on Instrumentation and Measurement,
625 2016. **65**(3): p. 672-679.

626 [55] Di Maio, F., F. Antonello, and E. Zio, *Condition-based probabilistic safety assessment of a spontaneous steam*
627 *generator tube rupture accident scenario*. Nuclear Engineering and Design, 2018. **326**: p. 41-54.

628 [56] An, D., J.-H. Choi, and N.H. Kim, *Prognostics 101: A tutorial for particle filter-based prognostics algorithm using*
629 *Matlab*. Reliability Engineering & System Safety, 2013. **115**: p. 161-169.

630 [57] Zhu, L., *A simulation based real options approach for the investment evaluation of nuclear power*. Computers &
631 Industrial Engineering, 2012. **63**(3): p. 585-593.

632 [58] Arif, A., S. Ma, Z. Wang, J. Wang, S.M. Ryan, and C. Chen, *Optimizing service restoration in distribution systems*
633 *with uncertain repair time and demand*. IEEE Transactions on Power Systems, 2018. **33**(6): p. 6828-6838.

634 [59] Ananda, M.M., *Confidence intervals for steady state availability of a system with exponential operating time and*
635 *lognormal repair time*. Applied Mathematics and Computation, 2003. **137**(2-3): p. 499-509.

636 [60] Ferrario, E. and E. Zio, *Assessing nuclear power plant safety and recovery from earthquakes using a system-of-*
637 *systems approach*. Reliability Engineering & System Safety, 2014. **125**: p. 103-116.

638 [61] Borovkova, S. and M.D. Schmeck, *Electricity price modeling with stochastic time change*. Energy Economics, 2017.
639 **63**: p. 51-65.

640 [62] Hefter, M. and A. Herzwurm, *Strong convergence rates for Cox–Ingersoll–Ross processes—full parameter range*.
641 Journal of Mathematical Analysis and Applications, 2018. **459**(2): p. 1079-1101.

642 [63] Zhu, L. and Y. Fan, *Optimization of China's generating portfolio and policy implications based on portfolio theory*.
643 Energy, 2010. **35**(3): p. 1391-1402.