A Clusterized Energy Management with Linearized Losses in the Presence of Multiple Types of Distributed Generation

Rémy Rigo-Mariani, Keck Voon Ling, Jan Maciejowski

► To cite this version:

Rémy Rigo-Mariani, Keck Voon Ling, Jan Maciejowski. A Clusterized Energy Management with Linearized Losses in the Presence of Multiple Types of Distributed Generation. *International Journal of Electrical Power & Energy Systems*, 2019, 113, pp.9-22. hal-03016675

HAL Id: hal-03016675

<https://hal.science/hal-03016675>

Submitted on 20 Nov 2020

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

A Clusterized Energy Management with Linearized Losses in the Presence of Multiple Types of Distributed Generation

Rmy Rigo-Mariani, Keck Voon Ling, Jan Maciejowski
Cambridge Centre for Advanced Research and Education in Singapore

Abstract—This paper presents an optimal management (OM) strategy for distributed generation (DG) planning whose objective is the CO₂ reduction for the power generation on the Jurong Island in Singapore. Different DG resources are investigated with solar generation, energy storage, small gas turbine as well as controllable loads in addition to the centralized generation already in site. Each of those resource is modeled in an optimal scheduling method that allow to test a great number of different DG configurations (i.e. type/size/site). The paper mainly focuses on the OM implementation that would allow avoiding prohibitive computational times. At first it is achieved thanks to a linearization of the line losses and a modified DC power flow. When simulating the system over a representative day. Then a generic clustering method is developed as well as a sequential optimal management (S-OM) with the zonal and nodal models is implemented. Different validation tests are performed as well as sets of simulation with different DG configurations. The optimal DG planning procedure will be part of further developments.

Index Terms—Distributed generation, MILP, CO₂ emissions, energy storage, controllable load, network partitioning.

INTRODUCTION

The work presented in this paper focuses on reducing carbon emissions due to the power generation on Jurong Island in Singapore. That island hosts around 40 % percent of the total generation capacity in Singapore with thirteen identified Combined Cycle Gas Turbine (CCGT) units aggregated in four power plants [1][2]. A great part of the generated energy is consumed on the island by refineries, oil storage facilities and other petrochemical activities while the surplus is exported to the Singaporean mainland. The integration of distributed generation (DG) to the existing system is investigated as a way to reduce the emissions compared to the current base scenario in which only the centralized generation (i.e. the four power plants) is considered. The advantage of DG assets is to bring more diverse resources as well as more flexibility with various additional benefits such as loss reduction, improved reliability or the deferment of grid investments [3] [4]. In such a framework typical DG planning problems aim at finding the best types, sizes and allocations of the assets that minimize the considered objective function (i.e. CO₂ emissions for a representative day here) [5]. The main concern when facing such problems is to avoid the computational burden while estimating the performances of many different DG configurations. The complexity of these DG

planning studies can be disaggregated in three parts. Firstly, the numbers and types of the considered distributed resources directly impacts the amount of possible configurations to test. Simplest case studies investigate the placement of single generic PQ units with exhaustive search or analytical approaches [6] [7]. More complex problems consider multiple generic PQ units [8] or multiple types of resources with both renewable and storage units [9] [10]. This paper investigates different DG technologies, including photovoltaic generation (PV), energy storage (ST) and distributed CCGT units (DU). The presence of controllable loads (CL) is also studied which is not commonly done in the literature. The second degree of complexity for DG planning studies comes from the size of the modeled power system which obviously increases the number of possible DG configurations (i.e. types/sizes/sites). Typical systems encountered literature display a wide range for their number of buses from less than 10 [11] to over 100 [12] while the Jurong Island system is modeled here with a little more than 200 nodes. Thirdly, the difficulty to solve those planning problems is enhanced when longer time horizons are considered to compute the objective function. Indeed, many studies only refers to a single snapshot power flow with one load level, to compute the cost, losses or reliability index corresponding to every DG configuration estimated [11] [13] [14]. Some works run simulations over a whole year with successive independent AC optimal power flow (AC OPF), as in [15] [16]. However, when storage units are considered, as it the case in this paper, the introduction of time related constraints (e.g. the state of charge computation) implies that the whole time horizon needs to be represented in the optimization problems and successive AC OPF cannot be applied. Thus, authors often refer to simplified DC OPF with the extensive use of linearized formulations in order to avoid prohibitive computation times [17] [18] (See table in [Appendix A](#) for a summary of the reviewed studies).

Figure 1: Coupling between design and management loops – a) integrated – b) all in one – c) iterative

With time series profiles considered, DG planning studies can be seen as systematic optimization problems. The goal is to find the best configuration for the DG assets (i.e. design loop) whose operation over a given time horizon (i.e. management loop) corresponds to the best values of the objective. Several approaches are identified in the literature, with different couplings between the management and design loops [19]. Bi-level optimization is often used where the DG sizes/sites are part of an outer loop problem while the management is solved in an inner loop ([Figure 1a](#)). Typically, the design variables generated in the outer level are used as input parameters for the inner level with two integrated optimization problems. Such an approach is presented

in [9] [20] [21] with the DG management over a day performed by dynamic programming or successive AC OPF while genetic algorithms try to find the best design in terms of DG sites/sizes. A second class of works refer to “all in one” approaches where both design and management variables are part of a single optimization problem (Figure 1b), usually using LP or MILP formulation [17] [18]. However, the convergence of the global problem might not be ensured in a reasonable time. The architecture considered in this paper corresponds to a classical iterative method which consists in several estimations of the management loop for different configurations and attempts to improve the design (Figure 1c). [10] [22] use such a method with successive AC OPF for the management strategy while different designs are generated with Monte Carlo simulations or an analytical approach.

This paper mainly focuses on the implementation of the DG management strategy within an iterative architecture for DG planning. Also note that the optimal operation of the assets is jointly considered with the schedule of the centralized resources on sites. DG integration will change the generation mix of the Jurong Island along with more flexibility provided by storage units and the ability to perform load control. Thus the management loop will be implemented in the form of a typical unit commitment problem (UC) with the existing power plants and the addition of DG resources whose connection buses and sizes are input parameters. Note that today the generations companies in Jurong Island bid in the national Singaporean market before the Power System Operator runs the UC [2]. In this work, the assumption is made that all the power plants and DG assets are centrally owned and managed by a vertical entity that could be the already existing “Jurong Island Community” for instance. A specific attention is paid to the computational time that has to be small enough in order to test a great number of DG configurations (i.e. types/sizes/sites). It is achieved here in two steps that are the main contributions of the proposed approach. Firstly, losses within the lines are linearized using a modified DC OPF. Unlike conventional iterative approaches [23] [24], the method developed here is faster and reference independent. It lies on the linear coefficients extracted from preliminary sets of simulations with several runs of AC OPF and it is denoted as OM (Optimal Management). Secondly, a clustering approach allows fast computational times while dealing with a reduced number of variables. In DG planning studies, clustering methods are often used to reduce the input information and the long time horizons are then represented by a limited number of representative time steps [15]. Other efficient clustering approaches consist in grouping the generations assets by type of resources [25] or by units displaying similar characteristics [26]. In this paper the clustering procedure is considered to perform a network partitioning based on its topology while computing the “electrical distances”. In particular, that zonal decomposition lies in a partitioning method that automatically ensures the cluster connectedness to improve the convergence of the clustering method. Finally, a sequential management procedure with zonal and nodal representations (denoted as S-OM) is implemented in order to ensure the

convergence of the management strategy in a faster computational time. It lies on successive runs of the previously OM within each cluster and for the overall system zonal representation.

The rest of the paper is organized as follow. Section 2 presents the management strategy run over a representative day. The mathematical formulation of the OMLL method is described with a particular attention paid to the power plant operation constraints for the centralized generation. The models for the different types of DG assets are detailed as well as the modified DC OPF constraints that integrates the proposed approximations for the line losses. Then Section 3 introduces the partitioning algorithm that performs the network clustering and the sequential zonal/nodal algorithm is presented. Finally, Section 4 gives a set of different results that allows to validated the proposed approaches (OM and S-OM) as well as the developed models. Different DG configurations added to the existing centralized assets are investigated. However, it is important to remind that the paper focuses on the management loop only (Figure 1c). The design strategy that would aim at estimating the best configurations will be part of further works.

OPTIMAL MANAGEMENT WITH LOSS LINEARIZATION

A. Jurong Island Power System

As already mentioned the case study is the transmission grid in the Jurong Island of Singapore. Figure 2a displays the corresponding model with the topology of the high voltage lines/buses as well as the position of the four existing power plants. Note that the 208 buses/219 branches model was built based on assumptions and does not necessarily represent the real topology. In particular, line impedances are computed from cables manufacturers datasheets and the geographic coordinates of the identified load points. Lines ratings are estimated based on the load at each node with four types of consumers are identified: refineries, oil storage, chemical plants and offices. The voltage connection of each of those consumers depends on their rated power following the rules of connection in Singapore. The centralized generation on site consists in thirteen CCGT units displaying five different technologies (denoted from A to E). Those thirteen units are among the four power plants as follow: Keppel (KPL): 2 units type A and two units type B – Pacific Light Power (PLP): 2 units type C – Sembcorp (SMB): 1 unit type A and 2 units type D – Seraya (SRY): 2 units type C and 2 units type E. Previous works focused on the modeling of the CO₂ emissions of the CCGT technologies based on their operating points and efficiency (ranging from 53 % to 62 %) [1]. Their nominal operating points and part load operations were simulated to finally compute their specific CO₂ emissions (*SCE* in kg/kWh) (Figure 2a). An environmental unit was developed to consider those “carbon costs” in a CO₂ minimization while supplying a representative load profile. The optimal management developed in this paper lies on the same strategy with more

complexity coming from the addition of different types of DG assets to the existing generation portfolio. Figure 2b shows the the daily deterministic load that have to be supplied with a 30 minute time step while aggregating the load for all the four types of consumers.

Figure 2: Jurong Island Power System – a) Grid topology – b) CO₂ emissions of centralized CCGT technologies – c) aggregated load profiles

B. Environmental Unit Commitment Objective

As already mentioned the management strategy is implemented in the form of a typical unit commitment (UC) with both centralized power plants and distributed resources. A typical MILP formulation is consider here with the objective to minimize those emissions while fulfilling a set of traditional constraints such as minimum up/down times and considering start-up and shut-down carbon costs [27]. It is important to note that the units contributing to the emissions are the centralized generators in existing power plants (index CG) as well as the smaller distributed units (index DU) that are considered in the DG planning framework. Mathematically the formulation is the same for those two types of generators. The distinction is made as the centralized assets will remain the same (size/site) while the smaller units portfolio will change depending on the different DG configurations that might be investigated. Thus equation (1) allows to compute the total CO₂ emissions for both centralized and distributed thermal units located at the system buses (bus set B) and along the simulated day (time set T) discretized at an half hourly time step Δt . The computation considers the on/off ($u_{b,t}^{CG}$, $u_{b,t}^{DU}$) and startup ($v_{b,t}^{CG}$, $v_{b,t}^{DU}$) conditions of the units at bus b at time t as well as the corresponding base “carbon costs” (CO_b^{CG} , CO_b^{DU}) and startup emissions (SU_b^{CG} , SU_b^{DU}). The piecewise linearization is run along C, the set of linear blocks, in which the generated power ($p_{c,b,t}^{CG}$, $p_{c,b,t}^{DU}$) is attach to a cost ($a_{c,b}^{CG}$, $a_{c,b}^{DU}$).

$$obj = \sum_{t \in T} \sum_{b \in B} \left(\left(CO_b^{CG} \times u_{b,t}^{CG} + \sum_{c \in C} a_{c,b}^{CG} \times p_{c,b,t}^{CG} \right) \times \Delta t + SU_b^{CG} \times v_{b,t}^{CG} + \left(CO_b^{DU} \times u_{b,t}^{DU} + \sum_{c \in C} a_{c,b}^{DU} \times p_{c,b,t}^{DU} \right) \times \Delta t + SU_b^{DU} \times v_{b,t}^{DU} \right) \quad (1)$$

Table 1: List of the used symbols in the OMLL

Sets :		
$b \in B$	set of buses	-
$t \in T$	set of time steps	-
$c \in C$	set of linear blocks for the CCGT carbon emissions	-
$l \in L$	set of lines	-
$w \in W$	set of linear blocks for line losses estimation	-
$n \in N$	set of grid cluster (with buses and lines)	-
$b_n \in B_n$	set of equivalent buses in zonal model	-
$l_n \in L_n$	set of lines in in zonal model (subset of L)	-
Variables :		
$u_{b,t}^{CG}, u_{b,t}^{DU}$	on/off status of CCGT unit at bus b at time t $\{0,1\}$	-
$v_{b,t}^{CG}, v_{b,t}^{DU}$	startup of CCGT unit at bus b at time t $\{0,1\}$	-
$p_{c,b,t}^{CG}, p_{c,b,t}^{DU}$	CCGT unit power at bus b operating in block c at time t	MW
$P_{b,t}^{CG}, P_{b,t}^{DU}$	power output of CCGT unit at bus b at time t	
$P_{b,t}^{CG\{k\}}$	power output of a unit k in power plant at bus b at time t	MW
$\Delta u_{b,t}^{CG\{k\}+}, \Delta u_{b,t}^{CG\{k\}-}$	up/down ramp of unit k in power plant at bus b at time t $\{0,1\}$	-
$F_{l,t}^+, F_{l,t}^-$	positive/negative power flows in line l at time t	MW
$\delta F_{l,t}^+, \delta F_{l,t}^-$	positive/negative power flows in line l at time t	MW
$f_{w,l,t}^+, f_{w,l,t}^-$	positive/negative power flows in block w of line l at time t	MW
$\theta_{b,t}$	voltage angle at bus b at time t	p.u.
$P_{b,t}^\Sigma$	power balance of at bus b at time t	MW
$\delta P_{b,t}^{PV-}$	curtailed PV generation at bus b at time t	MW
$P_{b,t}^{ST-}, P_{b,t}^{ST+}$	charge/discharge powers of storage at bus b at time t	MW
$SOC_{b,t}$	state of charge of distributed storage at bus b at time t	%
$u_{n,t}^{\Sigma CL-}, u_{n,t}^{\Sigma CL+}$	control for decrease/increase of cluster n at time t $\{0,1\}$	-
Parameters :		
CO_b^{CG}, CO_b^{DU}	base CO ₂ emissions of CCGT unit at bus b	tons
SU_b^{CG}, SU_b^{DU}	startup CO ₂ emissions of CCGT unit at bus b	tons
$a_{c,b}^{CG}, a_{c,b}^{DU}$	operating CO ₂ emissions of units bus b operating in block c	tons/MWh
$p_{c,b}^{CGmax}, p_{c,b}^{DUmax}$	upper bound of CCGT unit power at bus b operating in block c	MW
P_b^{CGmin}, P_b^{CGmax}	min/max output power of centralized CCGT unit at bus b	MW
P_b^{DUmin}, P_b^{DUmax}	min/max output power of distributed CCGT unit at bus b	MW
ΔP_{max}^{CG}	maximum ramp value for the centralized CCGT units	MW
$f_{w,l}^{max}$	maximum power flow in block w of line l at time t	MW
F_l^{max}	maximum flow in line l	MW
$\alpha_{w,l}^{\delta F}$	loss factor in block w of line l	-
$\mathbf{B}_{bus}$	$B \times B$ bus admittance matrix	p.u.
$P_{b,t}^{PV}$	available PV generation at bus b at time t	MW
P_b^{STmax}, E_b^{STmax}	rated power/energy for storage at bus b	MW/MWh
η^{ST}	generic storage power efficiency (typically 0.975)	-
$\Delta P_n^{\Sigma CL}, T_n^{\Sigma CL}$	power magnitude and duration of control phase of cluster n	MW/h
$\Delta P_{b \in n}^{CL}$	power magnitude for CL at bus b in cluster n	MW
$P_{b,t}^L$	load at bus b at time t	MW

Carbon costs linearization requires sets of typical variable and constraints [28] in order to compute the output power of the CCGT units ($P_{b,t}^{CG}, P_{b,t}^{DU}$) based on their on/off status, minimum output power (P_b^{CGmin}, P_b^{DUmin}) and their operation within each linear blocks c (2). The contribution in each block is subject to upper bounds ($p_{c,b}^{CGmax}, p_{c,b}^{DUmax}$) ((3)) and constraint (4) finally ensures that each units operates within its acceptable range if it is on. Conventional ramping limits and up/down-times constraints

do not appear here for the sake of simplicity. A full list of the symbols used in the optimal management strategy is given in [Table 1](#).

$$P_{b,t}^{CG} = P_b^{CGmin} \times u_{b,t}^{CG} + \sum_{c \in C} P_{c,b,t}^{CG} \quad \text{and} \quad P_{b,t}^{DU} = P_b^{DUmin} \times u_{b,t}^{DU} + \sum_{c \in C} P_{c,b,t}^{DU} \quad (2)$$

$$0 \leq P_{c,b,t}^{CG} \leq P_{c,b}^{CGmax} \quad \text{and} \quad 0 \leq P_{c,b,t}^{DU} \leq P_{c,b}^{DUmax} \quad (3)$$

$$P_b^{CGmin} \times u_{b,t}^{CG} \leq P_{b,t}^{CG} \leq P_b^{CGmax} \times u_{b,t}^{CG} \quad \text{and} \quad P_b^{DUmin} \times u_{b,t}^{DU} \leq P_{b,t}^{DU} \leq P_b^{DUmax} \times u_{b,t}^{DU} \quad (4)$$

C. Centralized Power Plants Operation Constraints

Unlike most UC studies in the literature, the different CCGT units are here aggregated among distinct power plants that display several generators with the same technology (i.e. the same parameters). All the generators k within a same power plant being connected to the same bus, the optimization may lead to unrealistic cases: two units k and k' of the same technology in a same plant opposite deviations (up/down ramps) between two successive time steps while the sum of their output power remains constant. With the considered mathematical formulation, such “distorted profiles” would correspond to the same emissions as a case where units k and k' would generate a constant power. Thus additional variables and constraints are introduced for the centralized generation in order to obtain more realistic operation of the power plants [\[29\]](#). Binary variables $\Delta u_{b,t}^{CG\{k\}+}$ and $\Delta u_{b,t}^{CG\{k\}-}$ allow the identification of the up/down ramp direction of each concerned units k at bus b at time t . Those ramp direction are computed with constraint [\(5\)](#) with Δu_{max}^{CG} being the maximum expected power deviation (set to a high value) and $P_{b,t}^{CG\{k\}}$ the output power of the power plant unit k at bus b at time t . That power has minimum and maximum value and is subject to conventional operating constraints related to the piecewise linearization of the carbon costs. Logical constraint [\(6\)](#) ensures that the deviations can be either positive or negative. Finally [\(7\)-\(8\)](#) allow to give priority (arbitrarily) to unit k' over another unit k'' if k' and k'' display the same technology within the same power plant. Note that only one of the two constraints in [\(8\)](#) is necessary, the other being implicitly fulfilled with [\(6\)](#).

$$-\Delta P_{max}^{CG} \times \Delta u_{b,t}^{CG\{k\}-} \leq P_{b,t}^{CG\{k\}} - P_{b,t-1}^{CG\{k\}} \leq \Delta P_{max}^{CG} \times \Delta u_{b,t}^{CG\{k\}+} \quad (5)$$

$$\Delta u_{b,t}^{CG\{k\}-} + \Delta u_{b,t}^{CG\{k\}+} \leq 1 \quad (6)$$

$$P_{b,t}^{CG\{k'\}} \geq P_{b,t}^{CG\{k''\}} \quad (7)$$

$$\Delta u_{b,t}^{CG\{k'\}-} + \Delta u_{b,t}^{CG\{k''\}+} \leq 1 \quad \text{or} \quad \Delta u_{b,t}^{CG\{k'\}+} + \Delta u_{b,t}^{CG\{k''\}-} \leq 1 \quad (8)$$

D. Modified DC OPF for Line Losses Linearization

This subsection describes the introduction of the line losses estimation in the developed optimal management. That estimation is necessary if the impact of different locations of the resources is investigated. AC power flow equations provide an exact computation of those losses when DG planning studies only considers single load level. However, a DC power flow should be considered here to avoid prohibitive computational times while optimizing over a daily time horizon. Conventional loss estimation in DC power flow lies in the computation of the marginal loss factor and generation shift factor matrixes [30]. The approaches require the integration of an offset that represent an initial guess of the total system loss which is not necessary available. Iterative approaches such as [24] allow to overcome that problem but might unnecessary increase the computational time with several runs needed. The Jump and Shift iterative method [23] will be further considered as a base case to validate the method developed in this paper. That method lies in a modified DC power flow that discriminates the flow directions $F_{l,t}^+$ and $F_{l,t}^-$ in line l at time t before performing a linearization of the corresponding losses $\delta F_{l,t}^+$ and $\delta F_{l,t}^-$. A preprocessing step is needed in which several AC OPF are run with random load levels and using a dedicated power flow package (Matpower here). A piecewise linearization of W blocks ($W = 1$ and $W = 2$) is then performed for each lines using a regular least square method (Figure 3).

Figure 3: Line Loss Linearization

Similarly to the linearization of the CO2 emissions new sets of variables and constraints allow the loss estimation with $f_{w,l,t}^+$, $f_{w,l,t}^-$ the positive/negative instantaneous line flow in block w and their corresponding upper bounds $f_{w,l}^{max}$. Similarly to the piecewise linearization of the carbon cost function, W intervals are defined to compute the power flowing through the branch ((9)). Equation (10) implicitly allows the avoidance of line congestion ($0 \leq F_{l,t}^+, F_{l,t}^- \leq F_l^{max}$). Note that for transformers, only unidirectional flows are possible meaning that either the positive or the negative flow has to remain null depending on the

transformer definition (i.e. start/end buses). Finally, line losses are computed following (11) with the slope coefficients $\alpha_{w,l}^{\delta F}$ estimated in the preprocessing phase for each block w of every line l .

$$F_{l,t}^+ = \sum_{w \in W} f_{w,l,t}^+ \quad \text{and} \quad F_{l,t}^- = \sum_{w \in W} f_{w,l,t}^- \quad (9)$$

$$0 \leq f_{w,l,t}^+ \leq f_{w,l}^{\max} \quad \text{and} \quad 0 \leq f_{w,l,t}^- \leq f_{w,l}^{\max} \quad (10)$$

$$\delta F_{l,t}^+ = \sum_{w \in W} \alpha_{w,l}^{\delta F} \times f_{w,l,t}^+ \quad \text{and} \quad \delta F_{l,t}^- = \sum_{w \in W} \alpha_{w,l}^{\delta F} \times f_{w,l,t}^- \quad (11)$$

That piecewise linearization is integrated in a conventional DCPF formulation [31] where line flows are computed with the bus admittance matrix $\mathbf{B}^{\text{bus}}$ and the bus instantaneous voltage angles $\theta_{b,t}$ (12). Finally, the power balance at each bus is computed according to (13) as the contribution of the in the branches arriving at the bus or departing from it. Noted that similarly to the method developed in [30] the losses within a line are equally distributed at the start and end buses as additional loads.

$$\begin{cases} F_{l,t}^+ - F_{l,t}^- = \mathbf{B}_{b'b''}^{\text{bus}} \times (\theta_{b',t} - \theta_{b'',t}) \text{ with line } l \text{ defined from } b' \text{ to } b'' \\ \theta_{l,t} = 0 \quad \forall t \in T \quad (\text{slack bus } b = 1) \end{cases} \quad (12)$$

$$P_{b,t}^{\Sigma} = \sum_{l \in \text{lines from } b} \left(F_{l,t}^+ + \frac{\delta F_{l,t}^+}{2} \right) - \left(F_{l,t}^- + \frac{\delta F_{l,t}^-}{2} \right) - \sum_{l \in \text{lines to } b} \left(F_{l,t}^+ + \frac{\delta F_{l,t}^+}{2} \right) - \left(F_{l,t}^- + \frac{\delta F_{l,t}^-}{2} \right) \quad (13)$$

E. Integration of DG Resources

1) Conventional DG assets

This section introduces the modeling for the different DG assets in the developed optimal management with linearized losses (OMLL). Firstly, PV distributed generation at bus b and time t $P_{b,t}^{PV}$ is considered with different sizes of installations simulated using a normalized profile for a 1MWc plant in Singapore that was generated with the PVwatts tool from the National Renewable Energy Laboratory [32]. The management strategy considers the possibility to curtailed the PV generation with the variable $\delta P_{b,t}^{PV-}$ (14) in order to avoid potential line congestion in case of oversized installation [33]. The second type of considered DG resources corresponds to distributed generic energy storage (ST) devices. A typical linear formulation is used while discriminating the charge ($P_{b,t}^{ST-}$) and discharge ($P_{b,t}^{ST+}$) powers for the units at bus b at time t . A power efficiency $\eta^{ST} = 97.5\%$ is introduced to compute the state of charge $SOC_{b,t}$ following (15) with the rated energy E_b^{STmax} and the initial charge level $SOC_{b,t=0}$ (typically 50 %) [17]. The set of constraints ensures to fulfill the power/energy limitations and enforces the storage devices to come back at their initial SOC at the end of the simulated day. The last type of conventional DG resources that is considered correspond to small CCGT. The operating parameters of those distributed units (DU) derive from the technology A

with value scale down for smaller rated power. The operating constraints of those assets are similar to the ones implemented for the centralized thermal units and have already been discussed in section 2.A.

$$0 \leq \delta P_{b,t}^{PV-} \leq P_{b,t}^{PV} \quad (14)$$

$$SOC_{b,t} = SOC_{b,t=0} - \frac{100 \times \Delta t}{E_b^{STmax}} \times \sum_{i=1}^t \left(\frac{P_{b,i}^{ST+}}{\eta^{ST}} - \eta^{ST} \times P_{b,i}^{ST-} \right) \quad (15)$$

$$0 \leq P_{b,t}^{ST-}, P_{b,t}^{ST+} \leq P_b^{STmax}, \quad 0 \leq SOC_{b,t} \leq 100, \quad SOC_{b,t=T} = SOC_{b,t=0} \quad (16)$$

2) Controllable loads

This paper considers load controllability (CL) as a potential DG resource. Many strategies are investigated in the literature when dealing with load control ranging from highly centralized demand response methods to the fully distributed transactive energy framework [Kok 16]. In this study a centralized control is implemented as the assumption is made that a vertical utility (Jurong Island Community here) owns and operates all the assets on site. In particular, it implies that the customers on site agrees to change their consumption pattern accordingly to central controls which might lead to some privacy issues and be challenging when heavy industrial customers are concerned. Incentives policies should then be considered but it is not in the scope of this paper. Distributed energy storage already provides an example of full continuous flexibility with controllable charge/discharge powers. Here the load control strategy relies on discrete load increments or decrements that would correspond to the time shifting of chemical processing by the considered consumers. The idea is to provide a different type of flexibility. Also, in order to better manage the complexity, loads are aggregated within N distinct clusters using a network partitioning strategy that will be discussed in the next section. The actual load control will then be applied to clusters and not individual customers. Each of those cluster n agrees in advance upon a global load level $\Delta P_n^{\Sigma CL}$ and duration $T_n^{\Sigma CL}$ for the control phase. If a power decrease ($u_{n,t}^{\Sigma CL-}$) or increase ($u_{n,t}^{\Sigma CL+}$) for the cluster n is triggered at time t (i.e. variables set to 1 by the management), all the loads in cluster n (i.e. $b \in n$) will adapt their profiles according to a predefined individual level Δp_b^{CL} as presented in Figure 4. Equation (17) ensures that power uprate and derate within each cluster do not occur simultaneously while (18) allows controlling the shift phase duration with only one load shifting occurring each day ((19)).

$$u_{n,t}^{\Sigma CL+} + u_{n,t}^{\Sigma CL-} \leq 1 \quad (17)$$

$$u_{n,t}^{\Sigma CL+} - u_{n,t-1}^{\Sigma CL+} \leq \frac{1}{T_n^{\Sigma CL}} \times \sum_{i=t}^{t+T_n^{\Sigma CL}-1} u_{n,i}^{\Sigma CL+} \quad \text{and} \quad u_{n,t}^{\Sigma CL-} - u_{n,t-1}^{\Sigma CL-} \leq \frac{1}{T_n^{\Sigma CL}} \times \sum_{i=t}^{t+T_n^{\Sigma CL}-1} u_{n,i}^{\Sigma CL-} \quad (18)$$

$$\sum_{t \in T} u_{n,t}^{\Sigma CL+} = \sum_{t \in T} u_{n,t}^{\Sigma CL-} = T_n^{\Sigma CL} \quad (19)$$

Figure 4:Control of loads at buses b' and b'' in cluster n

3) Total bus power balance

The power balance at each bus is computed according to (20) as the difference between both centralized and distributed generation at bus and its instantaneous load ($P_{b,t}^L$). Note that incidence matrices are needed to map the DG assets in the grid and test different configuration. Also the equality between constraints (13) and (20) allow to compute a Lagrangian that directly aggregates energy, congestion and loss costs (carbon costs here) where other approximation of the losses would require additional post processing. The MILP formulation of that optimal management (denoted OM) is finally written using YALMIP toolkit [35] and solved with CPLEX 12.7.1 (16 threads in parallel, 16 GB RAM, 3.2 GHz processor).

$$P_{b,t}^{\Sigma} = P_{b,t}^{CG} - P_{b,t}^L + P_{b,t}^{PV} - P_{b,t}^{PV-} - P_{b,t}^{ST-} + P_{b,t}^{ST+} + \Delta p_{b \in n}^{CL} \times (u_{n,t}^{CL+} - u_{n,t}^{CL-}) + P_{b,t}^{DU} \quad (20)$$

GRID CLUSTERING AND REDUCED COMPUTATIONAL TIME WITH ZONAL APPROACH

A. Computational Time Reduction

Preliminary runs of the OM converged for different configurations of the DG assets in the considered system. However, in some cases the computational time exceeded the arbitrary limit set to 5 minutes. If a couple of minutes/hours computation would not be an issue for a day ahead scheduling problem they can become prohibitive if the OM has to be run successively a great number of times as it is the case in the DG planning iterative strategy chosen here (i.e. hundreds/thousands runs). A grid clustering approach is then considered in this section in order to furtherly reduce the computational time of the implemented OM. As already mentioned in the introduction, such clustering methods are often used to reduce the amount of input information while reducing a whole year to a sample of representative time step. Other approaches consist in aggregating the generation unit of same type or displaying close characteristics. In this paper, the clustering lies in a network partitioning (bus clustering) and the considered power system is disaggregated in smaller microgrids. The previously developed OM can then be run faster in

each of those microgrids with a reduced numbers of variables while additional operations should ensure to maintain boundary conditions at the points of connection between the clusters.

B. Electrical Network Partitioning

The clustering method applied to the Jurong Island power system consists in a regular K-means algorithm [36] hybridized with a standard genetic algorithm similarly to [37]. The first step of the network partitioning is to define the way to compute the “electrical” distance between the buses. A typical approach consists in considering the line impedance with the bus impedance matrix $\mathbf{Z}^{\text{bus}}$. A modification is introduced in order to encourage the buses to be aggregated accordingly to their voltage level if the pre-defined number of clusters is high enough. A penalty coefficient λ (set to 10^3) is considered and the distance $d_{b'b''}$ between two buses b' and b'' is finally computed following (21) if there is an existing branch between the buses. With highly sparse matrices for radial systems the cluster connectedness might not ensure when running a typical K-means [38]. Thus the distance between two buses b' and b'' with no direct link (i.e. connection line/transformer) needs to be modified. The shortest path in terms of impedance is then considered using Dijkstra's algorithm. That formulation leads to a distance matrix with no null coefficients. The cluster connectedness is automatically guaranteed as the distance computation with the Dijkstra's algorithm lies on the summation of serial impedances.

$$\begin{cases} d_{b'b''} = \mathbf{Z}_{b'b''}^{\text{bus}} & \text{if } V_{b'} = V_{b''} \\ d_{b'b''} = \lambda \times \mathbf{Z}_{b'b''}^{\text{bus}} & \text{if } V_{b'} \neq V_{b''} \end{cases} \quad (21)$$

The idea of the hybridized K-means is to use the genetic algorithm to generate different sets of clusters centers (i.e. n buses defined as centers clusters K_n). Regular K-mean clustering is then performed for each set of centers before estimating the clustering performances which is computed as the aggregation of two indexes ((22)). On one hand the clustering tightness index (CTI in $[0,1]$) measures the extent to which each bus is proximate to the other members in the same cluster Then the cluster size index (CSI in $[0,1]$) tends to estimate the homogeneity of the clusters with s_n the size of the cluster containing bus b and $\#$ the cardinal function. Those two indices are gathered into a single objective K_{obj} with weights $\alpha = 2$ and $\beta = 1$ here. As displayed in Figure 5 the use of the genetic algorithm allow obtaining good performances with all the indexes close to unity for ten clusters or more.

$$CTI = 1 - \frac{\sum_{b' \in B} \sum_{b'' \in K_n} d_{b'b''}}{\sum_{b \in B} \sum_{b' \in B} d_{b'b'}} \quad , \quad CSI = e^{-\left(\frac{\#(B)}{n} - \ln \sum_{b \in B} \frac{s_n}{\#(B)} \right)^2} \quad , \quad K_{obj} = CTI^\alpha \times CSI^\beta \quad (22)$$

Figure 5: Clustering results – a) one run of K-means – b) hybridized K-mean – c) partitioning for 10 clusters

C. Modified Optimal Management

Figure 6a shows the results for a grid partitioning with ten clusters n each of them containing buses b and lines l that are subsets of the original B and L – denoted $b \in n$ and $l \in n$. Once the network partitioning is done, the overall system can be modeled using a zonal representation where each cluster is identified with an equivalent bus $b_n \in B_n$ and the different buses are connected through lines $l_n \in L_n$ that are a subset of L (Figure 6b). The zonal representation obviously corresponds to a much simpler system with a 208 buses / 210 branch system being reduced to a 10 buses / 10 branch model. Then that subsection describes a 3 steps method in order to take advantages of the zonal representation to lower the computation time of the OM when different configurations of DG assets are investigated.

Figure 6: Network partitioning for $N = 10$ clusters – a) nodal representation – b) zonal representation

1) Step 1 : Optimal management over the zonal modelConventional DG assets

The first step consists in running the OM method previously describe for the zonal representation of the model. The mathematical formulation does not need to be modified, except that the original buses and branches sets (B and L) have to be

substituted with B_n and L_n in the equations. However, a modification of some of the input parameters is required in order to aggregate the load, the PV generation as well as the rated power/capacity for the storage systems and distributed CCGT units following (23). Thus each of those resources will be represented by a single equivalent asset at every bus b_n . Note that the centralized units on site are not aggregated and, as previously, control variables will be considered for each of them. Also the controllable loads were defined to be aggregated in clusters. Thus the power magnitude of the control phase at each equivalent bus b_n corresponds to the cluster predefined control level $\Delta P_n^{\Sigma CL}$. Finally, the power balance constraint at each bus (20) can be rewritten as in (24) for better understanding.

$$\begin{cases} P_{b_n,t}^L = \sum_{b \in n} P_{b,t}^L \\ P_{b_n,t}^{PV} = \sum_{b \in n} P_{b,t}^{PV} \\ P_{b_n}^{STmax} = \sum_{b \in n} P_b^{STmax} \quad \text{and} \quad E_{b_n,t}^{STmax} = \sum_{b \in n} E_b^{STmax} \\ P_{b_n}^{DUmin} = \min_{b \in n} (P_b^{DUmin}) \quad \text{and} \quad P_{b_n}^{DUmax} = \sum_{b \in n} P_b^{DUmax} \end{cases} \quad (23)$$

$$P_{b_n,t}^{\Sigma} = \sum_{b \in n} P_{b,t}^{CG} - P_{b_n,t}^L + P_{b_n,t}^{PV} - P_{b_n,t}^{PV-} - P_{b_n,t}^{ST-} + P_{b_n,t}^{ST+} + \Delta P_n^{\Sigma CL} \times (u_{n,t}^{CL+} - u_{n,t}^{CL-}) + P_{b_n,t}^{DU} \quad (24)$$

The OM run for the defined zonal model is much faster than for the nodal representation of the whole system with many less variables. That number of variables in the OM is never fixed and depends on the considered DG configuration, the number of distributed assets for each resource. The outputs of that first step are the control variables for the centralized and aggregated DG assets as well as the power flows in lines L_n . Those flows time profiles denoted $F_{l_n,t}^{+*}$ and $F_{l_n,t}^{-*}$ define the energy exchange (i.e. import/export) between the cluster (i.e. the equivalent buses b_n). However, the obtained results for the zonal model would diverge from the ones computed for the complete system as losses and congestion issues within each cluster are not considered.

2) Step 2 : Optimal management within each cluster

A second step is implemented in order to refine the results inside every cluster with the OM run successively for each of them. Once again the mathematical formulation of the optimization problem does not require major modifications. The same equations are considered with subsets of B and L corresponding to every cluster (i.e. considering $b \in n$ and $l \in n$). The DG assets are not aggregated and their nodal position and individual control variables are considered when computing the power balance constraint at each bus. However, the bus injection constraint (13) with the line import/export is modified when considering the buses $b \in n$ that have a direct connection line with another cluster (L_n). The equation is modified following (25) in order to ensure that the cluster n exports the amount of energy predicted by the previous steps with the power flows profiles

$F_{l_n,t}^{+*}$ (for l_n leaving cluster n) and $F_{l_n,t}^{-*}$ (for l_n arriving at cluster n). On the contrary, imported flows $F_{l_n,t}^{+}$ (for l_n arriving cluster n) and $F_{l_n,t}^{-}$ (for l_n leaving cluster n) remain free variables subject to constraint (26) in order to ensure the convergence of the OM while compensating clusters losses or any deficit of local generation. A term is also added to the objective function of the OML with a penalty coefficient λ (typically $\lambda = 10^6$) to keep the import of energy from the other cluster as low as possible and encourage the local generation (for both centralized and decentralized assets) ((27)).

$$P_{b \in n, t}^{\Sigma} = \sum_{\substack{l \in n \\ \text{from} \\ b \in n}} \left(F_{l,t}^{+} + \frac{\delta F_{l,t}^{+}}{2} \right) - \left(F_{l,t}^{-} - \frac{\delta F_{l,t}^{-}}{2} \right) - \sum_{\substack{l \in n \\ \text{to} \\ b \in n}} \left(P_{l,t}^{+} - \frac{\delta F_{l,t}^{+}}{2} \right) - \left(P_{l,t}^{-} + \frac{\delta F_{l,t}^{-}}{2} \right) + \sum_{\substack{l_n \text{ from} \\ b \in n}} (F_{l_n,t}^{+*} - F_{l_n,t}^{-}) - \sum_{\substack{l_n \text{ to} \\ b \in n}} (F_{l_n,t}^{+} - F_{l_n,t}^{-*}) \quad (25)$$

$$\begin{cases} F_{l_n,t}^{-} \geq F_{l_n,t}^{-*} \text{ for lines leaving cluster } n \\ F_{l_n,t}^{+} \geq F_{l_n,t}^{+*} \text{ for lines arriving at cluster } n \end{cases} \quad (26)$$

$$obj \leftarrow obj + \lambda \times \sum_t \left(\sum_{\substack{l_n \text{ from} \\ b \in n}} P_{l,t}^{-} + \sum_{\substack{l_n \text{ to} \\ b \in n}} P_{l,t}^{+} \right) \quad (27)$$

Once the second step is performed, the net load for each cluster n ($P_{b_n,t}^{Net}$) can be computed considering the load and optimal generation profiles at each buses ($b \in n$) as well as the losses computed over the cluster lines ((28)).

$$P_{b_n,t}^{Net} = \sum_{b \in n} P_{b,t}^L - \sum_{b \in n} P_{b,t}^{CG} - P_{b_n,t}^{PV} + P_{b_n,t}^{PV-} + P_{b_n,t}^{ST-} - P_{b_n,t}^{ST+} - \Delta p_b^{CL} \times (u_{n,t}^{CL+} - u_{n,t}^{CL-}) - P_{b,t}^{DU} + \sum_{l \in n} \sum_{w \in W} \alpha_{w,l}^{\delta F} \times (f_{w,l,t}^{+} + f_{w,l,t}^{-}) \quad (28)$$

3) Step 3 : Optimal management within each cluster

A final OM is run for the zonal representation while considering the net load profiles for the clusters (buses b_n). the power balance constraint at each bus (20) is modified following (29). No DG assets are considered in this step as their operation is already implied in the computation of the cluster net load. That last runs aims at balancing the system losses and the cluster import/export with the centralized CCGT units. The sequential optimal management strategy is denoted as S-OM and is summarize in Figure 7.

$$P_{b_n,t}^{\Sigma} = \sum_{b \in n} P_{b,t}^{CG} - P_{b_n,t}^{Net} \quad (29)$$

Figure 7: Architecture of the sequential optimal management (S-OM)

VALIDATION RUNS AND SAMPLE RESULTS

A. Power Plant operations

In this section 4, validation tests for the implemented methods (OM and S-OM) are presented along with preliminary results for different DG configurations. Note the DG planning procedure is not in the scope of that paper. Thus the DG configurations that will be considered are not optimal and are only use to estimate the sensitivity of the objective function for different scenarios. The first set of simulations is run with no DG assets connected to the system. The objective is to verify the validity of the constraints in Section 2.C. that ensure appropriate operations of centralized power plants displaying several units of the same type. Figure 8 shows the results for the generation of the Sembcorp power plant with its two units of type *D* when the constraints are inactive (Figure 8a) and activate (Figure 8b). As expected, the introduction of the power plant constraints allows to smooth the generating profiles while the value objective function remains unchanged (i.e. tons of CO_2). Note that the overall power plant generation is consistent with for the greatest part of the day. The differences observed for the last two time steps are compensated by the same type of units in another power plant. Also note that the avoidance of multiple ripples in the units' power profile could have been done with the introduction of ramping cost that are not considered here.

Figure 8: Sembcorp plant operation – a) inactive constraints – b) active constraints

B. Line Losses

Another set of simulations aims at validating the estimation of the line losses compared to an iterative reference method (Jump and Shift method here [23]). Several runs of the OM with 1 block ($W=1$) and 2 block ($W=2$) are performed for the Jurong Island systems as well as for the IEEE 30-bus and 57-bus test cases. As previously, those test runs do not consider any DG connected to the system. Also the possibility to “correct” the outputs of the OM is considered with a sequential AC OPF. Like for the Jump & Shift method, those OPF are run for every time step while updating the bounds for the units generation around the power profiles returned by the OM (a tolerance of 5 % is considered here). Table 2 displays the obtained results computational times are reduced using the OM with linearized losses. The error in the objective function (i.e. CO₂ emissions) is very low, under 0.5 %, while the active losses difference is around 5 %. Running a sequential AC OPF after the OM (with $W=2$) allows adjusting the results and the obtained solution is even slightly better than the one returned by the Jump and Shift method.

Table 2 : Obtained Results for Jurong Island System

	Jump Shift	OM ($W=1$)	OM ($W=2$)	OM ($W=2$) + AC OPF
Jurong Island Power System – 13 units				
Tons of CO ₂	26119	26116	26114	26118
Losses (MWh)	219	211	206	219
CPU Time (sec)	63	6	8	13
IEEE 30 buses – 6 units				
Tons of CO ₂	1701	1681	1698	1699
Losses (MWh)	59	36	52	55
CPU Time (sec)	38	3	7	10
IEEE 57 buses – 7 units				
Tons of CO ₂	11136	11036	11113	11132
Losses (MWh)	309	275	286	300
CPU Time (sec)	51	9	23	28

The simulations also allow the analysis of the power flowing through the lines along the day for the different systems. Results for the IEEE 30-bus test case in Figure 9 show consistent power flows in the branches computed with the OM ($W = 2$) before and after the application of a sequential AC OPF (Figure 9a) (MW for UCLL₂ and MWA after AC OPF). Greater differences are observed when considering active losses with deviations either positive or negative (Figure 9b). However, it is noticeable that the rank of the least efficient branches is fully respected which is important when allocation problems are investigated. Indeed, the UCLL will prove able to properly discriminate two configurations (in terms of losses) where the same DG unit is connected to two different buses.

Figure 9: IEEE 30-bus results— a) line power – b) line losses

C. Computational Times

The next validation tests investigate the computational times for different DG configuration while comparing the performance of the firstly developed ON and the sequential version (S-OM). At first, twenty random distributions of PV installations and distributed CCGT units (DU) are tested with different capacities and allocations. The results displayed in Figure 10a show good consistency while computing the emissions with the two optimization procedures. The recorded computational times are similar. The S-OM is slightly faster while the regular OML encounters one case where the arbitrary 5 minutes limit of time is reached. The OM also exceeds the time limit for one case when distributed storage is added to the investigated DG configurations. With the introduction of storage assets, the S-OM tends to be slower than the OM (when the convergence is reached) while the results in terms of emissions are still consistent (Figure 10b). When controllable loads are considered with PV and DU the emissions computed with the two methods display greater deviations. Especially the rank of the “cleanest” DG distribution is not fully

respected any more (Figure 10c). However, the regular OM reaches the maximum computational time in most of the cases and the associated results might be sub optimal. The S-OM overcomes that difficulty, allowing a faster convergence with lower CO₂ emissions in most cases.

Figure 10: Comparison between OM and S-OM – a) PV and DU – b) PV, DU and BAT – c) PV, DU and CL.

D. DG configurations

1) Base Case Scenario

The last set of simulation focuses on the performances of different DG configuration regarding the objective of CO₂ reduction compared to a base case scenario in which only the centralized generation on site is considered while running the OM (with $W = 2$ here). As already displayed in Table 2, the simulated day corresponds to 26116 tons of CO₂ emitted, with an equivalent grid emission factor of 413 kg/MWh. That value is close to the official 431 kg/MWh estimated by the Singaporean energy authority for the year 2015 [2]. The difference can be explained by the 5 % of energy generated from old, dirtier oil power plants in Singapore, which is included in the official statistics. Regarding the plant generation the bulk load is provide by the cleanest units (type A in Keppel and type C in Seraya) while the dirtier generator are started up to supply the peak demand (Figure 11b). The system displays very low losses equals to 0.35 % when computed over the entire day (Figure 11a). Note that only higher voltage lines are considered here. The total grid losses (transmission/distribution) in Singapore is estimated around 2 % according to the International Energy Agency. Those low values are explained by the low impedance underground cables on site as well as by the short distances between the nodes.

Figure 11: Power profiles for the base case scenario– *a)* load and generation – *b)* plants operation

2) *Conection of DG assets on a test feeder*

A first set of simulations is performed considering the 20 MVA rated feeder connecting the buses 165-168 (Figure 2a). Once again, the tests do not imply any optimal DG size/site. Here the idea is to validate the problem formulation for an arbitrary chosen feeder. Different DG resources are successively connected to the nodes and results are estimated regarding the overall CO₂ emissions and losses reduction within the feeder. For the base case (**S0**) the feeder is loaded according to the buses consumption profiles along the day for a total of 4.3 MWh losses. Then a scenario (**S1**) is simulated with the connection of a 30 MWc PV plant to node 168. That peak power is at an arbitrary high value (greater than the feeder capacity which is not realistic) in order to validate the generation curtailment in case of important surplus of production. In practice, most of the generation is self-consumed by the local loads and the surplus flows upstream to the main grid (Figure 12a). Losses within the feeder are significantly reduced (more than 25 %) as a result of the shortened distance between the generation and the load point (Table 3). Adding a 1 MW/5 MWh storage to the same bus (**S2**) does not improve the performance much with a net load slightly reduced during short periods (Figure 12a). A cluster of controllable loads is then considered (**S3**) with 1MW shifted at nodes 165, 166 and 167 for 3 hours (Figure 12b). As expected the load is increased when the PV peak occurs. It leads to less energy exported to the grid, which corresponds to reduced losses in the feeder. Once again the benefits are not significant and many more loads should be controlled to get a real impact on CO₂ reduction. A last simulation is performed with the addition of a 5 MW distributed CCGT unit at bus 165 (**S4**). The optimal profiles returned by the OM method logically correspond to full-time operation of the distributed clean CCGT unit (Figure 12b) to lower the overall emissions.

Table 3 : DG connected to the tested branch

	S0	S1	S2	S3	S4
CO ₂ (tons)	26114	26056	26055	26054	26029
Losses (MWh)	4.3	3.0	2.9	2.7	1.8

Figure 12: Feeder load – a) S0, S1 and S2 – b) S3 and S4

3) *Impact of DG size and site*

Additional simulations are run with increasing DG capacities. For each type of DG resources, the installed capacity is distributed among five arbitrary buses (Figure 2a). Storage units are given with a power/energy ratio equal to one and a single cluster aggregates the load controlled at the test buses. As previously observed, photovoltaic and distributed CCGT units have the most significant impact on the carbon cost, with reduced system losses (Figure 13a). Both emissions and losses tend to decrease linearly as more capacity is installed. There is no major improvement when only controllable loads or energy storage are considered, even with greater capacities involved. Indeed, those two resources only allow shifting consumption through time and they cannot directly contribute to carbon reduction by themselves when a given amount of energy has to be consumed along the day. However, a slight improvement is observed with capacities above 15 MW. In those cases, the resources provide enough flexibility to allow a small benefit from the arbitrage between dirtier and cleaner CCGT centralized units. Typically, generation from the cleanest units is increased at night time and the reduced consumption during the day allows minimizing the time period where dirtier technologies are committed. The gain in terms of tons of CO₂ is then directly linked to the carbon cost difference between the different type of units. With only one type of fuel considered here (i.e. natural gas) the costs are very close to each other, which explains the almost non observable improvement. Note that the efficiency attached to storage units lead to increased losses even if the overall carbon cost is lower than in the base case scenario (Figure 13b). The DG resource siting is then investigated by distributing a same amount of DG capacity (30 MW) among different nodes. Twenty random sets of buses considered - sets of one, three, five and ten buses. As previously observed the carbon emissions decrease proportionally to losses when PV units are investigated (Figure 14a). However, the PV siting does not have any impact on the system performance, with a variation less than a ton (i.e. < 0.01 %) over the twenty simulated scenarios. It becomes a little more significant when allocation

of decentralized CCGT units is studied. In particular, distributing the capacity among several buses seems to correspond to slightly improved performance (around 1 %) (Figure 14b).

Figure 13: Impact of DG size at 5 arbitrary test buses– a) CO₂ emissions for different capacities – b) losses for different capacities

Figure 14: Impact of DG sites– a) different PV locations – b) different DU locations

A last set of simulations is performed with different sizes/sites considering only the distributed photovoltaic and storage devices. Different number of units of 10 MWp (for PV) and 10 MWh (for ST) are randomly distributed among the Jurong Island system in order to reach the total distributed capacities (denoted ST_{tot} and PV_{tot}). Note that the considered capacities are unrealistic regarding the available space on Jurong Island and that those simulations should be considered as a partial sensitivity analysis. As already noticed in the previous simulations the improvements in terms of CO₂ reduction are not significant. Indeed the results displayed in Table 4 show around 1 % reduction for every 100 MWp of PV installed – which is in the range of the total installed capacity currently installed in the whole Singapore. The impact of the storage is even more limited less than 0.5 % reduction for 500 MWh! The results are the same when storage units are connected at the same buses as the PV plant and with the same capacities ($PV_{tot} = ST_{tot}$ in Table 4).

Table 4 : CO₂ emisiosn for fdiffenrt PV and ST configurations

PV_{tot} \ ST_{tot}	0 MWh	100 MWh	200 MWh	300 MWh	400 MWh	500 MWh
0 MWp	26114	26070	26042	26031	26030	26023
100 MWp	25914	25869	25830	25818	25640	25545
200 MWp	25704	25645	25251	25250	25251	25251
300 MWp	25503	25065	25049	25063	25048	25041
400 MWp	25073	24866	24848	24848	24847	24841
500 MWp	24720	24698	24648	24649	24648	24640
PV_{tot}=ST_{tot}	26114	25870	25250	25048	24848	24640

Those low improvements are explained by the nature of the considered Jurong Island power system. Especially, there is no energy mix regarding the centralized generation with all the CCGT units fueled with natural gas. As displayed on [Figure 2b](#) the performances of the units in terms of CO₂ emissions are close. Thus if DG allow reducing the generation of the “dirtiest” unit, improvement will not be significant. Also the rated power of the centralized unit (around 400MW each) is high regarding the load level (3GW). It means that important levels of DG should be installed in order to cover the contribution of a single unit and avoid starting it which might be unrealistic as observed in [Table 4](#). The uselessness of storage device can be more specifically explained with the optimal scheduling problem that does not consider any time varying parameters (e.g. time of use or real time prices). The objective function is only the amount of CO₂ for the power generation and the interest of using storages to perform arbitrage thought time is limited here. The main contribution of storage unit would be to shave the overall peak demand in order to reduce the generation of the “dirtier” unit. However, once again the absence of energy mix with similar generator limit the expected improvements in terms of CO₂ savings.

CONCLUSIONS

The method developed in this paper presents an optimal energy management of a power system in the presence of different types of DG resources and with the centralized generation already installed on site. The case study refers to the Jurong Island in Singapore. A particular attention is attached to the computational time of the procedure as that management loop aims at being integrated in a DG planning method that would require to test many configurations of the DG assets. At first, the use of a modified DC OPF implemented in the form of MILP problem avoids computational complexity. Especially, the method lies in a piecewise linearization of the lines losses that has been validated over several systems (Jurong Island and IEEE test cases) and compared to another method with AC OPF constraints taken as the reference. In a second time a clusterised version of the optimal management is developed once a generic method is developed for network partitioning. Validation us showed that the clusterized method allow to reduce the computational time and the convergence before an arbitrary limit of five minutes. The implementation

of the DG optimal planning is not in the scope of the paper. However, some simulations have been performed in order to estimate the improvement in terms of CO₂ reduction depending on the DG types, sizes and sites. If the obtained results validated the implemented models and constraints, they did not show significant improvements compared to a base case scenario in which only the centralized generation on site is considered. That is directly linked to the nature of the Jurong Island power system with very low losses and only gas fueled units (i.e. no generation mix). Considering objective function with other parameters such as operating costs or carbon taxes might create more space for improvements. That should be part of further works as well as the integration of the management strategy in a design procedure in order to find the best DG configuration.

REFERENCES

- [1] R. Rigo-Mariani, K. V. Ling, J. Maciejowski, "A generic method to model CO₂ emission Performances of combined cycle power plants for environmental unit commitment", *Energy Technology*, 2017.
- [2] Energy Market Authority, *Singapore Energy Statistics*, 2016 <http://www.ema.gov.sg>
- [3] P. Prakash, D. K. Khatod, "Optimal sizing and siting techniques for distributed generation in distribution systems: A review", *Renewable and Sustainable Energy Reviews*, vol. 57, pp. 111–130, 2016.
- [4] A. R. Jordehi, "Allocation of distributed generation units in electric power systems: A review", *Renewable and Sustainable Energy Reviews*, vol. 56, pp. 893–905, 2016.
- [5] P. Paliwal, N. P. Patidar, R. K. Nema, "Planning of grid integrated distributed generators: A review of technology, objectives and techniques", *Renewable and Sustainable Energy Reviews*, vol. 40, pp. 557–570, 2014.
- [6] N. Acharya, P. Mahat, N. Mithulananthan, "An analytical approach for DG allocation in primary distribution network", *Electrical Power and Energy Systems*, Vol. 28, pp. 669–678, 2006.
- [7] S. Ghosh, S.P. Ghoshal, S. Ghosh, "Optimal sizing and placement of distributed generation in a network system", *Electrical Power and Energy Systems*, Vol. 32 pp. 849–856, 2010.
- [8] M. Nayeripour, E. Mahboubi-Moghaddam, J. Aghaei, A. Azizi-Vahed, "Multi-objective placement and sizing of DGs in distribution networks ensuring transient stability using hybrid evolutionary algorithm", *Renewable and Sustainable Energy Reviews*, Vol. 25, pp. 759–767, 2013.
- [9] R. Prenc, D. Skrlac, V. Komen, "Distributed generation allocation based on average daily load and power production curves", *Electrical Power and Energy Systems*, vol. 53, pp. 612–622, 2013.
- [10] G. Vigano, M. Rossi, D. Moneta, C. Carlini, "Methodology for the optimal siting and sizing of storage systems in distribution networks", *AEIT International Annual Conference*, Naples, Italy, 2015.
- [11] F. Abbasi, S. M. Hosseini, "Optimal DG allocation and sizing in presence of storage systems considering network configuration effects in distribution systems", *IET Generation, Transmission & Distribution*, Vol. 10, No. 3, pp. 617–624, 2016.
- [12] D. H. Popovic, J. A. Greatbanks, M. Begovic, A. Pregelj, "Placement of distributed generators and reclosers for distribution network security and reliability", *Electrical Power and Energy Systems*, Vol. 27, pp. 398–408, 2005.
- [13] T. Gozel, M. H. Hogaoglu, U. Eminoglu, A. Balikci, "Optimal Placement and Sizing of Distributed Generation on Radial Feeder with Different Static Load Models", *International Conference on Future Power Systems*, Amsterdam, Netherlands, 2005.
- [14] M. R. Vallem, J. Mitra, "Siting and sizing of distributed generation for optimal microgrid architecture", *37th Annual North American Power Symposium*, 2005.
- [15] L. F. Ochoa, C. J. Dent, G. P. Harrison, "Distribution network capacity assessment: variable DG and Active networks", *IEEE Trans. on Power Systems*, Vol. 25, No. 1, pp. 87–95, 2010.
- [16] S. Porkar, P. Poure, A. Abbaspour-Tehrani-Fard, S. Saadate, "Optimal allocation of distributed generation using a two-stage multi-objective mixed-integer-nonlinear programming", *European Transactions on Electrical Power*, Vol. 21, pp. 1072–1087, 2011.
- [17] H. Pandžić, Y. Wang, T. Qiu, Y. Dvorkin, D. S. Kirschen, "Near-optimal method for siting and sizing of distributed storage in a transmission network", *IEEE Transactions on Power Systems*, vol. 25, no. 1, pp. 2288–2300, 2015.
- [18] J. Stich, T. Massier, "Enhancing the integration of renewables by trans-border electricity trade in ASEAN", *IEEE PES Asia-Pacific and Energy Engineering Conference*, 2015.
- [19] H.K. Fathy, J.A. Rey, P.Y. papalambos et A.G. Ulsoy, "On the coupling between the plant and controller optimization problems", *American Control Conference*, Arlington, 2001.
- [20] F. Ugrandi, E. Karatepe, "Optimal wind turbine sizing to minimize energy loss", *Electrical Power and Energy Systems*, Vol. 53, pp. 656–663, 2013.
- [21] G. Celli, S. Mocci, F. Pilo, M. Loddo, "Optimal integration of energy storage in distribution networks", *IEEE Bucharest Power Tech Conference*, June 28th - July 2nd, Bucharest, Romania, 2009.
- [22] F. Rotaru, G. Chicco, G. Grigoros, G. Cartina, "Two-stage distributed generation optimal sizing with clustering-based node selection", *Electrical Power and Energy Systems*, Vol. 40, pp. 120–129, 2012.
- [23] S. X. Chen, H. B. Gooi, "Jump and shift method for multi-objective optimization", *IEEE Trans. On Industrial Electronics*, vol 58, no 10, pp 4538–4548, 2011.
- [24] F. Li, R. Bo, "DCOPF-Based LMP Simulation: algorithm, comparison with ACOPF, and sensitivity", *IEEE Transaction on Power Systems*, Vol. 22, No. 4, pp. 1475–1485, 2007.
- [25] L. Zhang, T. Capuder, Member, P. Mancarella, "Unified unit commitment formulation and fast multi-service LP model for flexibility evaluation in sustainable power systems", *IEEE Transactions in Sustainable Energy*, Vol. 7, No. 2, 2016.

- [26] B. S. Palmintier, M. D. Webster, "Heterogeneous unit clustering for efficient operational flexibility modeling", Power & Energy Society General Meeting, National Harbor, United States, 2014.
- [27] K. Van den Bergh, K. Bruninx, E. Delarue, W. D'haeseleer, "A Mixed-Integer Linear Formulation of the Unit Commitment Problem", KU Leuven, TME working paper, 2014. [Online] Available: https://www.mech.kuleuven.be/en/tme/research/energy_environment/Pdf/wpen2014-07.pdf.
- [28] M. Carrión, J. M. Arroyo, "A computationally efficient mixed-integer linear formulation for the thermal unit commitment problem", IEEE Trans. On Power Systems, vol 21, no. 3, pp 1371-1378, 2006.
- [29] M. P. Boyce. "Handbook for cogeneration and combined cycle power plants", ASME Press (2nd ed), 2010.
- [30] F. Li, "Fully reference-independent LMP decomposition using reference-independent loss factors", Electrical Power Systems Research, Vol. 81, pp. 1995-2004
- [31] H. Seifi, M. S. Sepasian, "Electric Power System Planning – Issues, Algorithms and Solutions", Springer, ISSN 16121287, New-York, 2011.
- [32] <http://pwwatts.nrel.gov>
- [33] S. W. Alnaser, L. F. Ochoa, "Optimal sizing and control of energy storage in wind power rich distribution networks", IEEE Transactions on Power Systems, Vol. 31, No. 3, pp. 2004-2013, 2016.
- [34] K. Kok, S. Widergren, "A society of devices : integrating intelligent distributed resources with transactive energy", IEEE Power and Energy Magazine, Vol. 14, No. 3, pp. 34-45, 2016.
- [35] J. Lofberg, "YALMIP: a toolbox for modelling and optimization in MATLAB", IEEE International Symposium on Computer Aided Control Systems Design, New-Orleans, USA, 2004, pp. 282-289.
- [36] A. K. Jain, "Data clustering: 50 years beyond K-means", Pattern Recognition Letters, vol 31, pp. 651–666, 2010.
- [37] S. Blumsack, P. Hines, M. Patel C, Barrows, E. Cotilla Sanchez, "Defining power network zones from measures of electrical distances", Power & Energy Society General Meeting, Calgary, Canada, 2009.
- [38] E. Cotilla Sanchez, P. Hines, Barrows, S. Blumsack, M. Patel C, "Multi-attribute partitioning of power networks based on electrical distance", IEEE Transactions on Power Systems, vol. 28, no. 4, pp. 4979–4987, 2013.
- [39] M. Nick, R. Cherkaoui, M. Paolone, "Optimal allocation of dispersed energy storage systems in active distribution networks for energy balance and grid support", IEEE Transactions on Power Systems, Vol. 29, No. 5, pp. 2300–2310, 2014.
- [40] W. El-Khattam, K. Bhattacharya, Y. Hegazy, M. M. A. Salama, "Optimal investment planning for distributed generation in a competitive electricity market", IEEE Transactions on Power Systems, Vol. 19, No. 3, pp. 1674–1684, 2004.
- [41] G. Muñoz-Delgado, J Contreras, J. M. Arroyo, "Joint expansion planning of distributed generation and distribution networks", IEEE Transactions on Power Systems, Vol. 30, No. 5, pp. 2579–2590, 2015.
- [42] R. K. Singh, S. K. Goswami, "Optimum siting and sizing of distributed generations in radial and networked systems", Electric Power Components and Systems, Vol. 37, pp. 127–145, 2009.
- [43] S. W. Alnaser, L. F. Ochoa, "Optimal sizing and control of energy storage in wind power rich distribution networks", IEEE Transactions on Power Systems, Vol. 31, No. 3, pp. 2004–2013, 2016.

ACKNOWLEDGEMENT

The authors acknowledge the support by the Singapore National Research Foundation under its Campus for Research Excellence And Technological Enterprise (CREATE) programme and the Cambridge Centre for Advanced Research in Energy Efficiency in Singapore Ltd (CARES).

Ref	System size	Load level	Objectives	AC / DC model	Method
[11]	33 bus	1 snap	Bi objective - cost and losses	AC	Multi objectives genetic algorithm (NSGA II) for multiple DG site/size
[9]	30 bus	1 day	Minimize losses	AC	Integrated – Sequential AC OPF and GA for multiple DG resources size/site
[17]	96 bus	1 year	Minimize capital and operating cost	DC	All in one – MILP formulation for storage site/size
[15]	61 bus	1 year	Maximize wind penetration	AC	All in one – Sequential AC OPF with a finite set of scenarios to represent a year for wind turbine size
[6]	69 bus	1 snap	Minimize losses	AC	Analytical function to compute the loss sensitivity factor for single DG site/size
[7]	30 bus	1 snap	Weighted sum - losses and cost	AC	Exhaustive search with ACPF for single DG site/size
[8]	33 bus	1 snap	Weighted sum - losses, reliability and voltage	AC	Hybrid particle swarm optimization for multiple DG site/size
[10]	32 bus	1 day	Minimize losses	AC	Iterative - Monte Carlo simulation with multi period AC OPF for storage site/size
[20]	30 bus	4 days	Minimize losses	AC	Integrated – Sequential AC OPF and GA for multiple wind turbines size/site
[27]	69 bus	1 snap	Minimize losses	AC	Analytical method for single and multiple DG site/size
[22]	24 bus	1 day	Weighted sum - loss and voltage profile	AC	Iterative - Clustering method and sequential AC OPF for PV and CHP site/size
[40]	8 bus	1 day	Minimize capital and operating cost	AC	Heuristic approach to sort the best locations and sequential AC OPF for multiple DG
[12]	114 bus	3 days	Weighted sum - losses, reliability and voltage	AC	Sequential AC OPF and exhaustive search for DG placement, GA for reliability
[13]	13 bus	1 snap	Minimize losses	AC	Exhaustive search of the optimal site mixed with analytical computation of optimal size
[14]	6 bus	1 snap	Minimize cost	DC reliability	+ Simulated annealing for multiple DG site/size
[39]	34 bus	150 snap	Minimize capital and operating cost	AC	All in one - Second order conic programming for storage site/size
[16]	30 bus	1 year	Weighted multi obj - losses and cost	AC	All in one – Sequential AC OPF for multiple DG resources size/site
[18]	87 bus	6 weeks	Minimize capital and operating cost	DC	All in one – LP formulation for multiple DG resources size/site
[41]	138 bus	3 snap	Weighted sum- losses and cost	DC	MILP for both grid (feeder, substations) and DG planning
[31]	17 bus	1 day	Minimize capital and operating cost	DC	Integrated - DP for management loop and GA for design for storage site/size
[42]	30 bus	3 snap	Minimize losses	AC	Genetic algorithm for single and multiple DG site/size
[43]	18 bus	1 day	Minimize renewable energy curtailment	AC	Iterative - Multi period AC OPF for storage site/size
This work	208 bus	1 day	Minimize CO ₂ emissions	DC losses	with Iterative – Estimation of the impact of multiple DG resources (PV, storage , DU and CL)

CHP : COMBINED HEAT AND POWER , NSGA : NON-DOMINATED SORTING GENETIC ALGORITHM, OPF : OPTIMAL POWER FLOW, SNAP : OME LOAD LEVEL (SNAPSHOT)