Real-time Parameters Identification of Lithium-ion Batteries Model to Improve the Hierarchical Model Predictive Control of Building MicroGrids

Daniela Yassuda Yamashita, Ionel Vechiu, Jean-Paul Gaubert

► To cite this version:

Daniela Yassuda Yamashita, Ionel Vechiu, Jean-Paul Gaubert. Real-time Parameters Identification of Lithium-ion Batteries Model to Improve the Hierarchical Model Predictive Control of Building MicroGrids. 2020 22nd European Conference on Power Electronics and Applications (EPE'20 ECCE Europe), Sep 2020, Lyon, France. pp.1-10, 10.23919/EPE20ECCEEurope43536.2020.9215878 . hal-03113129

HAL Id: hal-03113129

<https://hal.science/hal-03113129>

Submitted on 19 Jan 2021

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Real-time Parameters Identification of Lithium-ion Batteries Model to Improve the Hierarchical Model Predictive Control of Building MicroGrids

Daniela Yassuda Yamashita^{a,b}, Ionel Vechiu^a and Jean-Paul Gaubert^b

^aESTIA INSTITUTE OF TECHNOLOGY

Technopole Izarbel – 92, Allée Théodore Monod – Bidart, France

^bLABORATOIRE D'INFORMATIQUE ET D'AUTOMATIQUE POUR LES SYSTEMES (LIAS), UNIVERSITE DE POITIERS

4, Rue Pierre Brousse – Poitiers, France

d.yamashita@estia.fr, i.vechiu@estia.fr, jean.paul.gaubert@univ-poitiers.fr

Acknowledgements

The authors would like to thank the New Aquitaine Region for their financial support.

Keywords

Battery Management Systems (BMS), Control methods for electrical systems, MPC (Model-based Predictive Control), Device modelling, Microgrid

Abstract

Energy storage systems are key elements for enabling the design of MicroGrids in buildings, specially to deal with stochastic renewable energy resources and to promote peak shifting. However, inaccuracies in the batteries' mathematical models due to temperature and ageing effects can reduce the performance of a MicroGrid system. To tackle these uncertainties, this article presents a two-level hierarchical model predictive controller empowered with a data-driven algorithm for real-time model identification of Lithium-ion batteries. The objective is to enhance their state of charge estimation and to make their maximum use without damaging them. The results demonstrate that it improves up to three times the accuracy of state-of-charge estimation and increases about 3% the annual building MicroGrid self-consumption rate. Furthermore, the division of the building MicroGrid energy management system into two hierarchical levels soften the drawbacks arise from the inaccuracies of day-ahead data prediction while reducing the computational cost. The proposed architecture guarantees higher energetic autonomy indexes than a conventional rule-based controller in all scenarios under study.

Introduction

Building MicroGrids (BMGs) are an attractive alternative to foster the integration of renewable energy sources (RESs) into the electrical grid [1]. However, their wide implementation is restrained by the difficulty of designing a generic Energy Management System (EMS) capable of operating under stochastic variations in the power plant. Unpredictability in power generation and power consumption, along with inaccuracy of mathematical models of BMG components lead to the under exploitation of BMG resources or equipment damaging [2].

In the literature, there are various strategies to implement a reliable and efficient EMS [3]. Among the existent strategies, the hierarchical control structure enables to embed algorithms with different complexities at the same time, thanks to the parallel coordination of multiple control layers deployed at different sample time [4]. Concerning the EMS algorithms, those based on model predictive control (MPC) have proved their robustness against environmental disturbances, even with simplified plant model [5]. Nonetheless, there is a lack in evaluating the MPC performance under environmental changes, such as temperature, electric devices ageing and batteries model parameters inaccuracy.

Therefore, this article proposes a two-level Hierarchical MPC (HMPC) with a Real-Time Model Identification (RTMI) module to deal with batteries' parameter inaccuracy. Equipped with photovoltaic (PV) panels and Li-ion batteries, the purpose of the proposed HMPC is to maximise the MicroGrid self-consumption rate (τ_a) [10]. Relying on continuous data measurement and forecast data, the strategy is to optimise its internal power flow by promoting the use of renewables and reducing the energy dependency on the external grid. The results show that the RTMI enhances the State-of-Charge (SoC) estimation, leveraging τ_a and leading HMPC to outperform the traditional rule-based strategy.

Overview of the hierarchical energy management system

The diagram illustrates the overall architecture of the proposed system, showing the interaction between various components:

- RTMI module:** Receives parameters $\alpha_\epsilon, \beta_\epsilon, \gamma_\epsilon$ and predicted consumption $P_{\text{pred cons}}$. It provides $\epsilon = \{cc, dc, \{dd, cd\}\}$ to the EMPC and TMPC blocks.
- EMPC (Energy Management and Planning Control):** Performs day-ahead planning. It receives $P_{\text{pred cons}}$ and provides $S\hat{O}C$ to the TMPC. It sends a weather forecast to the Community Aggregator.
- Community Aggregator:** Manages the grid connection. It receives a weather forecast from the EMPC and provides $S\hat{O}C_{\text{ref}}$ to the TMPC. It negotiates with the Grid.
- Grid:** Connected to the Community Aggregator and the Transformer.
- Transformer:** Connects the Grid to the Smart meter.
- Smart meter:** Provides electricity bill and self-consumption rate data to the Habitant.
- Li-ion Battery:** Receives power consumption P_{bat} from the TMPC. It is connected to the Photovoltaic system and the Load.
- Photovoltaic:** Generates power for the system.
- Load:** Consumes power from the system.
- Habitant:** Receives electricity bill and self-consumption rate data from the Smart meter.
- Measurements:** $[v_{\text{bat}}, i_{\text{bat}}]$ are taken from the battery and sent back to the RTMI module.
- Power consumption & Power grid:** Data is sent back to the RTMI module.

Hierarchical model predictive controller

Considering the fluctuations of the data prediction of both PV power generation and building power consumption (P_{cons}^{pred}), the EMPC determines SoC_{ref} that, within a horizon of $N_h^{EMPC} = 48h$, minimises

the external grid energy dependency. Therefore, the EMPC maximises τ_a defined by (1) and minimises additional energy imports to reduce the cost of purchasing electricity. For this, the cost function defined by (2) is optimised daily ($T_s^{EMPC} = 24h$), in which the total power injected ($P_{injected}$) and the total power purchased ($P_{purchased}$) are minimised. It is noteworthy that the horizon (N_h^{EMPC}) twice bigger than the updating time (T_s^{EMPC}) is to guarantee the most suitable SoC at the end of the day. Doubling the horizon avoids unnecessary complete discharge of batteries at the end of the day since the last half of control variables determined by the EMPC is not implemented.

$$\tau_a = \frac{\text{Total energy produced from RES that is consumed locally}}{\text{Total energy produced from RES locally}} = 1 - \frac{\sum_k P_{injected,k}}{\sum_k P_{PV,k}} \quad (1)$$

$$SoC_{ref} = \arg \left(\min_{SoC_{ref}} \sum_{k=1}^{N_h^{EMPC}=48} P_{injected,k} + P_{purchased,k} \right) \quad (2)$$

Parallely to the EMPC, the TMPC is triggered at each $T_s^{TMPC} = 1h$ to follow the SoC_{ref} as much as possible, considering the updated data prediction and the $\widehat{SoC}$ estimated from the last measurements. To achieve this, the TMPC minimises hourly the cost function defined by (3). The purpose of the TMPC is to reduce the stochastic variation of the day-ahead power imbalance and battery model inaccuracies, by using a shorten horizon, simplifying the optimisation process.

$$P_{bat} = \arg \left(\min_{P_{bat}} \sum_{k=1}^{N_h^{TMPC}=6} (SoC_{ref,k} - \widehat{SoC}_k)^2 \right) \quad (3)$$

Meanwhile, in the background, the EMPC supervises the performance of the TMPC. Every hour, the EMPC compares the accuracy of day-ahead power planning sent to the aggregator (P_{grid}^{ref}) and SoC_{ref} with real measurements. As soon as the absolute difference between them is higher than a predefined threshold – named Δ_{SoC}^{thr} or $\Delta_{P_{grid}}^{thr}$ at time t_{reOpt} – the EMPC determines new SoC_{ref} using the updated prediction data, but with a reduced horizon, as illustrated in Fig. 2. The reduced horizon comprehends the data prediction of the remaining period of the first EMPC optimisation and is equal to $N_h - t_{reOpt}$.

Fig. 2: Re-optimization process of EMPC with reduced horizon.

The main constraints embedded in both EMPC and TMPC are those to respect the recommendations of the French Energy Regulation Commission (ERC) for grid-connected BMGs with PV capacity over 100 kWc [11]. To prevent energy speculation with the local energy storage systems (ESSs) when trading electricity, the ERC allows charging the ESSs only from renewable power generated locally. Additionally, it imposes that $\tau_a \geq 50\%$ at the end of the year [12]. As a result, batteries can be charged (P_{bat}^{ch}) as soon as there is an internal energy surplus, while they can be discharged (P_{bat}^{dis}) when there is an energy deficit, as detailed in (4). Moreover, aiming to extend the life of batteries, the maximum power rate (P_{bat}^{max}) and the SoC limits defined by their manufacturer must be supervised [2], [13]. Consequently, it is important to well estimate future SoC (SoC_{k+1}) and to limit them. Similarly, to maximize τ_a beyond the MPC horizon, the SoC at $k = 48h$ is forced to be higher than 40%.

$$-|\max(P_{bat}^{MAX}, P_{surplus})| \leq P_{bat,k}^{ch} \leq 0; 0 \leq P_{bat,k}^{dis} \leq |\max(P_{bat}^{MAX}, P_{deficit})| \quad (4)$$

Real-time model identification algorithm

Most of the scientific studies [5] estimate SoC_{k+1} through a model composed of time-invariant parameters derived from batteries' technical specification, as formulated in (5). However, based on more realistic models of Li-ion batteries [13], the efficiency during its charge (η_{ch}) or discharge (η_{dis}), the

nominal capacity (Q_{nom}) and the nominal voltage (v_{nom}) change according to the intensity of current, battery age and cell temperature (T_{cell}). According to [7], [9] the voltage variation can be around 10% of the nominal voltage when they are fully charged and discharged. Moreover, the nominal capacity can reach, at the end of their life, up to 80% of its initial value [9]. Consequently, additional uncertainties on SoC_{k+1} estimation arise, which may result in under or overuse of the batteries.

$$SoC_{k+1} = SoC_k + \frac{\eta_{ch} T_s}{v_{nom} \cdot Q_{nom}} \cdot P_{ch,k} + \frac{T_s}{v_{nom} \cdot Q_{nom} \eta_{dis}} \cdot P_{dis,k} \quad (5)$$

Fig. 3: Real-time parameters identification algorithm for a charge and discharge sequence ($\epsilon_k = cd$).

To tackle this issue, the authors designed the algorithm RTMI to improve the estimation of both SoC_{k+1} and their upper (SoC_{max}^{k+1}) and lower boundaries (SoC_{min}^{k+1}). The main objective of this new algorithm is to reduce human intervention for model calibration and BMG maintenance while taking full advantages of batteries. Therefore, the RTMI module updates the parameters of SoC_{k+1} , as illustrated in Fig. 3. The limits SoC_{max}^{k+1} and SoC_{min}^{k+1} are determined to guarantee the operation of the batteries in the linear region, as shown in Fig. 4a.

Fig. 4: RTMI module operation. (a) Discharge curves of a Li-ion battery under temperature cell variations. (b) Model perspective with the three pivot points for predicting the variation of SoC (Δi_t).

The RTMI module determines the parameters α_ϵ , β_ϵ and γ_ϵ of the SoC model defined by (6) and (7) by implementing an unconventional linear regression based on previous data measurements. The variable $\delta_{\epsilon,k}$ is a Boolean variable which is worth 1 when the battery is active and 0 otherwise. Remarkably, equation (7) can be interpreted as four surfaces Σ_ϵ of axis $xyz_\epsilon = [P_\epsilon, i_t, \Delta i_t]_\epsilon$, as illustrated in Fig. 4b. Then, each surface xyz can be represented by three pivot points, namely $A_\epsilon = [i_t^{MIN}, P_{bat}^{MIN}, \Delta i_t^A]_\epsilon$, $B_\epsilon = [i_t^{MAX}, P_{bat}^{MIN}, \Delta i_t^B]_\epsilon$ and $C_\epsilon = [i_t^{MAX}, P_{bat}^{MAX}, \Delta i_t^C]_\epsilon$, which cover the feasibility zone which corresponds to the limits recommended by the manufacturer extended in 20%. To reduce the impact of voltage variation, the surfaces Σ_ϵ are classified into four main categories, named $\epsilon = \{cd, dd, cc, dc\}$, which indicate the sequence of batteries' charge (c) and discharge (d), at time $k-1$ and k . Consequently, the RTMI sends daily to the HMPC only the values of α_ϵ , β_ϵ and γ_ϵ corresponding to the most likely temperature for the next day, which is the average temperature of the previous day.

$$SoC_{k+1} = 1 - \frac{i_{t,k} + \Delta i_{t,k}}{Q_{nom_k}}; P_{bat,k} = P_{bat,k}^{ch} + P_{bat,k}^{dis} = \sum_{\epsilon=\{cd, dd, cc, dc\}} P_{\epsilon,k} \quad (6)$$

$$\Delta i_{t,k} = \sum_{\epsilon=\{cd, dd, cc, dc\}} \alpha_\epsilon P_{\epsilon,k} + \beta_\epsilon i_{t,k-1} + \gamma_\epsilon \delta_{\epsilon,k} \quad (7)$$

Details of the RTMI algorithm

Synchronized with both EMPC and TMPC, the RTMI module acquires a new measurement point M , composed by the integral of the current (i_t), the reference power (P_{bat}) and the battery voltage (v) at each TMPC sampling time (i.e. T_s^{TMPC}). As detailed in the following sub-sections, the RTMI algorithm is divided into three steps, namely: classification, updating and identification of the limits for charging and discharging the batteries.

Step 1: Classification of data measurements by temperature interval

As depicted in Fig. 4a, v is directly correlated to the T_{cell} . This effect in the battery voltage impacts the batteries round-trip efficiency, reducing the accuracy of the classical model defined by (7). Higher voltage when charging the batteries or lower voltages when discharging them implies a loss of efficiency, once the storage energy variation is mainly dependent on the current flowing through the batterie cells. Therefore, aiming to improve the robustness against T_{cell} disturbance, the RTMI fits a linear model for each temperature ranges using classified measurements points. Without using any temperature sensor, the RTMI algorithm estimates the temperature interval from v measurements. The Fig. 4a and Fig. 5a show that the T_{cell} mainly involves a vertical offset in the batteries discharge curve, but almost does not affect the slope of v with respect to i_t . In this way, the maximum amplitude of v (Δv_{MAX}) due to the full charges and discharges of the batteries is almost unchanged, resulting in a quasi-constant slope along with different T_{cell} , as depicted in Fig. 5b and Fig. 5c.

Consequently, when the BMG operates for the first time, the EMS will force two full charges and discharges of the batteries to determine Δv_{MAX} , and therefore, the absolute value of the slope of the discharge curve ($|\Delta v/i_t|$). After this preliminary step, the temperature intervals are defined by identifying the lines $\vec{s}_{T_{class}}$, as shown in Fig. 5c, where T_{class} is the identification number for a specific temperature class. The lines $\vec{s}_{T_{class}}$ are outspread from a voltage interval which is chosen a priori regarding the desired precision, the computing resources and the RTMI convergence time. Typically, this voltage offset can be set as 1% of v_{nom} . As a result, a measurement M belongs to T_{class} , if and only if, the point M is between the lines $\vec{s}_{T_{class}}$ and $\vec{s}_{T_{class}+1}$.

Fig. 5: One-year simulation of the BMG with $SoC_{max} = 80\%$ and $SoC_{min} = 20\%$. (a) v and T_{cell} correlation. (b) Slope of battery discharge curve. (c) Correlation between voltage measurements, current integral and T_{cell} .

Step 2: Updating the values of α_ϵ , β_ϵ and γ_ϵ

Once determined which class of temperature the measurement M belongs to, it is possible to adjust the values of α_ϵ , β_ϵ and γ_ϵ of these respective T_{class} . The determination of α_ϵ , β_ϵ and γ_ϵ is implemented based on an iterative and real-time process. As soon as a new measurement M is acquired, the parameters of α_ϵ , β_ϵ and γ_ϵ are updated. Remarkably, α_ϵ , β_ϵ and γ_ϵ are vectors of size equals to the number of T_{class} , where each element of these vectors is the fitted values of the model defined by (8) over all measurements M . The upmost advantage of the RTMI algorithm is the non-dependency on storage of the past measurements. The knowledge of the previous measures is stored in dynamic confidence weights, named $\omega_{A,k}$, $\omega_{B,k}$ and $\omega_{C,k}$.

Starting from minimal values – typically between 0.1 and 1.0 – these confidence weights grow with the acquisition of new measurements. Since the pivot points possess fixed values in the plan $xy = [P_\varepsilon, i_t]$, the fitting process only consists of calculating the values of z-axis (i.e. $\Delta i_{t,k}^A, \Delta i_{t,k}^B$ and $\Delta i_{t,k}^C$). For the first iteration, the pivot points are initialized according to (8), where it is used the parameters given by the technical specification of the batteries and using the classical model defined in (7).

$$\Delta i_{t,k=0}^A = \Delta i_{t,k=0}^B = \frac{\eta_{ch} T_s}{Q_{nom} v_{nom}} \cdot P_{bat}^{MIN}; \Delta i_{t,k=0}^C = \frac{T_s}{Q_{nom} v_{nom} \eta_{dis}} \cdot P_{bat}^{MAX} \quad (8)$$

Thereafter, the values of $\Delta i_{t,k}^A, \Delta i_{t,k}^B$ and $\Delta i_{t,k}^C$ are updated so that to approach the surface Σ_ε to the new measurement M . To achieve this, an intermediate surface ϕ_ε defined by the intermediary pivot points $A'_\varepsilon, B'_\varepsilon$ and C'_ε , with z-axis values equal to z_A, z_B and z_C , are calculated through the optimisation of the cost function defined by (9). The surface ϕ_ε contains the point M and is determined to make $\Delta i_{t,k+1}^{A,B,C}$ of the next iteration as close as possible of $\Delta i_{t,k}^{A,B,C}$ of the previous period.

$$z_A, z_B, z_C = \arg \left(\min_{z_A, z_B, z_C} n_{A,k} (\Delta i_{t,k}^A - z_A)^2 + n_{B,k} (\Delta i_{t,k}^B - z_B)^2 + n_{C,k} (\Delta i_{t,k}^C - z_C)^2 \right) \quad (9)$$

Subject to:

$$M \in A'_\varepsilon B'_\varepsilon C'_\varepsilon; z_A, z_B, z_C \geq 0$$

Intuitively, high value of $n_{A,k}$ and low values of $n_{B,k}$ and $n_{C,k}$ lead z_A approach to $\Delta i_{t,k}^A$ faster than z_B and z_C to $\Delta i_{t,k}^B$ and $\Delta i_{t,k}^C$, whereas balanced values of $n_{A,k}, n_{B,k}$ and $n_{C,k}$ result in a fair variation among z_A, z_B and z_C . The weights of (9) are calculated with regard the normalized distance between the measure M and the respective intermediate pivot point projected on the plan xy (i.e. operator $\|\cdot\|_{xy}$), as defined in (10) for the pivot point A'_ε .

$$n_{A,k} = \frac{\|\overline{MA}\|_{xy}}{\|\overline{MA}\|_{xy} + \|\overline{MB}\|_{xy} + \|\overline{MC}\|_{xy}} \quad (10)$$

Once determined the intermediary plan $\phi_\varepsilon, \Delta i_{t,k}^A, \Delta i_{t,k}^B$ and $\Delta i_{t,k}^C$ and the confidence weights $\omega_{A,k}, \omega_{B,k}$ and $\omega_{C,k}$ are updated following equations (11) – (14), in the order of compilation. For the sake of simplicity, in this paper, it will only be detailed the updating process of the pivot point A_ε , but it is important to highlight that similar equations are used for B'_ε and C'_ε .

$$\omega_{A,k+1} = \omega_{A,k} + \frac{\frac{1}{\|\overline{MA}\|_{xy}}}{\frac{1}{\|\overline{MA}\|_{xy}} + \frac{1}{\|\overline{MB}\|_{xy}} + \frac{1}{\|\overline{MC}\|_{xy}}} \quad (11)$$

$$\omega_{inertia,k}^A = \sigma (\omega_{A,k+1} - \omega_{A,k}) \leq \omega_{A,k+1} \quad (12)$$

$$\Delta i_{t,k+1}^A = \frac{\Delta i_{t,k}^A \cdot \omega_{inertia,k}^A + z_A \cdot \omega_{A,k+1}}{\omega_{inertia,k}^A + \omega_{A,k+1}} \quad (13)$$

$$\omega_{A,k+1} = \omega_{A,k+1} - \tau_{decay} \cdot (\omega_{A,k+1} - \omega_{min}) \quad (14)$$

Firstly, the confidence weight $\omega_{A,k}$ is updated using (11). The closer M is to the A_ε , the more reliable the value of z_A calculated from (9) is. Consequently, $\omega_{A,k+1}$ is inversely proportional to the distance between the pivot point A_ε and the measurement M , and it is normalised according to the distance from other pivot points (i.e. B_ε and C_ε). To improve the robustness against measurement noise, the updated $\Delta i_{t,k+1}^A$ is a weighted value between the previous $\Delta i_{t,k}^A$ and the new fitted z_A . The inertial factor handles the ponderation among these two variables $\omega_{inertia,k}^A$ and the confidence weight $\omega_{A,k+1}$ as defined in (13). The equilibrium amongst $\omega_{inertia,k}^A$ and $\omega_{A,k+1}$ control the convergence time of $\Delta i_{t,k+1}^A$ to z_A . This balance can be manually set by tuning the value of σ , which indicates the importance of the new measurement regarding the previous value. Notably, $\omega_{inertia,k}^A$ is upper limited by $\omega_{A,k+1}$, to restrict the convergence time to a scale of two. Since the charge/discharge curve of batteries changes with age, the confidence weight $\omega_{A,k+1}$ gradually decreases with a time constant τ_{decay} until a minimum value ω_{min} which is equal to the starting value, as specified in (14).

After updating the plan Σ_ε , the coefficients α_ε , β_ε and γ_ε are calculated using the principles of analytical geometry. As the last step, it is still necessary to refine the developed model, because according to (7) and Fig. 4b, the plan Σ_ε does not cross the $\vec{i}_t$ axis, which makes batteries model inaccurate for low powers. Therefore, the model polishing consists of forcing the plan Σ_ε cross the $\vec{i}_t$ axis by using (15).

$$\Delta i_{t,k} = \sum_{\varepsilon=\{cd,dd,cc,dc\}} \theta_\varepsilon P_{\varepsilon,k} = \sum_{\varepsilon=\{cd,dd,cc,dc\}} P_{\varepsilon,k} \left(\alpha_\varepsilon + \frac{1}{P_{bat}^{MAX}} \cdot \left(\gamma_\varepsilon + \frac{(i_t'^{MAX} + i_t'^{MIN}) \cdot \beta_\varepsilon}{2} \right) \right) \quad (15)$$

Step 3: Identification of the limits for charging and discharging the batteries

As mentioned before and illustrated in Fig. 6a, the batteries must operate between points $Q(v_{exp})$ and $Q(v_{nom})$. The strategy consists in adjusting $i_{t,max}$ and $i_{t,min}$ to reduce the variations of the slope $|\Delta v / \Delta i_t|$. According to Fig. 6a, while i_t is inside the linear zone (zone 1), the slope $|\Delta v / \Delta i_t|$ is quasi-constant, because v is linearly dependent on i_t . However, when operating outside this zone (zone 2), $|\Delta v / \Delta i_t|$ is not constant because v is non-linear regarding i_t .

Fig. 6: Simulation of Li-ion batteries. (a) The slope of the charge/discharge curves as a function of i_t . (b) and (c) Temporal evolution of the slope when operating in linear and non-linear zones, respectively.

Based on this phenomenon, the developed algorithm for identifying the actual boundaries of i_t divides the temporal graphs into two zones, named *zone A* and *zone B*, as illustrated in Fig. 6b and Fig. 6c. The *zone A*, indicated by the red dots, represents the range where the batteries certainly operates in the linear zone. On the other hand, the *zone B*, outlined by the blue dots, is the zone for which the battery can be either in the linear or non-linear region. Therefore, *zone A* comprehends the range of 20% to 80% of the predefined limits of $i_{t,min}$ and $i_{t,max}$, whereas *zone B* is its complementary region.

Remarkably, the oscillation of the slope is more intense when zone B is in the non-linear zone (Fig. 6c) than when it is inside the linear range (Fig. 6b). As a result, to determine whether zone B corresponds to the linear or non-linear range, the average of the absolute difference between each $|\Delta v / \Delta i_t|$ measured inside *zone B* (m_{up}) and those measured inside *zone A* (m_{down}) are constant compared, through the mean deviations ϑ_{up} and ϑ_{down} calculated as detailed in Fig. 7. These deviations ϑ_{up} and ϑ_{down} are monitored by means of a proportional controller with a hysteresis at its input to maintain them within the range $\vartheta_{up,down}^{ref} \pm Tol$. The values of $Tol \cong 2\%$ and $\vartheta_{up,down}^{ref} \cong 10\%$ were manually regulated, but they can be re-adjusted to reduce the oscillations or increase the response time of $i_{t,min}$ and $i_{t,max}$. If the i_t boundaries are modified more than 10% of the previous values, the feasibility zone of Fig. 4b is readjusted accordingly and the confidence values ω_A , ω_B , ω_C are reset to ω_{min} .

Fig. 7: Algorithm for identifying the i_t limits to guarantee the batteries' operation inside the linear zone.

Simulation results

Aiming to evaluate the performance of the proposed control architecture, a BMG equipped with PV arrays with 107kWc and Li-ion batteries with nominal voltage of 700V and nominal capacity of 167Ah was simulated for 365 days in MATLAB Simulink® under several scenarios. The simulations were carried out using real solar radiation data [14] and the estimated annual building energy consumption, resulting in 135.95 MWh energy generation and 241.85 MWh energy consumption per year. The τ_a and the total power exchanged with the main grid was used for assessing the proposed HMPC with RTMI module, a non-hierarchical MPC, and a conventional rule-based (RB) strategy with and without data prediction inaccuracy.

The RB was adapted from [15], where, using no data prediction, the batteries are charged when there is an energy surplus and discharged when there is an energy deficit. The simulation results are divided into two subsections. The first one is to validate the RTMI algorithm for SoC and batteries' capacity estimation, while the second one is for assessing the benefits of dividing the EMS hierarchically.

Performance of the algorithm for batteries' parameter identification

To show the robustness of the RTMI algorithm against inaccuracies of the parameters coming from the technical specifications, three initial values of Q were considered, namely Q_{80} , Q_{100} and Q_{120} , corresponding to 80%, 100% and 120% of the actual capacity (167 Ah), respectively. To verify the error between the day-ahead SoC_{ref} calculated by the EMPC and the real one, the TMPC in these scenarios was considered as a perfect router. Consequently, instead of optimising (3), it does implement the control variables determined by EMPC. In this manner, it is possible to decouple the effect of TMPC and highlight only the impact of the errors in EMPC state of charge estimation on the BMG performance. The graph in Fig. 8a shows that, in all study cases, the cumulative error in predicting SoC_{k+1} using the RTMI module is about 3 times lower than using the conventional model with static parameters. Furthermore, the graphs in Fig. 8b shows that the EMPC empowered by RTMI module assures τ_a about 3% higher than the EMPC without RTMI module with Q_{80} and between 2% and 4% higher than RB controller.

Fig. 8: Evaluation of the EMPC robustness against parameter imprecision. (a) The cumulative error of the SoC estimation. (b) Self-consumption rate comparison. (c) Maximum (in blue lines) and minimum (in red lines) boundaries of the i_t when using RTMI. (d) Estimation of T_{cell} variation through T_{class} .

The increase in τ_a is mainly due to the enlargement of the i_t boundaries closed to the real frontiers (Q_{exp} and Q_{nom}), as shown in Fig. 8c. Accurately estimating the battery capacity reinforces the potential of batteries of shifting the load toward the periods of energy surplus, resulting in an enhanced internal load matching and lower grid dependency. For this reason, the relative difference between τ_a is more remarkable when the batteries' capacity is underestimated (i.e. Q_{80}). Nonetheless, there is a tradeoff between fostering τ_a and the batteries' state of health. Fig. 8c shows that expanding i_t boundaries, the attained depth of discharge (DoD) is higher when employing RTMI module than not using it (at the

beginning of the simulation), accelerating the batteries' degradation [7]. In addition, as shown in Fig. 8d employing the RTMI module and processing of v and i_t measurements, T_{cell} can be supervised without needing any thermal sensor, because T_{class} is an image of the temperature variation. This can provide further information to the HMPC for preserving the batteries state of healthy [2], [8].

Performance of the proposed two-level hierarchical control structure

Since the purpose of the hierarchical EMS is to soften the drawbacks provoked by stochastic variations in the internal power imbalance, the prediction data were multiplied by a random time-dependent factor (ρ), as detailed in Fig. 9a. In this manner, the error in the estimate power imbalance grows according to the horizon, attaining up to 60% at $N_h^{EMPC} = 48$, as shown in Fig. 9b and Fig. 9c. Aiming to assess the proposed HMPC, five control architectures were investigated. The first and second ones are the HMPC with and without RTMI modules. The third and fourth control structures are the non-hierarchical MPC with and without RTMI module, in which only EMPC is updated hourly with the full horizon. Finally, the fourth control disposal is the simple RB.

Fig. 9: Real power and its 48-hours data prediction of a summer day. (a) Time-variant factor. (b) Power consumption. (c) Power generation.

Fig. 10a and Fig. 10b show that both HMPC and the non-hierarchical MPC are robust against data prediction uncertainties, because with and without errors, the BMG imported and exported almost the same amount of energy in a year. Remarkably, when using HMPC with RTMI, it imported about 1% less energy and exported 8% less than without RTMI. Even though the non-hierarchical MPC optimises the cost function (2) around 11 times more than the HMPC, the results are very similar. Indeed, the non-hierarchical structure triggers EMPC at each hour, which means 8760 optimizations in a year, whereas only up to 631 times (number of re-optimisations plus once per day) using the proposed control structure, as detailed in Fig. 10c.

Fig. 10. Comparison between different control architectures. (a) Total power injected. (b) Total power purchased. (c) Number of EMPC re-optimisation. (d) Moving average error in P_{grid}^{ref} of the last 10 days

The cooperation of two control layers – one with long and another with a short horizon – enables to handle prediction data variability without needing to optimize the laborious cost function (2) every hour,

but only when the error in either SoC_{ref} or P_{grid}^{ref} is greater than $\Delta_{SoC}^{thr} = \Delta_{P_{grid}}^{thr} = 7\%$. Fig. 10d shows that errors in P_{grid}^{ref} are higher when not using the RTMI module, because of imprecisions in SoC estimation, which result in 391 more re-optimisations in the scenario without errors and 135 with errors.

Conclusions

This paper aims to develop a generic Building MicroGrid Energy Management System capable of adapting to external changes, such as Li-ion batteries modelling inaccuracy and inherent power imbalance uncertainties. The hierarchical MPC empowered with the proposed real-time parameter identification module increases the self-consumption rate regarding a well-established rule-based controller and the conventional MPC. This data-driven algorithm enables to identify the original batteries capacity and the cell temperature without any previous modelling step and without any thermal sensor, which simplify the energy management system design. Moreover, the simulation results demonstrated that the division in two control layers reduces the number of optimizations while maintaining the building less energetic dependent on the external grid even under imprecisions in data predictions.

References

- [1] T. M. Lawrence *et al.*, “Ten questions concerning integrating smart buildings into the smart grid,” *Build. Environ.*, vol. 108, pp. 273–283, Nov. 2016, doi: 10.1016/j.buildenv.2016.08.022.
- [2] G. Cardoso, T. Brouhard, N. DeForest, D. Wang, M. Heleno, and L. Kotzur, “Battery aging in multi-energy microgrid design using mixed integer linear programming,” *Appl. Energy*, vol. 231, pp. 1059–1069, Dec. 2018, doi: 10.1016/j.apenergy.2018.09.185.
- [3] M. F. Zia, E. Elbouchikhi, and M. Benbouzid, “Microgrids energy management systems: A critical review on methods, solutions, and prospects,” *Appl. Energy*, vol. 222, pp. 1033–1055, Jul. 2018, doi: 10.1016/j.apenergy.2018.04.103.
- [4] Z. Cheng, J. Duan, and M.-Y. Chow, “To Centralize or to Distribute: That Is the Question: A Comparison of Advanced Microgrid Management Systems,” *IEEE Ind. Electron. Mag.*, vol. 12, no. 1, pp. 6–24, Mar. 2018, doi: 10.1109/MIE.2018.2789926.
- [5] P. R. C. Mendes, L. V. Isorna, C. Bordons, and J. E. Normey-Rico, “Energy management of an experimental microgrid coupled to a V2G system,” *J. Power Sources*, vol. 327, pp. 702–713, Sep. 2016, doi: 10.1016/j.jpowsour.2016.07.076.
- [6] L. Su *et al.*, “Path dependence of lithium ion cells aging under storage conditions,” *J. Power Sources*, vol. 315, pp. 35–46, May 2016, doi: 10.1016/j.jpowsour.2016.03.043.
- [7] X. Li, C. Yuan, X. Li, and Z. Wang, “State of health estimation for Li-Ion battery using incremental capacity analysis and Gaussian process regression,” *Energy*, vol. 190, p. 116467, Jan. 2020, doi: 10.1016/j.energy.2019.116467.
- [8] Z. Song *et al.*, “The sequential algorithm for combined state of charge and state of health estimation of lithium-ion battery based on active current injection,” *Energy*, vol. 193, p. 116732, Feb. 2020, doi: 10.1016/j.energy.2019.116732.
- [9] Y. Li *et al.*, “Data-driven health estimation and lifetime prediction of lithium-ion batteries: A review,” *Renew. Sustain. Energy Rev.*, vol. 113, p. 109254, Oct. 2019, doi: 10.1016/j.rser.2019.109254.
- [10] R. Luthander, J. Widén, D. Nilsson, and J. Palm, “Photovoltaic self-consumption in buildings: A review,” *Appl. Energy*, vol. 142, pp. 80–94, Mar. 2015, doi: 10.1016/j.apenergy.2014.12.028.
- [11] Enedis l’électricité en réseau, “Conditions de raccordement des Installations de stockage.” [Online]. Available: https://www.enedis.fr/sites/default/files/Enedis-PRO-RES_78E.pdf.
- [12] Commission de Régulation de l’Energie, “Cahier des charges de l’appel d’offres portant sur la réalisation et l’exploitation d’Installations de production d’électricité à partir d’énergies renouvelables en autoconsommation et situées en métropole continentale.” Dec. 26, 2019.
- [13] O. Tremblay and L.-A. Dessaint, “Experimental Validation of a Battery Dynamic Model for EV Applications,” *World Electr. Veh. J.*, vol. 3, no. 2, pp. 289–298, Jun. 2009, doi: 10.3390/wevj3020289.
- [14] “JRC Photovoltaic Geographical Information System (PVGIS) - European Commission.” https://re.jrc.ec.europa.eu/pvg_tools/en/tools.html#MR (accessed Mar. 05, 2020).
- [15] H. Yu, S. Niu, Y. Zhang, and L. Jian, “An integrated and reconfigurable hybrid AC/DC microgrid architecture with autonomous power flow control for nearly/net zero energy buildings,” *Appl. Energy*, vol. 263, p. 114610, Apr. 2020, doi: 10.1016/j.apenergy.2020.114610.