Energy, exergy, economic, exergoenvironmental, and environmental analyses of a multigeneration system to produce electricity, cooling, potable water, hydrogen and sodium-hypochlorite

M. A. Ehyaei, Simin Baloochzadeh, A. Ahmadi, Stéphane Abanades

► To cite this version:

M. A. Ehyaei, Simin Baloochzadeh, A. Ahmadi, Stéphane Abanades. Energy, exergy, economic, exergoenvironmental, and environmental analyses of a multigeneration system to produce electricity, cooling, potable water, hydrogen and sodium-hypochlorite. Desalination, 2021, 501, pp.114902. 10.1016/j.desal.2020.114902 . hal-03221045

HAL Id: hal-03221045

<https://hal.science/hal-03221045>

Submitted on 7 May 2021

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Energy, Exergy, Economic, Exergoenvironmental, and Environmental analyses of a Multigeneration System to Produce Electricity, Cooling, Potable Water, Hydrogen and Sodium-Hypochlorite

M. A. Ehyaei^{1*}, Simin Baloochzadeh^{2*}, A. Ahmadi³, Stéphane Abanades⁴

¹Department of Mechanical Engineering, Pardis Branch, Islamic Azad University, Pardis New City
1468995513, Iran;

²Faculty of Technology, University of Sunderland, Sunderland, United Kingdom

³Iran University of Science and Technology, School of New Technologies, Department of Energy Systems
Engineering, Iran

⁴Processes, Materials, and Solar Energy Laboratory, PROMES-CNRS, 7 Rue du Four Solaire, 66120, Font-Romeu, France

Corresponding Author: aliehyaei@yahoo.com, <mailto:bg17pm@student.sunderland.ac.uk>

Abstract. One of the necessities of human beings in this century is the potable water supply. This supply has more environmental benefits if the potable water is supplied by renewable energy resources. In this paper, a combination of combined cooling and power system (Goswami cycle), with the reverse osmosis and sodium hypochlorite plant powered by geothermal energy resources is proposed. The products of this system are electrical and cooling energy, potable water, hydrogen and salt. To investigate all of the system aspects, energy, exergy, economic, exergoenvironmental, and environmental analyses are performed. In environmental analysis, the social costs of air pollution are considered. It means that for the same amount of system electrical power produced by non-renewable energy resource power generation systems, the produced air pollution gases and their costs considering the social cost of air pollution are quantified. In this regard, four scenarios are defined. Results show this multi-generation system produces 1.751 GJ/year electrical energy, 1.04 GJ/year cooling energy, 18106.8 m³/year potable water, 7.396 Ton/year hydrogen, and 3.838 Ton/year salt throughout a year. The system energy and exergy efficiencies are equal to 12.25%, and 19.6%. The payback period time of this system is equal to 2.7 years.

Keywords: Goswami Cycle; Reverse Osmosis; Salt; Exergy; Economic; Exergoenvironmental

1. Introduction

Water scarcity is one of the greatest dangers threatening people [1]. This shortage was considered high risk by the World Economic Forum [2]. Around four billion people experience potable water shortage during **at least** one month of a year and five hundred million experience this all the time year along [3].

Around 0.014% of **global** amount of water **existing** on Earth is potable water. The remaining part is brine water or non-accessible. However, the amount of potable water is sufficient, but regarding unequal distribution, some regions such as the middle east suffer from potable water shortage [4].

In addition to the non-equal distribution of potable water, several factors affect the water shortage, such as world population growth, living standard, method of water consumption, agriculture, climate change, and industrial impacts [5].

Thus, supplying potable water is essential for humanity and this can be achieved via desalination. The desalination processes are divided into four main groups: thermal desalination processes [6-9] (multi-stage flash distillation (MSF), multi-effect distillation (MED), vapor-compression evaporation (VC)); membrane processes [10] (reverse osmosis (RO), electrodialysis (ED), membrane distillation (MD)); freezing [11]; and ion exchange - solvent process [12, 13]. The strengths and weaknesses of desalination methods are depicted in Table 1.

Table 1. Strengths and weaknesses of desalination techniques

No.	Techniques	Strength	Weakness	Ref
Thermal desalination processes				
1	MSF	<ul style="list-style-type: none"> Relatively simple Low number moving components High purification Less sensitive to feed water quality The possibility to add more stage to performance improvement 	<ul style="list-style-type: none"> Tube clogging 	[9, 11, 14, 15]
2	MED	<ul style="list-style-type: none"> Less tube corrosion in comparison with MSF Less sensitive to feed water quality Lower power consumption in comparison with MSF Higher efficiency than MSF 	<ul style="list-style-type: none"> Tube clogging 	[9, 15]
3	VC	<ul style="list-style-type: none"> Reliability and simplicity Low operating temperature than MED and MSF Lower tube corrosion 	<ul style="list-style-type: none"> The extra cost for compressor The larger size of the heat exchanger 	[16, 17]
Membrane processes				
4	RO	<ul style="list-style-type: none"> Less corrosion Lower prices Usage of turbine recovery 	<ul style="list-style-type: none"> Clogging of membrane The requirement of a large quantity of water 	[9, 15]
5	ED	<ul style="list-style-type: none"> High recovery The proportion of energy requirement to salt removing 	<ul style="list-style-type: none"> Non-suitable for water with particles less than 0.4 g/L Non-affordable for water with particles higher than 30 g/L Low chemical usage for pre-treatment 	[9, 18]
6	MD	<ul style="list-style-type: none"> Simplicity Less operating temperature 	<ul style="list-style-type: none"> More space requirement Same energy usage with MSF and MED Needs for feed water with no organic pollutant 	[9, 15]
Freezing				

7	Freezing	<ul style="list-style-type: none"> • Lower energy requirement • Low corrosion • Very pure potable water 	<ul style="list-style-type: none"> • Hardly moving of ice and water mixture 	[9, 19]
Ion exchange - the solvent process				
8	Ion exchange - the solvent process	<ul style="list-style-type: none"> • Low cost • Simplicity • Operation easily 	<ul style="list-style-type: none"> • Long production cycle • Poor quality product • Large PH changes 	[20]

Based on a survey carried out by Shahzad et al. [21], the potable water demand will increase up to 60 billion m³ by 2050. This huge amount of water production can be achieved with different types of desalination systems so that the total energy consumption of desalination systems reaches 75.2 TWh per year. Moreover, it was recommended to improve the thermodynamic efficiency of the desalination systems from 10% to 25%, develop high flux membrane material for RO system, and design high-efficiency hybrid MED/MSF desalination systems.

It is preferable that the thermal and electrical energy needs of the various kinds of desalination system can be met by renewable energy resources due to elimination of pollution during operation time and depletion of non-renewable energy resources such as gas, oil, coal, etc. [22].

Among renewable energy resources, geothermal energy has a high potential for use in industrial and residential applications based on the mass flow rate, temperature, and pressure of geothermal fluid [23]. These applications are divided into many categories such as electrical [24], hydrogen [25], heating and cooling [26], and freshwater productions [27], as well as, cogeneration/multigeneration systems which have two or more products [28].

Hybrid cogeneration of the solar and geothermal based system with ammonia fuel cell was examined for electricity, hydrogen, cooling, and fresh-water production. By this configuration, 42.3 % and 21.3% energy and exergy efficiency were achieved in this hybrid system. In addition, the effects of different parameters on the system performance were studied by parametric analyses of the total system and associated subsystems [29].

A modified Kalina cycle was integrated with a reverse osmosis system to provide heating, cooling and power, and potable water. In this investigation, energy and exergy analyses were examined to evaluate its performance. The results of this investigation showed that the system can generate 46.77 kW electricity, 451 kW heating, 52 kW cooling, and 0.79 kg/s potable water. Also, it was

concluded that the thermodynamic properties of the steam cycle were dominant because these parameters can affect both the steam cycle and the Kalina cycle [30].

Integration of a photovoltaic system and geothermal source was examined to provide 840 kW electricity, heating, 5.295 kg/s biogas, and 2.773 kg/s desalinated water. The mixed fluid cascade cycle was employed for methane liquefaction. Its specific power consumption was reduced to 0.1888 kWh/kg LNG by application of an absorption refrigeration system. The energy and exergy efficiencies of this integrated system were 73.2% and 76.8%, respectively [31].

In a study carried out by Behnam et al. [32], exergy and thermo-economic analysis of a novel low-temperature geothermal heat resource for electricity, hot water, and fresh-water production were examined. Moreover, the sensitivity of decision parameters on the performance of this system was also analyzed. The results of this study showed that by using 100 °C geothermal water, this system was able to produce 0.662 kg/s freshwater, 161.5 kW power, and 246 kW heat load.

A multi-effect distillation (MED) desalination plant of 9000 m³/day with solar (parabolic trough collectors) and geothermal energy resources was examined in Spain. The theoretical results of this study revealed that this amount of fresh water was obtained during 76% of the annual time with both solar and geothermal resources (at 490 m depth) and a hot water temperature of 41.8 °C. However, the results of this study revealed by considering a gradient temperature of 8.87 °C per 100 m depth, just geothermal energy at depth of 790 m was enough to obtain working temperature of the desalination plant at 70 °C [33].

The application of a humidification-dehumidification (HDH) unit in a flash-binary geothermal heat source at 170 m was examined in a new tri-generation system for power, cooling, and freshwater production. The results of this study showed that the increment of the steam turbine output power, overall cooling load, gain-output-ratio (TGOR), and exergy efficiency of this system was around 77.1%, 87%, 8.2%, and 46.4%, respectively. The overall exergy destruction of this tri-generation system at the base mode was 946.7 kW. The recovery heat exchanger was recognized as the most destructive component in the base mode with exergy destruction of 308.5 kW [34].

An integrated system containing parabolic trough solar collectors and wind turbines was examined by Makkah et al. [35]. The benefits of a membrane-thermal desalination system to produce power and freshwater were pointed out. This proposed cogeneration system was employed for providing

electrical power and fresh water in Iran by three types of desalination system consisting of the Reverse Osmosis (RO), Multi-effect distillation (MED), and Thermal Vapor Compression (TVC). The obtained results from exergy analysis demonstrated that the exergy destruction of the solar collectors and wind turbines contributed by 39.5% and 22.2%, respectively. The results of multi-objective particle swarm optimization revealed that the exergy efficiency and the cost of freshwater production reach 26.2% and 3.08 US\$/m³. The environmental assessments showed that this hybrid system avoids 52164 tons of CO₂ emission per year.

A solar organic Rankine cycle (ORC) was employed for power generation and freshwater production by reverse osmosis (RO) desalination units in a power scale less than 500 kW. The performance of the ORC/RO desalination set-up was improved by using a cascade ORC/ORC system. Salinity-gradient solar pond (SGSP) was used instead of the conventional solar collector. These results showed that the ORC/ORC/RO system had the highest performance along with the lowest SUCP (sum unit cost of product) and total exergy destruction. Furthermore, the most economical month was June due to the low value of SUCP (72.42 \$/kWh) since more freshwater was produced in this month [36].

Thermodynamic and thermo-economic performances of a hybrid solar and biomass power plant producing electricity, freshwater, and domestic hot water requirements for a 40 households' community were studied by Mouaky et al [37]. The considered community was located in a semi-arid region in Morocco characterized by a good solar potential of 2239 kWh/m²/y and by the presence of brackish groundwater. In parabolic solar collectors and boilers, olive waste residues as feedstock were applied as a working fluid to run a 46 kW ORC and RO unit. The results showed that this proposed system was able to meet the community's requirements with an annual biomass consumption of 235 tons and a solar share of 11.4%. Moreover, this investigation showed that the monthly plant's overall energy efficiency was in a range between 11.3 and 16.3%, while its corresponding exergy efficiency was between 5.3 and 6.0%.

Application of a solar dish collector integrating phase change material storage was used for providing thermal energy of a steam power plant with a capacity of 1063 MW. The phase-change material was applied during the night and in the absence of solar thermal sources. In order to prevent heat losses in the condenser, a large part of the dissipated heat was provided to a multi-

effect desalination system. The desalination system produced 8321 kg/s of freshwater by utilizing 2571 MW of waste heat from the steam power plant. The total electrical efficiency of 28.84% and thermal efficiency of 97.2% were obtained for this system [38].

A plant consisting of photovoltaic panels, and supplying a RO unit for freshwater production was examined by Calise et al. [39]. The developed system was extremely profitable: the achieved payback period was about 1.3 years, mainly due to the high capital cost of freshwater in the reference scenario. Remarkable water-saving equivalent to 80% was obtained. For the selected case study, the sensitivity analyses suggested to adopt a solar field area equal to 6,436 m². The economic consideration revealed low pay-back periods for specific costs of the water higher than 7 €/m³.

Design and economic evaluation of solar-powered hybrid multi-effect and reverse osmosis system for seawater desalination were conducted by Filippini et al. [40]. In this study, the possibility of coupling the desalination plant with a photovoltaic (PV) solar farm was investigated to generate electricity at a low cost and in a sustainable way. Data about four locations, namely Isola di Pantelleria (IT), Las Palmas (ES), Abu Dhabi (UAE), and Perth (AUS), have been used to economically test the feasibility of installing the proposed plant, and especially the PV solar farm.

In a research conducted by Sezer et al. [41], the development and performance assessment of new integrated solar, wind, and osmotic power system for multi-generation, based on thermodynamic principles were examined. The results revealed that the overall obtained energy and exergy efficiencies were 73.3% and 30.6%, respectively. The obtained results showed that this system was able to generate 51.6 MW electrical power, 40.2 MW refrigeration load, 559 kg/h hydrogen, and 403.2 L/s freshwater.

An integrated solar-driven membrane distillation system for water purification and energy generation was used by Li et al. [42]. It was found that a system with a solar absorbing area of 1.6 m² coupled with ~0.2 m² of membranes can produce ~4 L of drinkable water and ~4.5 kWh of heat energy (at 45 °C) per day (with an average daily solar exposure of 4 kWh/m²). The economic consideration of this study indicated that this system had a payback time of ~4 years.

The summary of previous studies is reported in Table 2.

Table 2. Various researches about the multi/cogeneration systems

No.	Energy resource	Components	Products	Analysis	Energy efficiency (%)	Exergy efficiency (%)	Cost of products	Ref
1	Solar/Geothermal	RO; PEMFC; ASR; AFC; HSR	Electricity, Freshwater, Hydrogen, and Cooling	Energy/Exergy	42.3	21.3	-	[29]
2	Geothermal	KC, RO	Electricity, Heating, Cooling, and Freshwater	Energy/Exergy	-	38.1	-	[30]
3	Solar/Geothermal	Biogas system, MED, ORC; PV	Bio-liquefied natural gas; Freshwater, Electricity	Energy/Exergy	73.2	76.8	-	[31]
4	Geothermal	ORC; ASR; SSE	Electricity, Hot and Fresh water	Energy/Exergy/ Thermoeconomic	34	43	LCOE= 0.04 \$/kWh LCOW= 29.4 \$/m ³	[32]
5	Solar/Geothermal	PTC; MED	Freshwater	Feasibility study	-	-	-	[33]
6	Geothermal	FGPP; HDH	Electricity/Cooling	Energy/Exergy	46.4	TGOR= 0.9275	-	[34]
7	Solar/Geothermal	MED; PTC; ORC	Electricity; Cooling; Heating; Freshwater; Absorption Chiller	Exergy/Exergoeconomic	-	63	Electricity exergoeconomic cost= 0.1475–0.1722€/kW h Chilled water exergoeconomic cost= 0.1863–0.1888€/kW hex Cooling water exergoeconomic cost= 0.01612–0.01702€/kW hex Freshwater exergoeconomic cost= 0.5695–0.6023€/kW hex.	[34]
8	Solar/Wind	PTC; Wind turbine; MED; RO	Electricity/Fresh water	Energy/ Exergy/ Exergoeconomic	-	26.2	Fresh water cost= 3.08 \$/m ³	[35]
9	Solar	Solar Pond; KC; ORC; RO	Electricity/Freshwater	Thermodynamic/ Thermoeconomic	-	18	SUCP= 101.7 \$/kWh	[36]
10	Solar/Biomass		Electricity/ Freshwater/, domestic hot water (DHW)	Thermodynamic/ Thermoeconomic	11.3–16.3	5.3–6	Electricity cost= 0.231 €/kW Fresh water cost= 0.86 €/m ³ DHW cost= 0.047 €/kW	[37]
11	Solar	SD; PCM; SC; MED	Electricity; Freshwater	Energy/ Exergy	28.8	52.2	-	[38]
12	Solar	PV; RO	Electricity; Freshwater	Economic	-	-	PP = 1.3 years	[39]
13	Solar	PV; MED; RO	Electricity; Fresh water	Economic	-	-	Electricity cost= 0.1 €/kWh Fresh water cost= 0.59 €/m ³	[40]
14	Solar/Wind	Wind Turbine; CPVT; TES; FC; EL; MSF; VCR; PRO	Electricity; Freshwater; Cooling; Hydrogen	Energy/ Exergy	73.3	30.6	-	[41]
15	Solar	ESC; MD	Freshwater	Economic	-	-	PP = 4 years	[42]

Abbreviations: Reverse Osmosis: RO; Proton Exchange Membrane Fuel Cell: PEMFC; Absorption Refrigeration: ASR; Ammonia Fuel Cell: AFC; Organic Rankin Cycle: ORC; Single Stage Evaporator: SSE; Photovoltaic: PV; Levelized Cost of Electricity: LCOE; Levelized Cost of water: LCOW; Parabolic Through Collector: PTC; Trigenation-based Gain-Output-Ratio: TGOR; Flash-Binary Geothermal Power Plant: FGPP; Humidification-Dehumidification unit: HDH; Kalina Cycle: KC; SUCP: Sum Unit Cost of Product; Domestic Hot Water: DHW; PCM: Phase Change Material; Steam Cycle: SC; Solar Dish: SD; PP: Payback Period; CPVT: Concentrated Photovoltaics/Thermal; TES: Thermal Energy Storage; Electrolyzer: EL; Fuel Cell: FC; Multistage Flash Distillation: MSF; Vapor Compression Refrigeration: VCR; Pressure Retarded Osmosis: PRO; Evacuated Solar Collector: ESC

2.1. Novelty of the Research

After careful investigation of the multi/co-generation systems and different products from them, it is clear that the proposed system configuration has not been investigated yet. In this proposed system, three main sub-systems are considered that are power and cooling production (Goswami cycle [43-46]), Reverse Osmosis (RO) with a recovery turbine, hydrogen and sodium hypochlorite (NaClO) production) that are powered by the geothermal energy resource.

Moreover, the products of this system (electrical power, cooling, freshwater, hydrogen, and sodium hypochlorite (NaClO)) are different from the other systems which have been investigated in the literature.

The benefits of the proposed desalination system are varied and the key products are potable water (as main needs for humanity), hydrogen (a key clean fuel for the transportation sector), electrical and cooling energy (as needs for residential, commercial, and industrial applications), and sodium-hypochlorite (a valuable co-product).

Complete analyses covering all aspects of the system including energy, exergy, economic, exergoenvironmental, and environmental have not been considered for any system in the literature.

For the environmental analysis, the relation between environmental detrimental effects and economics is established by considering the social cost of environmental pollution. It is assumed the same amount of electrical power produced by this system is generated by non-renewable power generation systems and the air pollution gases (CO_2 , NO_x , SO_2 , CO) produced by these assumed systems are calculated. In this regard, four scenarios are defined.

By considering the social cost of these harmful gases, the effects of environmentally harmful gases on economics are evaluated.

The innovations of this paper are as follows:

- Energy, exergy, economic, exergoenvironmental, and environmental analyses of the multigeneration system to produce electrical, cooling, potable water, hydrogen, and NaClO simultaneously

- **Establish** a relationship between environmental negative effects and economics by considering the social cost of environmental pollution.

2. Mathematical Modeling

2.1. Process Description and Assumptions

Figure 1 shows the schematic diagram of the proposed system. This system has three sub-systems consisting of cooling and power production system (Goswami cycle), reverse osmosis (RO) with a recovery turbine, and **H₂/NaClO** production plant.

The advantage of the Goswami cycle compared to the Kalina cycle is the cooling output, however, with higher temperature source, the Kalina cycle has a better performance [43].

In the power and cooling production system (Goswami cycle), the working fluid is a binary mixture of water and ammonia. This working fluid flows through pump III and it is pressurized (points 1 & 2). After exchanging the heat with the heated lean ammonia-water mixture in the Recovery Heat Exchanger (RHX), it is transferred to the boiler (points 2, 3, 9 & 10). In the boiler, the mixture is heated and it is sent to the rectifier/separator (point 4). In the rectifier/separator, the working fluid is divided into rich and lean mixtures (points 5 & 9). The lean mixture is transferred to the RHX (points 9 & 10). After reducing the pressure in the throttling valve (point 11), it is transferred to the absorber.

The rich mixture is heated in the superheater and it is converted to the superheated steam (point 6). This superheated steam rotates the turbine and generator to produce electrical power. Then, the low-pressure rich mixture goes through the Refrigeration Heat Exchanger (RHE) to produce cooling (points 7 & 8). In the absorber, the lean and rich mixtures are mixed (points 8, 11 & 1).

The energy needs of the boiler and superheater are met to be supplied by the geothermal working fluid. After extraction of the geothermal working fluid from the production well (point 12), it is pressurized in the pump I (point 13) and then flows through the superheater and boiler to warm up the ammonia-water mixture (points 14 & 15).

In the RO, the seawater goes through high-pressure pumps (points 16, 17, 18, 19 & 20), and then it is transferred to the membranes I & II to separate the salt. The potable water (points 21, 23 & 25) is stored in the water storage tank (point 26). The high-pressure drain rotates the recovery

turbine (points 22, 24 & 27) to produce the electrical power (point 28). The part of the low-pressure drain water (point 29) is transferred to the NaClO plant to produce hydrogen and sodium hypochlorite (NaClO) (points 30 & 31).

In this system, the electrical power is produced in the turbine (Goswami cycle) and the recovery turbine. The part of this produced electricity is consumed internally by the pumps I to IV and NaClO plant. The remaining part can be used by consumers. The system Grassman diagram is shown in Figure 2.

Figure 1. Proposed system schematic diagram

Figure 2. Grassman diagram of the system

The following assumptions are considered [23, 43, 47-54]:

- 1- Steady-state operation.
- 2- The pump and turbine polytrophic efficiencies are equal to 85%, respectively.
- 3- The heat exchanger effectiveness factor is 85%.
- 4- The geothermal working fluid pressure, temperature, and mass flow rate are equal to 2 bar, 120°C, and 15 kg/s, respectively. The location of geothermal wells is in the Bandar Abbas city located in the southern of Iran. The type of geothermal resource is hydrothermal.
- 5- The dead state pressure and temperature are 15°C and 1 bar, respectively.
- 6- The potential and kinetic energy are neglected.
- 7- The pressure loss is neglected.
- 8- The process in the throttling valve is adiabatic.
- 9- The recovery ratio in the RO system is 0.3.
- 10- Heat exchangers are shell and tube type.
- 11- In the environmental analysis, air pollution is considered as environmental pollutions.
- 12- The polarization effects are ignored in this study.

2.2. Mass, Concentration, and Energy Balance

Generally, the mass and energy conservation equations are written as follows [55]:

$$\sum_{in} \dot{m} = \sum_{out} \dot{m} \quad (1)$$

$$\dot{Q} - \dot{W} = \sum_P \dot{m} (h_f + (h - h_0)) - \sum_R \dot{m} (h_f + (h - h_0)) \quad (2)$$

In which $\dot{W}$ and $\dot{Q}$ are the work and heat transfer rate, h and $\dot{m}$ are enthalpy and mass flow rate, respectively. Subscripts P, R, f, and 0 mean product, reactant, formation, and dead state, respectively.

The mass, concentration, and energy balance equations for the combined power and cooling system (Goswami cycle) and geothermal loop are shown in Table 3 [56-58].

Table 3. Mass, concentration, and energy balance equations for the Goswami cycle

No.	Components	Mass balance	Energy equation	X
Combined power and cooling system (Goswami cycle)				
1	Pump III (P)	$\dot{m}_1 = \dot{m}_2$	$\dot{W}_{pIII} = \dot{m}_1(h_2 - h_1)$	$X_1 = X_2$
2	Throttling valve	$\dot{m}_{10} = \dot{m}_{11}$	$h_{10} = h_{11}$	$X_{10} = X_{11}$
3	Recovery heat exchanger	$\dot{m}_3 = \dot{m}_2$, $\dot{m}_{10} = \dot{m}_9$	$\dot{m}_{20}(h_9 - h_{10})\eta_{RHX}$ $= \dot{m}_2(h_3 - h_2)$	$X_3 = X_2$ $X_{10} = X_9$
4	Boiler	$\dot{m}_3 = \dot{m}_4$, $\dot{m}_{14} = \dot{m}_{15}$	$\dot{m}_{14}(h_{14} - h_{15})\eta_{Boiler}$ $= \dot{m}_3(h_4 - h_3)$	$X_3 = X_4$
5	Rectifier/ separator (RS)	$\dot{m}_4 = \dot{m}_5 + \dot{m}_9$	$\dot{m}_4 h_4 = \dot{m}_5 h_5 + \dot{m}_9 h_9$	$\dot{m}_4 X_4 = \dot{m}_5 X_9 + \dot{m}_9 X_5$
6	Superheater (SH)	$\dot{m}_5 = \dot{m}_6$ $\dot{m}_{13} = \dot{m}_{14}$	$\dot{m}_{13}(h_{13} - h_{14})\eta_{SH} = \dot{m}_5(h_6 - h_5)$	$X_5 = X_6$
7	Turbine (T)	$\dot{m}_6 = \dot{m}_7$	$\dot{W}_T = \dot{m}_6(h_6 - h_7)$	$X_6 = X_7$
8	Refrigeration heat exchanger (RHE)	$\dot{m}_7 = \dot{m}_8$	$\dot{Q}_{RHE} = \dot{m}_7(h_7 - h_8)$	$X_7 = X_8$
9	Absorber (Abs)	$\dot{m}_8 + \dot{m}_{11} = \dot{m}_1$	$\dot{Q}_{Abs} = \dot{m}_8 h_8 + \dot{m}_{11} h_{11} - \dot{m}_1 h_1$	$\dot{m}_8 X_8 + \dot{m}_{11} X_{11} = \dot{m}_1 X_1$
Geothermal loop				
10	Pump I (P)	$\dot{m}_{12} = \dot{m}_{13}$	$\dot{W}_{pI} = \dot{m}_{12}(h_{12} - h_{13})$	-

In Table 3, $\dot{m}$, h , X , and η mean mass flow rate, enthalpy, ammonia mass ratio, and polytrophic efficiency for rotary equipment (pump and turbine), as well as, effectiveness factor for boiler, superheater, and heat exchangers.

In RO sub-system, the mass and concentration balance equations are as follows [49, 59, 60]:

$$\dot{m}_{SW} = \dot{m}_{BW} + \dot{m}_{PW} \quad (3)$$

$$\dot{m}_{SW}x_{SW} = \dot{m}_{PW}x_{PW} + \dot{m}_{BW}x_{BW} \quad (4)$$

where x is the salt concentration. Subscripts SW , PW , and BW denote seawater, potable water, and brain water, respectively.

The relation between sea and portable water is as follows [49, 59]:

$$\dot{m}_{PW} = RR\dot{m}_{SW} \quad (5)$$

where RR is the recovery ratio.

Osmosis pressure for the three main streams are calculated by [49, 59]:

$$\pi_{SW} = RT \times x_{SW} \quad (6)$$

$$\pi_{PW} = RT \times x_{PW} \quad (7)$$

$$\pi_{BW} = RT \times x_{BW} \quad (8)$$

R is the universal gas constant.

The net pressure in the membrane is calculated by [49, 59]:

$$\Delta\pi = \left(\frac{\pi_{SW} + \pi_{BW}}{2} \right) - \pi_{PW} \quad (9)$$

The water permeability coefficient is calculated by [49, 59]:

$$K_W = \frac{6.84 \times 10^{-8}(18.68 - 0.177x_{BW})}{T_{SW}} \quad (10)$$

The net pressure of the RO pump is calculated by [49, 59]:

$$\Delta P = \frac{\dot{m}_{PW}}{K_W A_m} + \Delta \pi \quad (11)$$

A_m is the membrane area.

The power needs of the RO pump is calculated as [49, 59]:

$$\dot{W}_{P,RO} = \frac{\Delta P \dot{m}_{SW}}{\rho_{SW} \eta_{P,RO}} \quad (12)$$

where ρ is the density.

The mass, concentration, and energy balance equations for the RO sub-system are presented in Table 4.

Table 4. Mass, concentration, and energy balance equations for the RO sub-system

No.	Components	Mass balance	Energy equation	x
1	Pump II	$\dot{m}_{17} = \dot{m}_{19}$	$\dot{W}_{PII} = \dot{m}_{17}(h_{19} - h_{17})$	$x_{17} = x_{19}$
2	Pump IV	$\dot{m}_{18} = \dot{m}_{20}$	$\dot{W}_{PIV} = \dot{m}_{18}(h_{20} - h_{18})$	$x_{18} = x_{20}$
3	Membrane I	$\dot{m}_{19} = \dot{m}_{21} + \dot{m}_{22}$	$\dot{m}_{19}h_{19} = \dot{m}_{21}h_{21} + \dot{m}_{22}h_{22}$	$\dot{m}_{19}x_{19} = \dot{m}_{21}x_{21} + \dot{m}_{22}x_{22}$
4	Membrane II	$\dot{m}_{20} = \dot{m}_{23} + \dot{m}_{24}$	$\dot{m}_{20}h_{20} = \dot{m}_{23}h_{23} + \dot{m}_{24}h_{24}$	$\dot{m}_{20}x_{20} = \dot{m}_{23}x_{23} + \dot{m}_{24}x_{24}$
5	Recovery turbine	$\dot{m}_{27} = \dot{m}_{28}$	$\dot{W}_{\text{Recovery turbine}} = \dot{m}_{27}(h_{27} - h_{28})$	$x_{27} = x_{28}$

In which x means the concentration of salt.

In the NaClO plant, the following reaction happens:

For the NaClO plant, the following relations between temperature and concentration ratio are considered [49, 59]:

$$T_{NaClO} = T_{BW} + 14 \quad (14)$$

$$x_{NaClO} = \frac{1}{6} x_{BW} \quad (15)$$

The power need of the NaClO plant is calculated by [49, 59]:

$$\dot{W}_{NaClO} = \frac{10^{-5}(5.9 \times 3600 \times \dot{m}_{NaClO} \times x_{NaClO})}{1.05} \quad (16)$$

Table 5 shows the mass, concentration, and energy balance equations for the NaClO plant.

Table 5. Mass, concentration, and energy balance equations for the NaClO plant.

Mass balance	$\dot{m}_{29} = \dot{m}_{30} + \dot{m}_{31}$
Concentration balance	$\dot{m}_{29}x_{29} = \dot{m}_{30}x_{30} + \dot{m}_{31}x_{31}$
Energy balance	$\dot{m}_{29}h_{29} + \dot{W}_{NaClO} = \dot{m}_{31}h_{31} + \dot{m}_{30}h_{30}$

The electrical power production equations for the Goswami, Goswami/RO, and system plants are shown below:

$$\dot{W}_{net,Goswami} = \dot{W}_T - \dot{W}_{P,I} - \dot{W}_{P,III} \quad (17)$$

$$\dot{W}_{net,Goswami/RO} = \dot{W}_T + \dot{W}_{recovery\ turbine} - \sum_{i=1}^4 \dot{W}_{P,i} \quad (18)$$

$$\dot{W}_{net,sys} = \dot{W}_T + \dot{W}_{recovery\ turbine} - \sum_{i=1}^4 \dot{W}_{P,i} - \dot{W}_{NaClO} \quad (19)$$

The energy efficiency equations for the Goswami, Goswami/RO, and system plants are defined as:

$$\eta_{en,Gowsami} = \frac{\dot{W}_{net,Goswami}}{\dot{m}_{12}(h_{12} - h_{15})} \quad (20)$$

$$\eta_{en,Gowsami/RO} = \frac{\dot{W}_{net,Goswami/RO} + \dot{m}_{25}h_{25}}{\dot{m}_{12}(h_{12} - h_{15})} \quad (21)$$

$$\eta_{en,system} = \frac{\dot{m}_{31}h_{31} + \dot{m}_{30}h_{30} + \dot{m}_{25}h_{25} + \dot{W}_{net,Goswami/RO/NaClO}}{\dot{m}_{12}(h_{12} - h_{15})} \quad (22)$$

2.3. Exergy Analysis

Exergy analysis is carried out by including four parts which are physical, chemical, kinetic, and potential. Specific exergy equation is written below [61, 62]:

$$e = \sum x_i ex_{chi} + \frac{V^2}{2} + gz + (h - h_0) - T_0(s - s_0) + T_0 \sum x_i R_i \ln y_i \quad (23)$$

e and x are specific exergies and mass fraction. V, g, and z are defined as velocity, gravitational acceleration, and height. h, T, s, y are specific enthalpy, entropy, temperature, and mole fraction. Abbreviations ch, i, and 0 are defined as chemical, species, and dead state condition.

Tables 6, 7, and 8 show the exergy destruction rate and exergy efficiency for each component of the combined power and cooling system and geothermal loop (Goswami cycle), RO, and NaClO plant, respectively.

Table 6. Exergy efficiency and exergy destruction rate for each component of the combined power and cooling system and geothermal loop (Goswami cycle)

No.	Components	Exergy efficiency	Exergy destruction rate (kW)
Combined power and cooling system (Goswami cycle)			
1	Pump III (P)	$\frac{\dot{W}_{P_{III}}}{\dot{m}_1(e_2 - e_1)}$	$\dot{m}_1 e_1 - \dot{m}_2 e_2 + \dot{W}_{P_{III}}$
2	Throttling value	$\frac{\dot{m}_{11} e_{11}}{\dot{m}_{10} e_{10}}$	$\dot{m}_{11} e_{11} - \dot{m}_{10} e_{10}$
3	Recovery heat exchanger	$\frac{\dot{m}_2(e_3 - e_2)}{\dot{m}_{20}(e_9 - e_{10})}$	$\dot{m}_2 e_2 + \dot{m}_9 e_9 - \dot{m}_3 e_3 - \dot{m}_{10} e_{10}$
4	Boiler	$\frac{\dot{m}_3(e_4 - e_3)}{\dot{m}_{11}(e_{14} - e_{15})}$	$\dot{m}_3 e_3 + \dot{m}_{14} e_{14} - \dot{m}_{15} e_{15} - \dot{m}_4 e_4$
5	Rectifier/ separator (RS)	$\frac{\dot{m}_5 e_5 + \dot{m}_9 e_9}{\dot{m}_4 e_4}$	$\dot{m}_4 e_4 - \dot{m}_5 e_5 - \dot{m}_9 e_9$
6	Superheater (SH)	$\frac{\dot{m}_5(e_6 - e_5)}{\dot{m}_6(e_{13} - e_{14})}$	$\dot{m}_{13} e_{13} + \dot{m}_5 e_5 - \dot{m}_6 e_6 - \dot{m}_{14} e_{14}$
7	Turbine (T)	$\dot{m}_6(e_6 - e_7) - \dot{W}_T$	$\frac{\dot{W}_T}{\dot{m}_6(e_6 - e_7)}$
8	Refrigeration heat exchanger (RHE)	$\dot{m}_7(e_7 - e_8) - \dot{Q}_{RHE}(1 - \frac{T_8}{T_0})$	$\frac{\dot{Q}_{RHE}(1 - \frac{T_8}{T_0})}{\dot{m}_7(e_7 - e_8)}$

9	Absorber (Abs)	$\dot{m}_8 e_8 + \dot{m}_{11} e_{11} - \dot{m}_1 e_1 - \dot{Q}_{abs}$	$\frac{\dot{m}_1 e_1}{\dot{m}_8 e_8 + \dot{m}_{11} e_{11} - \dot{Q}_{abs}}$
Geothermal loop			
10	Pump I (P)	$\frac{\dot{W}_{PI}}{\dot{m}_1 (e_{13} - e_{12})}$	$\dot{m}_{12} e_{12} - \dot{m}_{13} e_{13} + \dot{W}_{PII}$

Table 7. Exergy destruction rate and exergy efficiency for each component of the RO system

No.	Components	Exergy efficiency	Exergy destruction rate (kW)
1	Pump II	$\frac{\dot{W}_{PII}}{\dot{m}_{17}(e_{19} - e_{17})}$	$\dot{m}_{17}(e_{17} - e_{19}) + \dot{W}_{PII}$
2	Pump IV	$\frac{\dot{W}_{PIV}}{\dot{m}_{18}(e_{20} - e_{18})}$	$\dot{m}_{18}(e_{18} - e_{20}) + \dot{W}_{PIV}$
3	Membrane I	$\frac{\dot{m}_{21} e_{21}}{\dot{m}_{19} e_{19}}$	$\dot{m}_{19} e_{19} - \dot{m}_{21} e_{21} - \dot{m}_{22} e_{22}$
4	Membrane II	$\frac{\dot{m}_{23} e_{23}}{\dot{m}_{20} e_{20}}$	$\dot{m}_{20} e_{20} - \dot{m}_{23} e_{23} - \dot{m}_{24} e_{24}$
5	Recovery turbine	$\frac{\dot{W}_{recovery\ turbine}}{\dot{m}_{17}(e_{27} - e_{28})}$	$\dot{m}_{27} e_{27} - \dot{m}_{28} e_{28} - \dot{W}_{recovery\ turbine}$

Table 8. Exergy efficiency and exergy destruction rate for each component of the NaClO plant

Exergy efficiency	$\frac{\dot{m}_{31} e_{31}}{\dot{W}_{NaClO}}$
Exergy destruction rate	$\dot{m}_{29} e_{29} + \dot{W}_{NaClO} - \dot{m}_{30} e_{30} - \dot{m}_{31} e_{31}$

The exergy efficiency equations for the Goswami, Goswami/RO, and system are presented below:

$$\eta_{ex,Goswami} = \frac{\dot{W}_{net,Goswami}}{\dot{m}_{12}(e_{12} - e_{15})} \quad (24)$$

$$\eta_{ex,Goswami/RO} = \frac{\dot{W}_{net,Goswami/RO} + \dot{m}_{25} e_{25}}{\dot{m}_{12}(e_{12} - e_{15})} \quad (25)$$

$$\eta_{ex,sys} = \frac{\dot{W}_{net,sys} + \dot{m}_{31} e_{31} + \dot{m}_{30} e_{30} + \dot{m}_{25} e_{25}}{\dot{m}_{12}(e_{12} - e_{15})} \quad (26)$$

2.4. Economic Evaluation

The cogeneration annual income CF is calculated as follows [63, 64]:

$$CF = Y_{power}k_{power} + Y_{cooling}k_{cooling} + Y_{PW}k_{PW} + Y_{NaCl}k_{NaCl} + Y_{H2}k_{H2} \quad (27)$$

where k and Y are products specific cost and annual capacity of system productions. The production costs are shown in Table 9.

Table 9. Specific cost of fuel and products

Specific cost of products	Unit	Value	Ref.
k_{power}	US\$/kWh	0.22	[65]
k_{PW}	US\$/kg	0.0004	[66]
$k_{cooling}$	US\$/kWh	0.07	[67]
k_{NaCl}	US\$/kg	10.5	[68]
k_{H2}	US\$/kg	13.99	[69]

The system investment cost equation is given below [63, 64]:

$$C_0 = K_{Goswami} + K_{Geothermal\ loop} + K_{RO} + K_{NaClO} \quad (28)$$

K is the investment and installation cost of each subsystem shown in Table 10. For the operation and maintenance cost, 3% of the initial cost is considered [63, 64].

Table 10. K values for different components

No.	Components	Cost function	Ref
Combined power and cooling system (Goswami cycle)			
1	Pump	$1120 \dot{W}^{0.8}$	[70-73]

2	Throttling value	<i>Neglected</i>	[50, 74]
3	Heat exchanger	$588 A^{0.8}$	[70-72]
4	Boiler	$588 A^{0.8}$	[70-72]
5	Superheater (SH)	$588 A^{0.8}$	[70-72]
6	Turbine	$4405 \dot{W}^{0.7}$	[70-73]
7	Rectifier/Separator	$\frac{576.1}{397} 10^{(3.4974 + 0.4485 \log(V_{sep}) + 0.1074 (\log(V_{sep}))^2)} (2.25$ $+ 1.82 \text{ maximum} \left\{ \frac{(P_{sep} + 1) D_{sep}}{2[850 - 0.6(P_{sep} + 1)]} + 0.00315, 1 \right\}$	[75]
8	Absorber (Abs)	$0.322(30000 + 0.75 A^{0.8})$	[66]
Geothermal loop			
9	Pump	$3540 \dot{W}^{0.71}$	[76, 77]
10	Drilling well	$16.5 z^{1.607}$	[78]
RO			
11	Pump	$996 (86400 \dot{Q})^{0.8}$	[79]
12	Membrane	50	[67]
13	Tank	$1.14(158,62V_{Tank} + 18321$	[80]
14	Recovery turbine	$52 (86400 \dot{Q} \Delta P^{0.8})$	[79]
NaClO Plant			
15	NaClO Plant (Model HD:6000)	45000	[81]

In Table 10, z, D, and V mean depth of geothermal well, diameter, and volume, respectively. Subscript sep denotes separator.

For estimating the surface area of the heat exchanger, the logarithmic method is applied. In this regard, the following equation is considered [82]:

$$\dot{Q} = U A F_t \Delta T_{In} \quad (29)$$

where $\dot{Q}$, U , A , F_t , and ΔT_{In} are the heat transfer rate, overall heat transfer coefficient, surface area, correction factor, and logarithmic mean temperature difference. The overall heat transfer coefficient for various components is shown in Table 10 [50]. The method for estimating the volume of the separator is explained in Ref. [83].

Table 11. U values for various components

No.	Components	$U(W/m^2K)$
1	Separator	300
2	Boiler	500
3	Heat exchanger	700
4	Absorber	800

Since the cost function is based on various years, the effect of inflation can be represented by the following equation [84]:

$$C_n = C_0(1 + i)^n \quad (30)$$

where n is the number of years, and i is the inflation rate which is equal to 3.11% [85].

The simple payback period (SPP) index is calculated by [63, 64]:

$$SPP = \frac{C_n}{CF} \quad (31)$$

The payback period (PP) index can be expressed as [63, 64]:

$$PP = \frac{\ln(\frac{C_F}{CF - r \cdot C_n})}{\ln(1 + r)} \quad (32)$$

where r represents the discount factor (3%).

The Net Present Value (NPV) is obtained as [63, 64]:

$$NPV = CF \frac{(1 + r)^N - 1}{r(1 + r)^N} - C_n \quad (33)$$

N is the project lifetime that is considered 25 years.

The Internal Rate of Return (IRR) is given by [63, 64, 86]:

$$IRR = \frac{CF}{C_n} \left[1 - \frac{1}{(1 + IRR)^N} \right] \quad (34)$$

2.4. Exergoenvironmental Analysis

To investigate the system from the combination of exergy and environmental perspective, exergoenvironmental analysis is considered. The exergoenvironment factor which is affected by the exergy destruction rate is shown below [87-89]:

$$f_{ei} = \frac{\dot{E}_D}{\sum \dot{E}_{in}} \quad (35)$$

In equation (35), subscripts D and in are destruction and input. The environmental damage effectiveness factor can be calculated as [87-89]:

$$\theta_{ei} = f_{ei} \cdot C_{ei} \quad (36)$$

C_{ei} is the exergoenvironmental impact coefficient which is calculated by [87-89]:

$$C_{ei} = \frac{1}{\eta_{ex}} \quad (37)$$

In equation (37), η_{ex} is the system exergy efficiency. The exergoenvironmental impact is expressed as [87-89]:

$$\theta_{eii} = \frac{1}{\theta_{ei}} \quad (38)$$

The exergy stability factor is given by [87-89]:

$$f_{es} = \frac{\dot{E}_D}{\dot{E}_{out} + \dot{E}_D + 1} \quad (39)$$

2.5. Environmental Analysis

To establish the relation between environmental air pollution and economics, the social cost of air pollution is considered. The social cost of air pollution is the cost associated with the harmful

effects of air pollution on society. These effects are including diseases, deaths, etc. This cost can vary from one region to another. Also, the standard of living affects this cost. Further explanations are provided in ref. [90, 91].

The air pollution factors are not limited to these categories. Other sources of pollution such as water, soil, and noise... are existing that are ignored in this work because no data is existing in the literature, and the effects of these pollutions are much lower than air pollution.

In addition, during the components system production, various kinds of environmental pollution are produced that are out of the scope of this work. The environmental pollution produced during the operation time is related to life cycle analysis (LCA) and it can be investigated in future research [90, 91].

In order to establish a relationship between the environmental pollution and economics direct/indirect effect, four scenarios are considered. In all scenarios, it is assumed that the same amount of electrical power produced by the proposed system in this work, is produced by non-renewable energy resource power production systems. These scenarios are as follows:

Scenario I: Natural gas-fueled gas turbine power plant

Scenario II: Gas oil-fueled gas turbine power plant

Scenario III: Coal-fired steam power plant

Scenario IV: Natural gas-fueled gas turbine with heat recovery boiler and steam turbine

The social cost of air pollution for carbon dioxide (CO₂), nitrogen oxide (NO_x), and sulfur dioxide (SO₂) are presented in Table 12 [90, 91]. The four scenarios with air pollution generation are shown in Table 13 [92].

Table 12. Social cost of air pollution for CO₂, NO_x, and SO₂

Pollution	Unit	Values
CO ₂	US\$/kg	0.042
NO _x		7.3
SO ₂		7.4

Table 13. Four scenarios and air pollution **generation** [92]

Scenario	Power plant types	Fuel	CO ₂ (g/kWh)	NO _x (g/kWh)	SO ₂ (g/kWh)
1	Gas turbine power plant	NG	610	1.1	-
2	Gas turbine power plant	GO	800	1.6	1.4
3	Coal-fired steam power plant	Coal	930	2.1	8.8
4	Gas turbine with heat recovery boiler and steam turbine	NG	510	0.9	-
Abbreviations: NG: Natural gas; GO: Gas oil					

In the proposed system of this study, since the system does not produce any air pollution during the operation time, it can be considered as a benefit of this system. So, cogeneration annual income (CF) can be considered by the following expression to show the effect of the social cost of air pollution:

$$CF = Y_{power}k_{power} + Y_{cooling}k_{cooling} + Y_{PW}k_{PW} + Y_{NaCl}k_{NaCl} + Y_{H_2}k_{H_2} + Y_{CO_2}k_{CO_2} + Y_{SO_2}k_{SO_2} + Y_{NO_x}k_{NO_x} \quad (40)$$

where Y represents the annual air pollution **generated** by different scenarios depicted in Table 13, and k is the social cost of various air pollutions shown in Table 12.

3. Results and Discussion

3.1. Description of the Simulation Method

After the mathematical modeling of the system, a computer program code was developed in engineering equation solver (EES) software. For the mixture of ammonia/water mixture properties calculation, the subroutine (NH₃H₂O) which is existing in the external library of the EES is used. Other working fluids' properties exist in EES software and they can be used easily by definition of thermodynamic function. The input information of the simulation program is depicted in Table 14.

Table 14. Input information of the simulation code

Parameter	Unit	Value	Ref
X_1	-	0.53	[45]
X_4	-	0.94	[45]
X_5	-	0.99	[45]
$\dot{m}_1$	kg/s	0.4	-
T_1	K	280	[45]
T_5	K	348	[45]
T_7	K	278	[45]
P_1	kPa	202.6	[45]
P_2	kPa	3039	[45]
x_{16}	mg/l	40200	[93]
x_{27}	mg/l	150	[93]
A_m	m ²	35.3	[94]
RR	-	0.3	[59]
$\dot{m}_{16}$	kg/s	2	-

3.2. Model Validation

Since the whole plant has not been investigated yet, the validation of the whole plant by using experimental data is not feasible. Thus, each of the sub-systems has been validated individually.

For validation of the combined power and cooling sub-systems (Goswami cycle), ref. [56] is considered. The input information of that reference is inserted into the computer simulation program. Table 15 shows the results of the comparison between the simulation model of this work with ref. [56].

Table 15. Results of the comparison between the simulation model with ref. [56]

No.	P ₁ (kPa)	P ₂ (kPa)	η_{en}		
			Model	Ref[56]	Error(%)
1	673.6	12124.8	3.54	3.5	1.2
2	673.6	12798.4	2.98	2.8	4.2
3	673.6	13472	2.36	2.2	2.5

The comparison shows that the errors in the three situations are 1.2%, 4.2%, and 2.5%, respectively.

For validation of the RO system, the ref. [59] is considered. The data from the table of that reference is inserted into the computer code. Table 16 shows the comparison between the results of the RO system and ref. [59]. The minimum and maximum errors are 0.7% and 7%, respectively.

For validation of the NaClO plants, the ref. [81] is considered. The electrical power requirement of the NaClO plant is 4 kW while it is 3.78 kW in the computer code developed for this study. The error is around 5.5%. The reason for this error is that the salt concentration in the feed mixture is unknown in ref. [81].

In conclusion, the developed computational code provides consistent results for each process sub-systems, in agreement with the previously published data.

Table 16. Comparison between the results of the RO system and ref. [59]

$\dot{m}_{brin}(\frac{kg}{s})$			$\dot{m}_{PW}(\frac{kg}{s})$			$\dot{W}_{recovery\ turbine}(kW)$			$\dot{W}_{P,RO}(kW)$		
Model	Ref	Error(%)	Model	Ref	Error(%)	Model	Ref	Error(%)	Model	Ref	Error(%)
1.092	1.104	0.7	0.468	0.456	2.6	3.45	3.711	7	8.42	8.96	6

3.3. Energy and Exergy Analyses

Table 17 shows the thermodynamic properties for each point of the system. Table 18 shows the annual system productions. By using this system, 1.075 GJ/year electrical energy, 1.04 GJ/year cooling energy, 18106.8 m³/year potable water, 7.396 Ton/year hydrogen, and 3.838 Ton/year salt are produced annually. The cooling and electrical energy in the combined cooling and power system are close. The ratio of cooling to electrical energy is 0.97 (around unit).

Figure 3 shows the system power production in three configurations (Goswami, Goswami/RO, Goswami/RO/NaClO(global system)). It is clear that by adding the RO and NaClO plants to the system, power production declines to 36.78 and 37.09 kW, respectively **due to electrical power consumption of the RO and NaClO plants.**

Figure 4 shows the energy and exergy efficiencies for three different configurations (Goswami, Goswami/RO, global system). It can be found that adding the RO system to the Goswami cycle increases the system energy efficiency from 10.2% to 12.4%. From the energy point of view, although adding the RO system to the Goswami cycle reduces the electrical power production, **the freshwater is also produced in the system ($\dot{m}_{25h25}$). The amount of this increase overcomes the reduction of the electrical power consumed in the RO system, since it adds the energy rate of the fresh water to the numerator of energy efficiency.** From an exergy point of view, adding the RO system to the Goswami cycle is not beneficial, since it reduces the exergy efficiency from 25.6% to 20.2%. It means that the electrical power exergy rate has a higher value than the freshwater

exergy rate. The reason for this phenomenon is that the RO system operates near the dead state (25°C, 101.3 kPa). So, the value of ($\dot{m}_{25}e_{25}$) in equation 25 is low. Adding the NaClO plant to the Goswami/RO reduces the energy and exergy efficiencies slightly from 12.4% and 20.2% to 12.25% and 19.6%, respectively. In both energy and exergy analyses, the penalty of consumed electrical power by the NaClO plant is higher than the products amount of energy and exergy. However, the small amount of electrical power consumed in NaClO plant compensates with the recovery turbine.

Table 17. Thermodynamic properties for each point of the system

No.	$\dot{m}$ (kg/s)	T (K)	P (kPa)	h (kJ/kg)	e (kJ/kg)
1	0.4	280	202.6	-208.9	-20.8
2	0.4	282	3039	-197	-17.62
3	0.4	287.4	3039	-172.5	-17.9
4	0.4	373	3039	1287	320.7
5	0.3429	348	3039	1273	324.1
6	0.3429	378	3039	1437	361.3
7	0.3429	278	202.6	1268	-1.841
8	0.3429	303	202.6	1364	-0.6563
9	0.05714	348	3039	132	26.04
10	0.05714	305	3039	-69.66	2.402
11	0.05714	305	202.6	532.1	-8.933
12	15	393.2	202.6	503.8	52.1
13	15	393.2	263.4	498.6	52.16
14	15	391.9	255.5	444.7	50.9
15	15	379.2	247.8	59.45	38.68
16	2	298.2	101.3	59.45	13.46
17	1	298.2	101.3	59.45	13.46
18	1	298.2	101.3	63.69	13.46
19	1	298.2	4767	63.69	17.98
20	1	298.2	4767	67.49	17.98
21	0.3	298.2	4767	61.83	4.659
22	0.7	298.2	4767	67.49	6.596
23	0.3	298.2	4767	61.83	4.659
24	0.7	298.2	4767	67.49	6.596
25	0.6	298.2	4767	63.05	4.659
26	0.6	298.2	101.3	61.83	0.000242
27	1.4	298.2	4767	57.84	6.596
28	1.4	298.2	303.9	57.84	2.323

29	0.014	298.2	101.3	3932	2.323
30	0.0002568	298.2	101.3	3932	5491
31	0.000133	312.2	101.3	274.7	0.8442

Table 18. Annual system productions

Product	Unit	Values
$W_{\text{net,system}}$	GJ/year	1.0751
Q_{cooling}	GJ/year	1.04
V_{PW}	m ³ /year	18106.8
m_{NaCl}	Ton/year	3.838
m_{H_2}	Ton/year	7.396

Figure 3. System power production in three configurations (Goswami, Goswami/RO, Goswami/RO/NaClO(system))

Figure 4. Energy and exergy efficiencies for three configurations (Goswami, Goswami/RO, global system)

Figure 5 shows the share of the exergy destruction rate for each subsystem. The maximum value is related to the Goswami cycle (87.31%). This is because this subsystem has the highest number of components and it operates at a temperature which is much higher than the two other subsystems. The RO plant has 11.04% of the total system exergy destruction rate. The reason is that the RO system operates at temperature (25°C) near the dead state (15°C, 101.3 kPa). Furthermore, this system has a lower number of components than the Goswami cycle. The lowest portion of the total exergy destruction rate is related to the NaClO plant (1.65%). The reason is that the mass flow rate of the brine water flowing through the NaClO plant is low. Similar to the RO system, this plant operates near the dead state. In general, the addition of these two sub-systems does not induce much exergy destruction on the system.

Figure 5. Share of the exergy destruction rate for each subsystem

3.4. Economic Analysis Results

Figure 6 shows the Net Present Value (NPV) from the Goswami, Goswami/RO, and total system, respectively. The NPV for the Goswami cycle is 0.826 million US dollars. Adding the RO system to the Goswami cycle is not beneficial considering this factor, because it decreases the NPV from 0.826 to 0.6 million US dollars. It means that the extra cost imposed on the system is higher than the product costs during the lifetime of this system. However, adding the NaClO plant is beneficial since the value of the NPV increased significantly from 0.6 to 3.1 (higher than five times). Unlike the RO system, in this case, the production benefits (salt and hydrogen) of the NaClO plant during the lifetime is higher than the initial cost. So, it can be concluded that producing NaClO and H₂ is beneficial from the economic point of view.

Figure 6. The NPV from the Goswami, Goswami/RO, and total system

The values of the Payback Period (PP) and Simple Payback Period (SPP) are shown in Figure 7. Adding the RO system to the Goswami cycle increases the PP and SPP from 4.26 and 3.95 years to 8.86 and 7.68 years, respectively. But adding the NaClO plant decreases these values. In general, the total system PP and SPP (2.7 and 2.56 years) are lower than the Goswami cycle and combination of Goswami and RO.

Figure 8 shows the internal rate of return for the Goswami, Goswami/RO, and the total system. By adding the RO system to the Goswami cycle, the IRR is reduced from 0.25 to 0.12. This reduction is not appropriate. Adding the NaClO plant to Goswami/RO system compensates this reduction (0.12 to 0.39).

From the economic analysis, it is clear that the RO system should be combined with the NaClO plant to bring more benefit to the system.

Figure 7. Values of PP and SPP for the Goswami, Goswami/RO, and the total system

Figure 8. Internal rate of return for the Goswami, Goswami/RO, and the total system

3.5. Exergoenvironmental Analysis Results

Figure 9 shows three exergoenvironmental factors (exergoenvironment (f_{ei}), environmental damage effectiveness (θ_{ei}), and exergy stability (f_{es})) for three configurations (Goswami, Goswami/RO, and total system), respectively.

Figure 9. Exergoenvironment (f_{ei}), environmental damage effectiveness (θ_{ei}), and exergy stability (f_{es}) factors for three configurations (Goswami, Goswami/RO, and total system)

The exergoenvironment factor (f_{ei}) increases by adding the RO and NaClO plant. If equation 35 is considered, it is clear that the denominator of this equation is the same for all three configurations, since in all three states, the energy resource is geothermal energy. However, the numerator of this equation is increased and each system added to the Goswami cycle has an exergy destruction rate. The trend of the environmental damage effectiveness factor (θ_{ei}) is similar to the exergoenvironmental factor (f_{ei}), since the exergy efficiency of the system does not improve by adding the RO and NaClO plants. Thus, this factor is increased due to higher exergy destruction rate and lower exergy efficiency.

The exergy stability factor is increased from 0.83 to 0.85 and 0.86, by adding the RO and NaClO systems to the Goswami cycle. It means that the exergy stability factor for Goswami, Goswami/RO, and the total system are 0.83, 0.85, and 0.86, respectively. This increase is however

not considerable. Considering the related equation (equation 36), it can be concluded that the amount of exergy destruction rate added to the Goswami cycle is higher than the output exergy of the added system. It means that the output exergy of the RO and NaClO system cannot compensate for the exergy destruction produced in these systems.

3.6. Environmental Analysis Results

As mentioned before in the environment section, four scenarios are considered for environmental evaluations.

Figure 10 shows the amount of CO₂, SO₂, NO_x produced by the four scenarios if producing the same amount of electrical power generated by the proposed system in this work. The maximum amount of pollution is related to carbon dioxide (CO₂). The highest amount of CO₂ is related to the third scenario (coal-fired power plant) and the minimum amount of CO₂ is related to the fourth scenario (gas turbine with heat recovery boiler and back-pressure steam turbine). Similar to CO₂, the maximum and minimum amounts of NO_x are related to the third and fourth scenarios.

The first and fourth scenarios do not exhibit any sulfur dioxide production. The maximum amount of SO₂ is related to the third scenario.

Figure 10. Amount of CO₂, SO₂, NO_x produced in the four scenarios

As mentioned before, if the social cost of air pollutions generated by the four scenarios is considered in the economic investigation, due to the absence of air pollution produced by the proposed system in this work, the economic factors (NPV, PP, SPP, IRR) are changed considerably.

Figure 11 shows the amount of NPV if the social cost of air pollution by each scenario is considered. The third scenario displays the maximum amount of NPV, since this scenario generates the maximum amount of air pollution in comparison with other scenarios.

Assuming that the same electrical power of the proposed system is produced by the third scenario and considering the social cost of air pollution, the NPV is changed from 3.1 million US\$ to 3.58 million US\$. If the first, second, and fourth scenarios are considered, this value is changed to 3.17, 3.28, and 3.17 million US\$, respectively. It can be concluded that by inserting the social cost of air pollution, the multigeneration system powered by renewable energy is more beneficial.

Figure 11. Amount of NPV considering the social cost of air pollution by the four scenarios

Figure 12 shows the comparison of PP and SPP between the system and scenarios I to IV when these scenarios produce the same amount of electrical power. By considering the social cost of air pollution, the amounts of PP and SPP are reduced. For example, if the third scenario is considered,

the amount of PP and SPP are reduced from 2.7 and 2.56 years to 2.32 and 2.2 years, respectively. The various amounts of the IRR for the system and four scenarios are shown in Figure 13. The same results can be observed in this figure too. By considering the social cost of air pollution, this factor is improved from 0.39 to 0.41, 0.42, 0.45, and 0.41 for the first to fourth scenario, respectively. The maximum amount of IRR is related to the third scenario that relies on the coal power plant with the highest air pollution impact.

Figure 12. Comparison of PP and SPP between the system and scenarios I to IV

Figure 13. IRR for the system and four scenarios

In general, it can be concluded that if the social cost of air pollution or other sources of pollution is considered in the economic evaluation of the renewable energy powered systems, such multi-generation systems are more economical.

4. Conclusion

This study investigated a combined cogeneration system including the combined power and cooling system (Goswami cycle), Reverse Osmosis (RO), and NaClO production plant. The products of this system are electrical and cooling energy, potable water, hydrogen, and NaClO (salt).

The energy, exergy, economic, exergoenvironmental, and environmental analyses were conducted in this work to assess all of the aspects of this system. For the environmental analysis and establishment of a relationship between environmental pollutions and economics, the social cost of air pollution was considered. In this regard, four scenarios were defined. It is assumed the same amount of electrical power is produced by the non-renewable energy resource power production systems. These systems are gas turbines with natural gas and gas oil fuels, coal fired steam power plants, and natural gas fueled gas turbines with heat recovery boiler and backpressure steam turbine.

The air pollutions generated by these systems are estimated by typical data existing in literature. By considering these social costs as benefits for this proposed system due to the absence of air pollution produced during the operation time, the environmental effect can be highlighted.

Summly, the main results of this research are as follows:

- This system produces 1.075 GJ/year electrical energy, 1.04 GJ/year cooling energy, 18106.8 m³/year potable water, 7.396 Ton/year hydrogen, and 3.838 Ton/year salt are produced annually.
- The system energy efficiency for the Goswami, Goswami/RO, and the total system are equal to 10.2%, 12.4%, and 12.25%, respectively.
- The system exergy efficiency for the Goswami, Goswami/RO, and the total system are equal to 25.6%, 20.2%, and 19.6%, respectively.
- The share of the exergy destruction rate for the Goswami cycle, RO, and NaClO plant are 87.3%, 11.04%, and 1.65%, respectively.
- The system NPV, PP, SPP, IRR are equal to 3.1 million US\$, 2.7 years, 2.56 years, and 0.39, respectively.
- The f_{ei} , Θ_{ei} , f_{es} for the total system are 1.45, 7.43, and 0.86, respectively.
- Adding the NaClO plant to the system is appropriate from economic point of view.
- By considering the social cost of air pollution in economic evaluation, the renewable energy resource multi-generation systems can be more economical.

Nomenclature

Abbreviation	Definition
AFC	Ammonia fuel cell
ASR	Absorption refrigeration
CPVT	Concentrated Photovoltaics/Thermal
DHW	Domestic Hot Water
ED	Electrodialysis, Electrolyzer
ESC	Evacuated Solar Collector
FC	Fuel Cell
FGPP	Flash-Binary Geothermal Power Plant

GO	Gas Oil
HDH	Humidification-Dehumidification unit
KC	Kalina Cycle
LCOE	Levelized Cost of Electricity
LCOW	Levelized Cost of water
MD	Membrane Distillation
MED	Multi-Effect Distillation
MSF	Multi-Stage Flash Distillation
NG	Natural Gas
ORC	Organic Rankin Cycle
PCM	Phase Change Material
PEMFC	Proton Exchange Membrane Fuel Cell
PRO	Pressure Retarded Osmosis
PTC	Parabolic Through Collector
PV	Photovoltaic
RHE	Refrigeration Heat Exchanger
RHX	Recovery Heat Exchanger
RO	Reverse Osmosis
SC	Steam Cycle
SD	Solar Dish
SSE	Single Stage Evaporator
SUCP	Sum Unit Cost of Product
TES	Thermal Energy Storage
TGOR	Trigeneration-based Gain-Output-Ratio
VC	Vapor-Compression Evaporation

Symbols	Unit	Definition
A	m ²	Area
C₀	US\$	System investment cost
C_{ei}	-	Exergoenvironmental impact coefficient
C_n	US\$	System investment cost in the specific year with considering inflation rate
CF	US\$	Cogeneration annual income
D	m	Diameter
e	kJ/kg	Specific exergy
$\dot{E}$	kW	Exergy rate

f_{ei}	-	Exergoenvironment factor
f_{es}	-	Exergy stability factor
F_t	-	Correction factor
g	m/s ²	Gravitational acceleration
h	kJ/kg	Specific enthalpy
IRR	-	Internal rate of return
k	US\$/kWh	Products specific cost
K	US\$	Investment and installation cost of each subsystem
K_w	1/K	Water permeability coefficient
$\dot{m}$	kg/s	Mass flow rate
N	Years	Lifetime of the project
NPV	US\$	Net Present Value
P	kPa	Pressure
PP	Years	Payback Period
$\dot{Q}$	kW	Heat transfer rate
r	-	Discount factor
R	kJ/kmoleK	Global gas constant
RR	-	Recovery ratio
s	kJ/kgK	Specific entropy
SPP	Years	Simple Payback Period
T	°C/K	Temperature
U	W/m ² K	Overall heat transfer coefficient
V	m/s, m ³	Velocity, Volume
$\dot{W}$	kW	Work transfer rate
x	-	Concentration of salt, Mass fraction
X	-	Ammonia mass ratio
y	-	Mole fraction
Y	US\$/kWh, US\$/kg	Annual capacity of system productions
z	m	Height, Depth of geothermal well
Greek Symbols		
η	-	Polytrophic efficiency
$\Delta\pi$	kPa	Net-pressure membrane
θ_{ei}	-	Environmental damage effectiveness factor

θ_{eii}	-	Exergoenvironmental impact
Subscripts		Definition
0		Dead state
BW		Brain water
ch		Chemical
D		Destruction
en		Energy
ex		Exergy
f		Formation
i		Species
in		Inlet
out		Outlet
m		Membrane
P		Product, Pump
PW		Potable water
R		Reactant
Sep		Seperator
SW		Seawater
T		Turbine

References

- [1] The Global Risks Report 2019, [weforum.org/reports/the-global-risks-report-2019](https://www.weforum.org/reports/the-global-risks-report-2019) [Access 03.06.2020], in, 2019.
- [2] M. Ehyaei, S. Hakimzadeh, N. Enadi, P. Ahmadi, Exergy, economic and environment (3E) analysis of absorption chiller inlet air cooler used in gas turbine power plants, *International Journal of Energy Research*, 36 (2012) 486-498.
- [3] M.M. Mekonnen, A.Y. Hoekstra, Four billion people facing severe water scarcity, *Science Advances*, 2 (2016) e1500323.
- [4] How do we prevent today's water crisis becoming tomorrow's catastrophe? [weforum.org/agenda/2017/03/building-freshwater-resilience-to-anticipate-and-address-water-crises](https://www.weforum.org/agenda/2017/03/building-freshwater-resilience-to-anticipate-and-address-water-crises) [Access 03.06.2020] in, 2017.
- [5] C.J. Vörösmarty, P. Green, J. Salisbury, R.B. Lammers, Global Water Resources: Vulnerability from Climate Change and Population Growth, *Science*, 289 (2000) 284-288.
- [6] R.G. Raluy, L. Serra, J. Uche, A. Valero, Life-cycle assessment of desalination technologies integrated with energy production systems, *Desalination*, 167 (2004) 445-458.
- [7] A.D. Khawaji, J.-M. Wie, Potabilization of desalinated water at Madinat Yanbu Al-Sinaiyah, *Desalination*, 98 (1994) 135-146.

- [8] M. Al-Shammiri, M. Safar, Multi-effect distillation plants: state of the art, *Desalination*, 126 (1999) 45-59.
- [9] O.K. Buross, The ABCs of Desalting, in, International Desalination Association, Topsfield, Massachusetts, USA, 2000.
- [10] The Desalting and Water Treatment Membrane Manual: A Guide to Membranes for Municipal Water Treatment, Water Treatment Technology Program, Report No. 1, usbr.gov/research/dwpr/reportpdfs/report001.pdf [Access 03.06.2020], in, the United States Department of the Interior, Bureau of Reclamation, Denver Office, Research and Laboratory Services Division, Applied Sciences Branch (R-93-15), 1993.
- [11] A.D. Khawaji, I.K. Kutubkhanah, J.-M. Wie, Advances in seawater desalination technologies, *Desalination*, 221 (2008) 47-69.
- [12] T. Xu, Ion exchange membranes: State of their development and perspective, *Journal of Membrane Science*, 263 (2005) 1-29.
- [13] J.E. Miller, Review of Water Resources and Desalination Technologies in, Sandia National Laboratories Albuquerque, New Mexico 87185 and Livermore, California 94550 2003.
- [14] M.I.M. Shatat, Solar water desalination, in, , School of Engineering, Durham University, UK, 2008.
- [15] Water Desalination Technologies in the ESCWA Member Countries, in, United Nations. Economic and Social Commission for Western Asia, 2001.
- [16] M.A. Darwish, H. El-Dessouky, The heat recovery thermal vapour-compression desalting system: A comparison with other thermal desalination processes, *Applied Thermal Engineering*, 16 (1996) 523-537.
- [17] S. Karellas, A. Schuster, A. Leontaritis, Influence of supercritical ORC parameters on plate heat exchanger design, *Applied Thermal Engineering*, s 33–34 (2012) 70–76.
- [18] S.A. Kalogirou, Seawater desalination using renewable energy sources, *Progress in Energy and Combustion Science*, 31 (2005) 242-281.
- [19] W. Rice, D.S.C. Chau, Freeze desalination using hydraulic refrigerant compressors, *Desalination*, 109 (1997) 157-164.
- [20] H. Chen, L. Wang, Chapter 8 - Posttreatment Strategies for Biomass Conversion, in: H. Chen, L. Wang (Eds.) *Technologies for Biochemical Conversion of Biomass*, Academic Press, Oxford, 2017, pp. 197-217.
- [21] M.W. Shahzad, M. Burhan, L. Ang, K.C. Ng, Energy-water-environment nexus underpinning future desalination sustainability, *Desalination*, 413 (2017) 52-64.
- [22] H. Mahmoudi, N. Ghaffour, M.F. Goosen, J. Bundschuh, *Renewable energy technologies for water desalination*, CRC Press, 2017.
- [23] M.A. Ehyaei, A. Ahmadi, M. El Haj Assad, M.A. Rosen, Investigation of an integrated system combining an Organic Rankine Cycle and absorption chiller driven by geothermal energy: Energy, exergy, and economic analyses and optimization, *Journal of Cleaner Production*, 258 (2020) 120780.
- [24] M. El Haj Assad, E. Bani-Hani, M. Khalil, Performance of geothermal power plants (single, dual, and binary) to compensate for LHC-CERN power consumption: comparative study, *Geothermal Energy*, 5 (2017) 17.
- [25] H. Kianfard, S. Khalilarya, S. Jafarmadar, Exergy and exergoeconomic evaluation of hydrogen and distilled water production via combination of PEM electrolyzer, RO desalination unit and geothermal driven dual fluid ORC, *Energy Conversion and Management*, 177 (2018) 339-349.
- [26] L. Ozgener, A. Hepbasli, I. Dincer, Energy and exergy analysis of the Gonen geothermal district heating system, Turkey, *Geothermics*, 34 (2005) 632-645.
- [27] M.A. Abdelkareem, M. El Haj Assad, E.T. Sayed, B. Soudan, Recent progress in the use of renewable energy sources to power water desalination plants, *Desalination*, 435 (2018) 97-113.

- [28] V. Zare, A comparative thermodynamic analysis of two tri-generation systems utilizing low-grade geothermal energy, *Energy Conversion and Management*, 118 (2016) 264-274.
- [29] O. Siddiqui, I. Dincer, A new solar and geothermal based integrated ammonia fuel cell system for multigeneration, *International Journal of Hydrogen Energy*, (2020).
- [30] A. Mohammadi, M. Mehrpooya, Energy and exergy analyses of a combined desalination and CCHP system driven by geothermal energy, *Applied Thermal Engineering*, 116 (2017) 685-694.
- [31] B. Ghorbani, A. Ebrahimi, M. Moradi, M. Ziabasharhagh, Energy, exergy and sensitivity analyses of a novel hybrid structure for generation of Bio-Liquefied natural Gas, desalinated water and power using solar photovoltaic and geothermal source, *Energy Conversion and Management*, 222 (2020) 113215.
- [32] P. Behnam, A. Arefi, M.B. Shafii, Exergetic and thermoeconomic analysis of a trigeneration system producing electricity, hot water, and fresh water driven by low-temperature geothermal sources, *Energy Conversion and Management*, 157 (2018) 266-276.
- [33] A. Colmenar-Santos, E. Palomo-Torrejón, F. Mur-Pérez, E. Rosales-Asensio, Thermal desalination potential with parabolic trough collectors and geothermal energy in the Spanish southeast, *Applied Energy*, 262 (2020) 114433.
- [34] T. Gholizadeh, M. Vajdi, H. Rostamzadeh, A new trigeneration system for power, cooling, and freshwater production driven by a flash-binary geothermal heat source, *Renewable Energy*, 148 (2020) 31-43.
- [35] S.A. Makkeh, A. Ahmadi, F. Esmaeilion, M.A. Ehyaei, Energy, exergy and exergoeconomic optimization of a cogeneration system integrated with parabolic trough collector-wind turbine with desalination, *Journal of Cleaner Production*, 273 (2020) 123122.
- [36] A. Shekari Namin, H. Rostamzadeh, P. Nourani, Thermodynamic and thermoeconomic analysis of three cascade power plants coupled with RO desalination unit, driven by a salinity-gradient solar pond, *Thermal Science and Engineering Progress*, 18 (2020) 100562.
- [37] A. Mouaky, A. Racheq, Thermodynamic and thermo-economic assessment of a hybrid solar/biomass polygeneration system under the semi-arid climate conditions, *Renewable Energy*, 156 (2020) 14-30.
- [38] B. Ghorbani, R. Shirmohammadi, M. Mehrpooya, Development of an innovative cogeneration system for fresh water and power production by renewable energy using thermal energy storage system, *Sustainable Energy Technologies and Assessments*, 37 (2020) 100572.
- [39] F. Calise, F.L. Cappiello, R. Vanoli, M. Vicidomini, Economic assessment of renewable energy systems integrating photovoltaic panels, seawater desalination and water storage, *Applied Energy*, 253 (2019) 113575.
- [40] G. Filippini, M.A. Al-Obaidi, F. Manenti, I.M. Mujtaba, Design and economic evaluation of solar-powered hybrid multi effect and reverse osmosis system for seawater desalination, *Desalination*, 465 (2019) 114-125.
- [41] N. Sezer, M. Koç, Development and performance assessment of a new integrated solar, wind, and osmotic power system for multigeneration, based on thermodynamic principles, *Energy Conversion and Management*, 188 (2019) 94-111.
- [42] Q. Li, L.-J. Beier, J. Tan, C. Brown, B. Lian, W. Zhong, Y. Wang, C. Ji, P. Dai, T. Li, P. Le Clech, H. Tyagi, X. Liu, G. Leslie, R.A. Taylor, An integrated, solar-driven membrane distillation system for water purification and energy generation, *Applied Energy*, 237 (2019) 534-548.
- [43] F. Xu, Analysis of a novel combined thermal power and cooling cycle using ammonia-water mixtures as a working fluid, in, University of Florida, 1997.
- [44] G. Tamm, D.Y. Goswami, S. Lu, A.A. Hasan, Novel Combined Power and Cooling Thermodynamic Cycle for Low Temperature Heat Sources, Part I: Theoretical Investigation, *Journal of Solar Energy Engineering*, 125 (2003) 218-222.
- [45] D.Y. Goswami, F. Xu, Analysis of a New Thermodynamic Cycle for Combined Power and Cooling Using Low and Mid Temperature Solar Collectors, *Journal of Solar Energy Engineering*, 121 (1999) 91-97.

- [46] G. Tamm, D.Y. Goswami, S. Lu, A.A. Hasan, Theoretical and experimental investigation of an ammonia–water power and refrigeration thermodynamic cycle, *Solar Energy*, 76 (2004) 217-228.
- [47] A. Behzadi, E. Gholamian, P. Ahmadi, A. Habibollahzade, M. Ashjaee, Energy, exergy and exergoeconomic (3E) analyses and multi-objective optimization of a solar and geothermal based integrated energy system, *Applied Thermal Engineering*, 143 (2018) 1011-1022.
- [48] S.M. Alirahmi, S. Rahmani Dabbagh, P. Ahmadi, S. Wongwises, Multi-objective design optimization of a multi-generation energy system based on geothermal and solar energy, *Energy Conversion and Management*, 205 (2020) 112426.
- [49] R. Yargholi, H. Kariman, S. Hoseinzadeh, M. Bidi, A. Naseri, Modeling and advanced exergy analysis of integrated reverse osmosis desalination with geothermal energy, *Water Supply*, 20 (2020) 984-996.
- [50] B.H. Gebreslassie, G. Guillén-Gosálbez, L. Jiménez, D. Boer, Design of environmentally conscious absorption cooling systems via multi-objective optimization and life cycle assessment, *Applied Energy*, 86 (2009) 1712-1722.
- [51] A. Al-Zahrani, J. Orfi, Z. Al-Suhaibani, B. Salim, H. Al-Ansary, Thermodynamic Analysis of a Reverse Osmosis Desalination Unit with Energy Recovery System, *Procedia Engineering*, 33 (2012) 404-414.
- [52] A. Ahmadi, M. El Haj Assad, D.H. Jamali, R. Kumar, Z.X. Li, T. Salameh, M. Al-Shabi, M.A. Ehyaei, Applications of geothermal organic Rankine Cycle for electricity production, *Journal of Cleaner Production*, 274 (2020) 122950.
- [53] E. Ghasemian, M.A. Ehyaei, Evaluation and optimization of organic Rankine cycle (ORC) with algorithms NSGA-II, MOPSO, and MOEA for eight coolant fluids, *International Journal of Energy and Environmental Engineering*, 9 (2018) 39-57.
- [54] M.A. Ehyaei, A. Ahmadi, M.A. Rosen, A. Davarpanah, Thermodynamic Optimization of a Geothermal Power Plant with a Genetic Algorithm in Two Stages, *Processes*, 8 (2020) 1277.
- [55] A. Bejan, *Advanced engineering thermodynamics*, John Wiley & Sons, 2016.
- [56] G. Demirkaya, R.V. Padilla, A. Fontalvo, M. Lake, Y.Y. Lim, Thermal and Exergetic Analysis of the Goswami Cycle Integrated with Mid-Grade Heat Sources, *Entropy*, 19 (2017) 416.
- [57] F. Xu, D.Y. Goswami, S.S. Bhagwat, A combined power/cooling cycle, *Energy*, 25 (2000) 233-246.
- [58] D.Y. Goswami, F. Xu, Analysis of a new thermodynamic cycle for combined power and cooling using low and mid temperature solar collectors, (1999).
- [59] A. Naseri, M. Bidi, M.H. Ahmadi, Thermodynamic and exergy analysis of a hydrogen and permeate water production process by a solar-driven transcritical CO₂ power cycle with liquefied natural gas heat sink, *Renewable Energy*, 113 (2017) 1215-1228.
- [60] H.T. El-Dessouky, H.M. Ettouney, *Fundamentals of salt water desalination*, Elsevier, 2002.
- [61] A. Lazzaretto, G. Tsatsaronis, SPECO: a systematic and general methodology for calculating efficiencies and costs in thermal systems, *Energy*, 31 (2006) 1257-1289.
- [62] A. Bejan, G. Tsatsaronis, M. Moran, *Thermal Design and Optimization* John Wiley and Sons, Inc. New York, (1996).
- [63] E. Bellos, S. Pavlovic, V. Stefanovic, C. Tzivanidis, B.B. Nakomcic-Smaradgakis, Parametric analysis and yearly performance of a trigeneration system driven by solar-dish collectors, *International Journal of Energy Research*, 43 (2019) 1534-1546.
- [64] C. Tzivanidis, E. Bellos, K.A. Antonopoulos, Energetic and financial investigation of a stand-alone solar-thermal Organic Rankine Cycle power plant, *Energy conversion and management*, 126 (2016) 421-433.
- [65] H. Nami, I.S. Ertesvåg, R. Agromayor, L. Riboldi, L.O. Nord, Gas turbine exhaust gas heat recovery by organic Rankine cycles (ORC) for offshore combined heat and power applications-Energy and exergy analysis, *Energy*, 165 (2018) 1060-1071.
- [66] M. Mishra, P.K. Das, S. Sarangi, Optimum design of crossflow plate-fin heat exchangers through genetic algorithm, (2004).

- [67] A. Ahmadi, D.H. Jamali, M.A. Ehyaei, M.E.H. Assad, Energy, exergy, economic and exergoenvironmental analyses of gas and air bottoming cycles for production of electricity and hydrogen with gas reformer, *Journal of Cleaner Production*, 259 (2020) 120915.
- [68] <https://www.flinnsci.com/sodium-chloride-laboratory-grade-500-g/s0063/> [Access 03.06.2020], in, 2020.
- [69] H. Nami, E. Akrami, Analysis of a gas turbine based hybrid system by utilizing energy, exergy and exergoeconomic methodologies for steam, power and hydrogen production, *Energy Conversion and Management*, 143 (2017) 326-337.
- [70] J.C.E.P. Carlos Eymel Campos Rodríguez, César Rodríguez Sotomonte, Marcio Lemea, Osvaldo J. Venturinia, Electro E. Silva Lora, Vladimir Melián Cobasa, Daniel Marques dos Santosb, Fábio R. Lofraro Dottoc, Vernei Giallucad, Exergetic and economic analysis of Kalina cycle for low temperature geothermal sources in Brazil, in: *The 25th international conference on efficiency, cost, optimization, simulation and environmental impact of energy systems*, Perugia, Italy, 2012, pp. 1-13.
- [71] P. Dorj, Thermoeconomic Analysis of a New Geothermal Utilization CHP Plant in Tsetserleg, in: *Department of Mechanical and Industrial Engineering, Iceland, University of Iceland*, 2005.
- [72] A. Bejan, G. Tsatsaronis, M.J. Moran, *Thermal design and optimization*, John Wiley & Sons, 1995.
- [73] K. Bahloul, R. Khoshbakhti Saray, N. Sarabchi, Parametric investigation and thermo-economic multi-objective optimization of an ammonia–water power/cooling cycle coupled with an HCCI (homogeneous charge compression ignition) engine, *Energy*, 86 (2015) 672-684.
- [74] L.S. Vieira, J.L. Donatelli, M.E. Cruz, Exergoeconomic improvement of a complex cogeneration system integrated with a professional process simulator, *Energy Conversion and Management*, 50 (2009) 1955-1967.
- [75] R. Turton, R.C. Bailie, W.B. Whiting, J.A. Shaeiwitz, *Analysis, synthesis and design of chemical processes*, Pearson Education, 2008.
- [76] J.L. Silveira, C.E. Tuna, Thermoeconomic analysis method for optimization of combined heat and power systems. Part I, *Progress in Energy and Combustion Science*, 29 (2003) 479-485.
- [77] M. Ameri, P. Ahmadi, A. Hamidi, Energy, exergy and exergoeconomic analysis of a steam power plant: A case study, *International Journal of Energy Research*, 33 (2009) 499-512.
- [78] M.L. Koenraad F. Beckers, Timothy J. Reber, Brian J. Anderson, Michal C. Moore, Jefferson W. Tester, Introducing geophires V1.0 software package for estimating levelized cost of electricity and/or heat from enhanced geothermal systems, in: *Thirty-Eighth Workshop on Geothermal Reservoir Engineering*, Stanford University, Stanford, California, USA, 2012.
- [79] Y. Du, L. Xie, J. Liu, Y. Wang, Y. Xu, S. Wang, Multi-objective optimization of reverse osmosis networks by lexicographic optimization and augmented epsilon constraint method, *Desalination*, 333 (2014) 66-81.
- [80] Establishment of cost functions for construction of various types of public water services assets in Portugal, in, 2003.
- [81] Sodium hypochlorite production plant of chlorination system chemical production plant [alibaba.com/product-detail/Sodium-hypochlorite-production-plant-of-chlorination_60489161719](https://www.alibaba.com/product-detail/Sodium-hypochlorite-production-plant-of-chlorination_60489161719) [Access 03.06.2020], in, 2020.
- [82] L. Pierobon, T.-V. Nguyen, U. Larsen, F. Haglind, B. Elmegaard, Multi-objective optimization of organic Rankine cycles for waste heat recovery: Application in an offshore platform, *Energy*, 58 (2013) 538-549.
- [83] S.J. Zarrouk, M.H. Purnanto, Geothermal steam-water separators: Design overview, *Geothermics*, 53 (2015) 236-254.
- [84] T. Shafer, Calculating Inflation Factors for Cost Estimates, in, *City of Lincoln Transportation and Utilities Project Delivery*.
- [85] Statista, Global inflation rate compared to previous year, in.
- [86] S. Edalati, M. Ameri, M. Iranmanesh, H. Tarmahi, M. Gholampour, Technical and economic assessments of grid-connected photovoltaic power plants: Iran case study, *Energy*, 114 (2016) 923-934.

- [87] T.A. Ratlamwala, I. Dincer, M.A. Gadalla, Comparative environmental impact and sustainability assessments of hydrogen and cooling production systems, in: *Causes, Impacts and Solutions to Global Warming*, Springer, 2013, pp. 389-408.
- [88] T.A. Ratlamwala, I. Dincer, B.V. Reddy, Exergetic and Environmental Impact Assessment of an Integrated System for Utilization of Excess Power from Thermal Power Plant, in: *Causes, Impacts and Solutions to Global Warming*, Springer, 2013, pp. 803-824.
- [89] A. Midilli, I. Dincer, Development of some exergetic parameters for PEM fuel cells for measuring environmental impact and sustainability, *International Journal of Hydrogen Energy*, 34 (2009) 3858-3872.
- [90] J.S. David Birchby, Sally Whiting,, M. Vedrenne, Air Quality damage cost update 2019, in, 2019.
- [91] S. Karkour, Y. Ichisugi, A. Abeynayaka, N. Itsubo, External-Cost Estimation of Electricity Generation in G20 Countries: Case Study Using a Global Life-Cycle Impact-Assessment Method, *Sustainability*, 12 (2020) 2002.
- [92] Combined Heat and Power (CHP) Developers Guides in, United Kingdom Government Department of Energy & Climate Change 2009.
- [93] H.I. Emara, Nutrient salts, inorganic and organic carbon contents in the waters of the Persian Gulf and the Gulf of Oman, *Journal of the Persian Gulf*, 1 (2010) 33-44.
- [94] FILMTEC™ Membranes How to Evaluate the Active Membrane Area of Seawater Reverse Osmosis Elements, [dupont.com/content/dam/dupont/amer/us/en/water-solutions/public/documents/en/45-D01504-en.pdf](https://www.dupont.com/content/dam/dupont/amer/us/en/water-solutions/public/documents/en/45-D01504-en.pdf) [Access 03.06.2020] (2015).

Response to reviewers' comments

Dear Respectful Editor-in-Chief

Journal: Desalination

The revision-1 of paper entitled” Energy, Exergy, Economic, Exergoenvironmental, and Environmental analyses of a Multigeneration System to Produce Electricity, Cooling, Potable Water, Hydrogen and Sodium-Hypochlorite” is attached. All the changes are highlighted by yellow color in the revised manuscript.

Reviewer #1:

- 1) This is a comprehensive study utilizing renewable energy (geothermal energy) with conventional membrane process (reverse osmosis). Electrolysis process (sodium hypochlorite) production was also considered. Energy, exergy, economic, exergoenvironmental, and environmental analyses of this multigeneration system was investigated for the production of electricity, cooling, potable water, hydrogen and sodium-hypochlorite. Since this work represent a potential use of such system, I recommend its publication with minor modifications and moderate priorities.

Ans. Thank you for your support.

- 2) The justification of utilizing such a combine system is not shown; i.e the added values (benefits, contribution) of each process on the integrated system are not described.

Ans. Thank you for your valuable comment. The following paragraph has been added to the paper as shown below:

The benefits of the proposed desalination system are varied and the key products are potable water (as main needs for humanity), hydrogen (a key clean fuel for the transportation sector), electrical and cooling energy (as needs for residential, commercial, and industrial applications), and sodium-hypochlorite (a valuable co-product).

Reviewer #2:

- 1) In this paper very useful information on 5E analyses of a Multigeneration System to Produce Electricity, Cooling, Potable Water, Hydrogen and Sodium Hypochlorite is provided.

Ans. Thank you for your support.

- 2) Introduction is very general without any data. Author should provide information on Electricity, Cooling, Potable Water, Hydrogen and Sodium Hypochlorite production, demand and estimated gap in neat future.

Ans. Thank you for your valuable comment. More details about the Electricity, Cooling, Potable Water, Hydrogen and Sodium Hypochlorite production have been added in the Introduction, and are highlighted in the text.

- 3) They only highlighted partially water production information in introduction and totally ignored other parameters mentioned in the title.

Ans. The introduction has been extended to address the other parameters mentioned in the title in addition to water production. A review of different multigeneration systems coupled with renewable energy has been included.

- 4) The desalination related information presented in the literature is also not latest, they should read latest developments and present accordingly. They can read following article for latest desalination processes related information.

* Muhammad Wakil Shahzad, Muhammad Burhan, Li Ang and Kim Choon Ng, Energy-water-environment nexus underpinning future desalination sustainability, Desalination 413 (2017) 52-64.

Ans. The literature survey has been updated with different recent references added in the introduction, and the mentioned reference has also been added to the paper as shown below:

Based on a survey carried out by Shahzad et al. [6], the potable water demand will increase up to 60 billion m³ by 2050. This huge amount of water production can be achieved with different types of desalination systems so that the total energy consumption of desalination systems reaches 75.2 TWh per year. Moreover, it was recommended to improve the thermodynamic efficiency of the desalination systems from 10% to 25%, develop high flux membrane material for RO system, and design high-efficiency hybrid MED/MSF desalination systems.

- 5) Table 2 is incomplete. The energy and exergy efficiency is depend on operational parameters those are missing and the current values providing wrong impression about different technologies. For example, geothermal energy efficiency 73%, one can get at 40C?. Author should provide related operational parameters in the table.

Ans. Additional details about different operational conditions of Table 2 are now mentioned in the text highlighted in yellow (introduction section). Furthermore, the summary of previous studies is reported in Table 2.

6) In section 2.1 author mentioned, After careful investigation of the multi/co-generation systems and different products from them, but in actual they only provided the literature on water production. Not sure why they keep calling it multigeneration system.

Ans. The literature survey for various multigeneration systems now covers the various products in addition to water production. The fourth column in Table 2 specifies the products of each system reviewed in literature. This column is highlighted as shown below:

No.	Energy resource	Components	Products	Analysis	Energy efficiency (%)	Exergy efficiency (%)	Cost of products	Ref
1	Solar/Geothermal	RO; PEMFC; ASR; AFC; HSR	Electricity, Freshwater, Hydrogen, and Cooling	Energy/Exergy	42.3	21.3	-	[29]
2	Geothermal	KC, RO	Electricity, Heating, Cooling, and Freshwater	Energy/Exergy	-	38.1	-	[30]
3	Solar/Geothermal	Biogas system, MED, ORC; PV	Bio-liquefied natural gas; Freshwater, Electricity	Energy/Exergy	73.2	76.8	-	[31]
4	Geothermal	ORC; ASR; SSE	Electricity, Hot and Fresh water	Energy/Exergy/ Thermoeconomic	34	43	LCOE= 0.04 \$/kWh LCOW= 29.4 \$/m ³	[32]
5	Solar/Geothermal	PTC; MED	Freshwater	Feasibility study	-	-	-	[33]
6	Geothermal	FGPP; HDH	Electricity/Cooling	Energy/Exergy	46.4	TGOR= 0.9275	-	[34]
7	Solar/Geothermal	MED; PTC; ORC	Electricity; Cooling; Heating; Freshwater; Absorption Chiller	Exergy/Exergoeconomic	-	63	Electricity exergoeconomic cost= 0.1475–0.1722€/kW h Chilled water exergoeconomic cost= 0.1863–0.1888€/kW hex Cooling water exergoeconomic cost= 0.01612–0.01702€/kW hex Freshwater exergoeconomic cost= 0.5695–0.6023€/kW hex.	[34]
8	Solar/Wind	PTC; Wind turbine; MED; RO	Electricity/Fresh water	Energy/ Exergy/ Exergoeconomic	-	26.2	Fresh water cost= 3.08 \$/m ³	[35]
9	Solar	Solar Pond; KC; ORC; RO	Electricity/Freshwater	Thermodynamic/ Thermoeconomic	-	18	SUCP= 101.7 \$/kWh	[36]
10	Solar/Biomass		Electricity/ Freshwater/, domestic hot water (DHW)	Thermodynamic/ Thermoeconomic	11.3–16.3	5.3–6	Electricity cost= 0.231 €/kW Fresh water cost= 0.86 €/m ³ DHW cost= 0.047 €/kW	[37]
11	Solar	SD; PCM; SC; MED	Electricity; Freshwater	Energy/ Exergy	28.8	52.2	-	[38]
12	Solar	PV; RO	Electricity; Freshwater	Economic	-	-	PP = 1.3 years	[39]
13	Solar	PV; MED; RO	Electricity; Fresh water	Economic	-	-	Electricity cost= 0.1 €/kWh Fresh water cost= 0.59 €/m ³	[40]

14	Solar/Wind	Wind Turbine; CPVT; TES; FC; EL; MSF; VCR; PRO	Electricity; Freshwater; Cooling; Hydrogen	Energy/ Exergy	73.3	30.6	-	[41]
15	Solar	ESC; MD	Freshwater	Economic	-	-	PP = 4 years	[42]

Abbreviations: Reverse Osmosis: RO; Proton Exchange Membrane Fuel Cell: PEMFC; Absorption Refrigeration: ASR; Ammonia Fuel Cell: AFC; Organic Rankin Cycle: ORC; Single Stage Evaporator: SSE; Photovoltaic: PV; Levelized Cost of Electricity: LCOE; Levelized Cost of water: LCOW; Parabolic Through Collector: PTC; Trigenation-based Gain-Output-Ratio: TGOR; Flash-Binary Geothermal Power Plant: FGPP; Humidification-Dehumidification unit: HDH; Kalina Cycle: KC; SUCP: Sum Unit Cost of Product; Domestic Hot Water: DHW; PCM: Phase Change Material; Steam Cycle: SC; Solar Dish: SD; PP: Payback Period; CPVT: Concentrated Photovoltaics/Thermal; TES: Thermal Energy Storage; Electrolyzer: EL; Fuel Cell: FC; Multistage Flash Distillation: MSF; Vapor Compression Refrigeration: VCR; Pressure Retarded Osmosis: PRO; Evacuated Solar Collector: ESC

7) Goswami cycle is not the same as ammonia chiller?, if yes, then it should not be called as innovation.

Ans. The Goswami cycle configuration is different from the ammonia chiller. Also, the main output of the Goswami cycle is electrical and cooling energy production simultaneously while the ammonia chiller only produces cooling energy.

8) Author mentioned, the innovations of this paper are as follows, and the all components/processes mentioned are available in the literature. They should not call it as innovation. The language of manuscript need to address accordingly

Ans. This innovation has been deleted, and the second innovation has been updated as follows:

- **Energy, exergy, economic, exergoenvironmental, and environmental analyses of the multigeneration system to produce electrical, cooling, potable water, hydrogen, and NaClO simultaneously**
- **Establish a relationship between environmental negative effects and economics by considering the social cost of environmental pollution.**

9) In assumptions, they considered geothermal temperature 120C without any geological information. They should provide geological chart and point out the location of proposed study.

Ans. This assumption has been revised as shown below:

- 1- The geothermal working fluid pressure, temperature, and mass flow rate are equal to 2 bar, 120 °C, and 15 kg/s, respectively. The location of geothermal wells is in the Bandar Abbas city located in the southern of Iran. The type of geothermal resource is hydrothermal.**

10) The pressure loss is neglected....considering geothermal and pressure losses neglected is not acceptable in simulation work. It will have very high impact in terms of depth. They should include this factor in simulation instead neglecting it.

Ans. The neglecting of pressure is related to the Goswami cycle and the RO system. For the geothermal loop, the 3% pressure loss is considered which is compatible with the following reference:

M.A.Ehyaei, A. Ahmadi, M. El Haj Assad, Marc A. Rosen. Investigation of an integrated system combining an Organic Rankine Cycle and absorption chiller driven by geothermal energy: Energy, exergy, and economic analyses and optimization. Journal of Cleaner Production 258 (2020) 120780.

11) Table 3 is just 1st law analysis that don't exist in real world. They should include proper hear transfer coefficient and other correlations for ammonia system. For example, <https://doi.org/10.1016/j.ijrefrig.2019.04.008> article provide detailed model for ammonia chiller and author should conduct proper analysis.

Ans. For calculating the overall surface area of heat exchangers, the logarithmic method is applied. The U values for various heat exchangers (separator, boiler, heat exchanger, and absorber) are presented in Table 11 of the paper. The following text has been added:

For estimating the surface area of the heat exchanger, the logarithmic method is applied. In this regard, the following equation is considered [81]:

$$\dot{Q} = UAF_t\Delta T_{In} \quad (29)$$

where $\dot{Q}$, U , A , F_t , and ΔT_{In} are the heat transfer rate, overall heat transfer coefficient, surface area, correction factor, and logarithmic mean temperature difference. The overall heat transfer coefficient for various components is shown in Table 10 [50]. The method for estimating the volume of the separator is explained in Ref. [82].

Table 11. U values for various components

No.	Components	$U(W/m^2K)$
1	Separator	300
2	Boiler	500
3	Heat exchanger	700
4	Absorber	800

12) Similarly, table 4 is also just a 1st law analysis of RO ignoring all losses and proper membrane impact.

Ans. The net pressure throughout the membranes is equal to net pressure of the RO pump that is calculated by equation 11. Since the outlet pressure of the RO pump is very high to allow the seawater flow through the membranes, neglecting the pressure loss is compatible with the real data. The equation is shown below:

The net pressure of the RO pump is calculated by [49, 56]:

$$\Delta P = \frac{\dot{m}_{PW}}{K_W A_m} + \Delta \pi \quad (11)$$

A_m is the membrane area.

13) Table 13 and 14 references are missing.

Ans. The references have been added to both tables as shown below:

Table 13. Four scenarios and air pollution production [91]

Table 14. Input information of the simulation code

Parameter	Unit	Value	Ref
X_1	-	0.53	[45]
X_4	-	0.94	[45]
X_5	-	0.99	[45]
$\dot{m}_1$	kg/s	0.4	-
T_1	K	280	[45]
T_5	K	348	[45]
T_7	K	278	[45]
P_1	kPa	202.6	[45]
P_2	kPa	3039	[45]
x_{16}	mg/l	40200	[92]
x_{27}	mg/l	150	[92]
A_m	m ²	35.3	[93]
RR	-	0.3	[56]
$\dot{m}_{16}$	kg/s	2	-

14) Author's results Fig 4 is contradicting with Table 3. Their results shows geothermal system energetic and exergetic efficiency 12% and 19% respectively. In Table 3 its was quoted as 34% and 43% respectively. They have to check their model and results carefully.

Ans. The Table 3 in the paper only shows the related equation. The figure 4 shows values of energy and exergy efficiencies.

15) Fig 10 legends are missing.

Ans. The legend has been added to the Figure 10 as shown below:

Figure 10. Amount of CO₂, SO₂, NO_x produced in the four scenarios

16) More explanation of result is required.

Ans. Several paragraphs and sentences have been added to the result and discussion section as highlighted in yellow in the revised paper.

17) Overall English need to improve.

Ans. Thank you for your valuable comment. The text has been reviewed to improve the English.

Research highlights

- A novel desalination multigeneration system powered by geothermal energy is proposed
- 5E analyses of multigeneration system producing electricity, cooling, potable water, hydrogen and NaClO
- The cogeneration system combines geothermal energy with reverse osmosis and electrolysis process
- The system energy and exergy efficiencies are equal to 12.25% and 19.6%
- The payback period time of this system is equal to 2.7 years

Energy, Exergy, Economic, Exergoenvironmental, and Environmental analyses of a Multigeneration System to Produce Electricity, Cooling, Potable Water, Hydrogen and Sodium-Hypochlorite

M. A. Ehyaei^{1*}, Simin Baloochzadeh^{2*}, A. Ahmadi³, Stéphane Abanades⁴

¹ Department of Mechanical Engineering, Pardis Branch, Islamic Azad University, Pardis New City
1468995513, Iran;

² Faculty of Technology, University of Sunderland, Sunderland, United Kingdom

³ Iran University of Science and Technology, School of New Technologies, Department of Energy Systems
Engineering, Iran

⁴ Processes, Materials, and Solar Energy Laboratory, PROMES-CNRS, 7 Rue du Four Solaire, 66120, Font-Romeu, France

Corresponding Author: aliehyaei@yahoo.com, <mailto:bg17pm@student.sunderland.ac.uk>

Abstract. One of the necessities of human beings in this century is the potable water supply. This supply has more environmental benefits if the potable water is supplied by renewable energy resources. In this paper, a combination of combined cooling and power system (Goswami cycle), with the reverse osmosis and sodium hypochlorite plant powered by geothermal energy resources is proposed. The products of this system are electrical and cooling energy, potable water, hydrogen and salt. To investigate all of the system aspects, energy, exergy, economic, exergoenvironmental, and environmental analyses are performed. In environmental analysis, the social costs of air pollution are considered. It means that for the same amount of system electrical power produced by non-renewable energy resource power generation systems, the produced air pollution gases and their costs considering the social cost of air pollution are quantified. In this regard, four scenarios are defined. Results show this multi-generation system produces 1.751 GJ/year electrical energy, 1.04 GJ/year cooling energy, 18106.8 m³/year potable water, 7.396 Ton/year hydrogen, and 3.838 Ton/year salt throughout a year. The system energy and exergy efficiencies are equal to 12.25%, and 19.6%. The payback period time of this system is equal to 2.7 years.

Keywords: Goswami Cycle; Reverse Osmosis; Salt; Exergy; Economic; Exergoenvironmental

1. Introduction

Water scarcity is one of the greatest dangers threatening people [1]. This shortage was considered high risk by the World Economic Forum [2]. Around four billion people experience potable water shortage during at least one month of a year and five hundred million experience this all the time year along [3].

Around 0.014% of global amount of water existing on Earth is potable water. The remaining part is brine water or non-accessible. However, the amount of potable water is sufficient, but regarding unequal distribution, some regions such as the middle east suffer from potable water shortage [4].

In addition to the non-equal distribution of potable water, several factors affect the water shortage, such as world population growth, living standard, method of water consumption, agriculture, climate change, and industrial impacts [5].

Thus, supplying potable water is essential for humanity and this can be achieved via desalination. The desalination processes are divided into four main groups: thermal desalination processes [6-9] (multi-stage flash distillation (MSF), multi-effect distillation (MED), vapor-compression evaporation (VC)); membrane processes [10] (reverse osmosis (RO), electrodialysis (ED), membrane distillation (MD)); freezing [11]; and ion exchange - solvent process [12, 13]. The strengths and weaknesses of desalination methods are depicted in Table 1.

Table 1. Strengths and weaknesses of desalination techniques

No.	Techniques	Strength	Weakness	Ref
Thermal desalination processes				
1	MSF	<ul style="list-style-type: none"> Relatively simple Low number moving components High purification Less sensitive to feed water quality The possibility to add more stage to performance improvement 	<ul style="list-style-type: none"> Tube clogging 	[9, 11, 14, 15]
2	MED	<ul style="list-style-type: none"> Less tube corrosion in comparison with MSF Less sensitive to feed water quality Lower power consumption in comparison with MSF Higher efficiency than MSF 	<ul style="list-style-type: none"> Tube clogging 	[9, 15]
3	VC	<ul style="list-style-type: none"> Reliability and simplicity Low operating temperature than MED and MSF Lower tube corrosion 	<ul style="list-style-type: none"> The extra cost for compressor The larger size of the heat exchanger 	[16, 17]
Membrane processes				
4	RO	<ul style="list-style-type: none"> Less corrosion Lower prices Usage of turbine recovery 	<ul style="list-style-type: none"> Clogging of membrane The requirement of a large quantity of water 	[9, 15]
5	ED	<ul style="list-style-type: none"> High recovery The proportion of energy requirement to salt removing 	<ul style="list-style-type: none"> Non-suitable for water with particles less than 0.4 g/L Non-affordable for water with particles higher than 30 g/L Low chemical usage for pre-treatment 	[9, 18]
6	MD	<ul style="list-style-type: none"> Simplicity Less operating temperature 	<ul style="list-style-type: none"> More space requirement Same energy usage with MSF and MED Needs for feed water with no organic pollutant 	[9, 15]
Freezing				

7	Freezing	<ul style="list-style-type: none"> • Lower energy requirement • Low corrosion • Very pure potable water 	<ul style="list-style-type: none"> • Hardly moving of ice and water mixture 	[9, 19]
Ion exchange - the solvent process				
8	Ion exchange - the solvent process	<ul style="list-style-type: none"> • Low cost • Simplicity • Operation easily 	<ul style="list-style-type: none"> • Long production cycle • Poor quality product • Large PH changes 	[20]

Based on a survey carried out by Shahzad et al. [21], the potable water demand will increase up to 60 billion m³ by 2050. This huge amount of water production can be achieved with different types of desalination systems so that the total energy consumption of desalination systems reaches 75.2 TWh per year. Moreover, it was recommended to improve the thermodynamic efficiency of the desalination systems from 10% to 25%, develop high flux membrane material for RO system, and design high-efficiency hybrid MED/MSF desalination systems.

It is preferable that the thermal and electrical energy needs of the various kinds of desalination system can be met by renewable energy resources due to elimination of pollution during operation time and depletion of non-renewable energy resources such as gas, oil, coal, etc. [22].

Among renewable energy resources, geothermal energy has a high potential for use in industrial and residential applications based on the mass flow rate, temperature, and pressure of geothermal fluid [23]. These applications are divided into many categories such as electrical [24], hydrogen [25], heating and cooling [26], and freshwater productions [27], as well as, cogeneration/multigeneration systems which have two or more products [28].

Hybrid cogeneration of the solar and geothermal based system with ammonia fuel cell was examined for electricity, hydrogen, cooling, and fresh-water production. By this configuration, 42.3 % and 21.3% energy and exergy efficiency were achieved in this hybrid system. In addition, the effects of different parameters on the system performance were studied by parametric analyses of the total system and associated subsystems [29].

A modified Kalina cycle was integrated with a reverse osmosis system to provide heating, cooling and power, and potable water. In this investigation, energy and exergy analyses were examined to evaluate its performance. The results of this investigation showed that the system can generate 46.77 kW electricity, 451 kW heating, 52 kW cooling, and 0.79 kg/s potable water. Also, it was

concluded that the thermodynamic properties of the steam cycle were dominant because these parameters can affect both the steam cycle and the Kalina cycle [30].

Integration of a photovoltaic system and geothermal source was examined to provide 840 kW electricity, heating, 5.295 kg/s biogas, and 2.773 kg/s desalinated water. The mixed fluid cascade cycle was employed for methane liquefaction. Its specific power consumption was reduced to 0.1888 kWh/kg LNG by application of an absorption refrigeration system. The energy and exergy efficiencies of this integrated system were 73.2% and 76.8%, respectively [31].

In a study carried out by Behnam et al. [32], exergy and thermo-economic analysis of a novel low-temperature geothermal heat resource for electricity, hot water, and fresh-water production were examined. Moreover, the sensitivity of decision parameters on the performance of this system was also analyzed. The results of this study showed that by using 100 °C geothermal water, this system was able to produce 0.662 kg/s freshwater, 161.5 kW power, and 246 kW heat load.

A multi-effect distillation (MED) desalination plant of 9000 m³/day with solar (parabolic trough collectors) and geothermal energy resources was examined in Spain. The theoretical results of this study revealed that this amount of fresh water was obtained during 76% of the annual time with both solar and geothermal resources (at 490 m depth) and a hot water temperature of 41.8 °C. However, the results of this study revealed by considering a gradient temperature of 8.87 °C per 100 m depth, just geothermal energy at depth of 790 m was enough to obtain working temperature of the desalination plant at 70 °C [33].

The application of a humidification-dehumidification (HDH) unit in a flash-binary geothermal heat source at 170 m was examined in a new tri-generation system for power, cooling, and freshwater production. The results of this study showed that the increment of the steam turbine output power, overall cooling load, gain-output-ratio (TGOR), and exergy efficiency of this system was around 77.1%, 87%, 8.2%, and 46.4%, respectively. The overall exergy destruction of this tri-generation system at the base mode was 946.7 kW. The recovery heat exchanger was recognized as the most destructive component in the base mode with exergy destruction of 308.5 kW [34].

An integrated system containing parabolic trough solar collectors and wind turbines was examined by Makkah et al. [35]. The benefits of a membrane-thermal desalination system to produce power and freshwater were pointed out. This proposed cogeneration system was employed for providing

electrical power and fresh water in Iran by three types of desalination system consisting of the Reverse Osmosis (RO), Multi-effect distillation (MED), and Thermal Vapor Compression (TVC). The obtained results from exergy analysis demonstrated that the exergy destruction of the solar collectors and wind turbines contributed by 39.5% and 22.2%, respectively. The results of multi-objective particle swarm optimization revealed that the exergy efficiency and the cost of freshwater production reach 26.2% and 3.08 US\$/m³. The environmental assessments showed that this hybrid system avoids 52164 tons of CO₂ emission per year.

A solar organic Rankine cycle (ORC) was employed for power generation and freshwater production by reverse osmosis (RO) desalination units in a power scale less than 500 kW. The performance of the ORC/RO desalination set-up was improved by using a cascade ORC/ORC system. Salinity-gradient solar pond (SGSP) was used instead of the conventional solar collector. These results showed that the ORC/ORC/RO system had the highest performance along with the lowest SUCP (sum unit cost of product) and total exergy destruction. Furthermore, the most economical month was June due to the low value of SUCP (72.42 \$/kWh) since more freshwater was produced in this month [36].

Thermodynamic and thermo-economic performances of a hybrid solar and biomass power plant producing electricity, freshwater, and domestic hot water requirements for a 40 households' community were studied by Mouaky et al [37]. The considered community was located in a semi-arid region in Morocco characterized by a good solar potential of 2239 kWh/m²/y and by the presence of brackish groundwater. In parabolic solar collectors and boilers, olive waste residues as feedstock were applied as a working fluid to run a 46 kW ORC and RO unit. The results showed that this proposed system was able to meet the community's requirements with an annual biomass consumption of 235 tons and a solar share of 11.4%. Moreover, this investigation showed that the monthly plant's overall energy efficiency was in a range between 11.3 and 16.3%, while its corresponding exergy efficiency was between 5.3 and 6.0%.

Application of a solar dish collector integrating phase change material storage was used for providing thermal energy of a steam power plant with a capacity of 1063 MW. The phase-change material was applied during the night and in the absence of solar thermal sources. In order to prevent heat losses in the condenser, a large part of the dissipated heat was provided to a multi-

effect desalination system. The desalination system produced 8321 kg/s of freshwater by utilizing 2571 MW of waste heat from the steam power plant. The total electrical efficiency of 28.84% and thermal efficiency of 97.2% were obtained for this system [38].

A plant consisting of photovoltaic panels, and supplying a RO unit for freshwater production was examined by Calise et al. [39]. The developed system was extremely profitable: the achieved payback period was about 1.3 years, mainly due to the high capital cost of freshwater in the reference scenario. Remarkable water-saving equivalent to 80% was obtained. For the selected case study, the sensitivity analyses suggested to adopt a solar field area equal to 6,436 m². The economic consideration revealed low pay-back periods for specific costs of the water higher than 7 €/m³.

Design and economic evaluation of solar-powered hybrid multi-effect and reverse osmosis system for seawater desalination were conducted by Filippini et al. [40]. In this study, the possibility of coupling the desalination plant with a photovoltaic (PV) solar farm was investigated to generate electricity at a low cost and in a sustainable way. Data about four locations, namely Isola di Pantelleria (IT), Las Palmas (ES), Abu Dhabi (UAE), and Perth (AUS), have been used to economically test the feasibility of installing the proposed plant, and especially the PV solar farm.

In a research conducted by Sezer et al. [41], the development and performance assessment of new integrated solar, wind, and osmotic power system for multi-generation, based on thermodynamic principles were examined. The results revealed that the overall obtained energy and exergy efficiencies were 73.3% and 30.6%, respectively. The obtained results showed that this system was able to generate 51.6 MW electrical power, 40.2 MW refrigeration load, 559 kg/h hydrogen, and 403.2 L/s freshwater.

An integrated solar-driven membrane distillation system for water purification and energy generation was used by Li et al. [42]. It was found that a system with a solar absorbing area of 1.6 m² coupled with ~0.2 m² of membranes can produce ~4 L of drinkable water and ~4.5 kWh of heat energy (at 45 °C) per day (with an average daily solar exposure of 4 kWh/m²). The economic consideration of this study indicated that this system had a payback time of ~4 years.

The summary of previous studies is reported in Table 2.

Table 2. Various researches about the multi/cogeneration systems

No.	Energy resource	Components	Products	Analysis	Energy efficiency (%)	Exergy efficiency (%)	Cost of products	Ref
1	Solar/Geothermal	RO; PEMFC; ASR; AFC; HSR	Electricity, Freshwater, Hydrogen, and Cooling	Energy/Exergy	42.3	21.3	-	[29]
2	Geothermal	KC, RO	Electricity, Heating, Cooling, and Freshwater	Energy/Exergy	-	38.1	-	[30]
3	Solar/Geothermal	Biogas system, MED, ORC; PV	Bio-liquefied natural gas; Freshwater, Electricity	Energy/Exergy	73.2	76.8	-	[31]
4	Geothermal	ORC; ASR; SSE	Electricity, Hot and Fresh water	Energy/Exergy/ Thermoeconomic	34	43	LCOE= 0.04 \$/kWh LCOW= 29.4 \$/m ³	[32]
5	Solar/Geothermal	PTC; MED	Freshwater	Feasibility study	-	-	-	[33]
6	Geothermal	FGPP; HDH	Electricity/Cooling	Energy/Exergy	46.4	TGOR= 0.9275	-	[34]
7	Solar/Geothermal	MED; PTC; ORC	Electricity; Cooling; Heating; Freshwater; Absorption Chiller	Exergy/Exergoeconomic	-	63	Electricity exergoeconomic cost= 0.1475–0.1722€/kW h Chilled water exergoeconomic cost= 0.1863–0.1888€/kW hex Cooling water exergoeconomic cost= 0.01612–0.01702€/kW hex Freshwater exergoeconomic cost= 0.5695–0.6023€/kW hex.	[34]
8	Solar/Wind	PTC; Wind turbine; MED; RO	Electricity/Fresh water	Energy/ Exergy/ Exergoeconomic	-	26.2	Fresh water cost= 3.08 \$/m ³	[35]
9	Solar	Solar Pond; KC; ORC; RO	Electricity/Freshwater	Thermodynamic/ Thermoeconomic	-	18	SUCP= 101.7 \$/kWh	[36]
10	Solar/Biomass		Electricity/ Freshwater/, domestic hot water (DHW)	Thermodynamic/ Thermoeconomic	11.3-16.3	5.3-6	Electricity cost= 0.231 €/kW Fresh water cost= 0.86 €/m ³ DHW cost= 0.047 €/kW	[37]
11	Solar	SD; PCM; SC; MED	Electricity; Freshwater	Energy/ Exergy	28.8	52.2	-	[38]
12	Solar	PV; RO	Electricity; Freshwater	Economic	-	-	PP = 1.3 years	[39]
13	Solar	PV; MED; RO	Electricity; Fresh water	Economic	-	-	Electricity cost= 0.1 €/kWh Fresh water cost= 0.59 €/m ³	[40]
14	Solar/Wind	Wind Turbine; CPVT; TES; FC; EL; MSF; VCR; PRO	Electricity; Freshwater; Cooling; Hydrogen	Energy/ Exergy	73.3	30.6	-	[41]
15	Solar	ESC; MD	Freshwater	Economic	-	-	PP = 4 years	[42]

Abbreviations: Reverse Osmosis: RO; Proton Exchange Membrane Fuel Cell: PEMFC; Absorption Refrigeration: ASR; Ammonia Fuel Cell: AFC; Organic Rankin Cycle: ORC; Single Stage Evaporator: SSE; Photovoltaic: PV; Levelized Cost of Electricity: LCOE; Levelized Cost of water: LCOW; Parabolic Through Collector: PTC; Trigeration-based Gain-Output-Ratio: TGOR; Flash-Binary Geothermal Power Plant: FGPP; Humidification-Dehumidification unit: HDH; Kalina Cycle: KC; SUCP: Sum Unit Cost of Product; Domestic Hot Water: DHW; PCM: Phase Change Material; Steam Cycle: SC; Solar Dish: SD; PP: Payback Period; CPVT: Concentrated Photovoltaics/Thermal; TES: Thermal Energy Storage; Electrolyzer: EL; Fuel Cell: FC; Multistage Flash Distillation: MSF; Vapor Compression Refrigeration: VCR; Pressure Retarded Osmosis: PRO; Evacuated Solar Collector: ESC

2.1. Novelty of the Research

After careful investigation of the multi/co-generation systems and different products from them, it is clear that the proposed system configuration has not been investigated yet. In this proposed system, three main sub-systems are considered that are power and cooling production (Goswami cycle [43-46]), Reverse Osmosis (RO) with a recovery turbine, hydrogen and sodium hypochlorite (NaClO) production) that are powered by the geothermal energy resource.

Moreover, the products of this system (electrical power, cooling, freshwater, hydrogen, and sodium hypochlorite (NaClO)) are different from the other systems which have been investigated in the literature.

The benefits of the proposed desalination system are varied and the key products are potable water (as main needs for humanity), hydrogen (a key clean fuel for the transportation sector), electrical and cooling energy (as needs for residential, commercial, and industrial applications), and sodium-hypochlorite (a valuable co-product).

Complete analyses covering all aspects of the system including energy, exergy, economic, exergoenvironmental, and environmental have not been considered for any system in the literature.

For the environmental analysis, the relation between environmental detrimental effects and economics is established by considering the social cost of environmental pollution. It is assumed the same amount of electrical power produced by this system is generated by non-renewable power generation systems and the air pollution gases (CO_2 , NO_x , SO_2 , CO) produced by these assumed systems are calculated. In this regard, four scenarios are defined.

By considering the social cost of these harmful gases, the effects of environmentally harmful gases on economics are evaluated.

The innovations of this paper are as follows:

- Energy, exergy, economic, exergoenvironmental, and environmental analyses of the multigeneration system to produce electrical, cooling, potable water, hydrogen, and NaClO simultaneously

- Establish a relationship between environmental negative effects and economics by considering the social cost of environmental pollution.

2. Mathematical Modeling

2.1. Process Description and Assumptions

Figure 1 shows the schematic diagram of the proposed system. This system has three sub-systems consisting of cooling and power production system (Goswami cycle), reverse osmosis (RO) with a recovery turbine, and $H_2/NaClO$ production plant.

The advantage of the Goswami cycle compared to the Kalina cycle is the cooling output, however, with higher temperature source, the Kalina cycle has a better performance [43].

In the power and cooling production system (Goswami cycle), the working fluid is a binary mixture of water and ammonia. This working fluid flows through pump III and it is pressurized (points 1 & 2). After exchanging the heat with the heated lean ammonia-water mixture in the Recovery Heat Exchanger (RHX), it is transferred to the boiler (points 2, 3, 9 & 10). In the boiler, the mixture is heated and it is sent to the rectifier/separator (point 4). In the rectifier/separator, the working fluid is divided into rich and lean mixtures (points 5 & 9). The lean mixture is transferred to the RHX (points 9 & 10). After reducing the pressure in the throttling valve (point 11), it is transferred to the absorber.

The rich mixture is heated in the superheater and it is converted to the superheated steam (point 6). This superheated steam rotates the turbine and generator to produce electrical power. Then, the low-pressure rich mixture goes through the Refrigeration Heat Exchanger (RHE) to produce cooling (points 7 & 8). In the absorber, the lean and rich mixtures are mixed (points 8, 11 & 1).

The energy needs of the boiler and superheater are met to be supplied by the geothermal working fluid. After extraction of the geothermal working fluid from the production well (point 12), it is pressurized in the pump I (point 13) and then flows through the superheater and boiler to warm up the ammonia-water mixture (points 14 & 15).

In the RO, the seawater goes through high-pressure pumps (points 16, 17, 18, 19 & 20), and then it is transferred to the membranes I & II to separate the salt. The potable water (points 21, 23 & 25) is stored in the water storage tank (point 26). The high-pressure drain rotates the recovery

turbine (points 22, 24 & 27) to produce the electrical power (point 28). The part of the low-pressure drain water (point 29) is transferred to the NaClO plant to produce hydrogen and sodium hypochlorite (NaClO) (points 30 & 31).

In this system, the electrical power is produced in the turbine (Goswami cycle) and the recovery turbine. The part of this produced electricity is consumed internally by the pumps I to IV and NaClO plant. The remaining part can be used by consumers. The system Grassman diagram is shown in Figure 2.

Figure 1. Proposed system schematic diagram

Figure 2. Grassman diagram of the system

The following assumptions are considered [23, 43, 47-54]:

- 1- Steady-state operation.
- 2- The pump and turbine polytrophic efficiencies are equal to 85%, respectively.
- 3- The heat exchanger effectiveness factor is 85%.
- 4- The geothermal working fluid pressure, temperature, and mass flow rate are equal to 2 bar, 120°C, and 15 kg/s, respectively. The location of geothermal wells is in the Bandar Abbas city located in the southern of Iran. The type of geothermal resource is hydrothermal.
- 5- The dead state pressure and temperature are 15°C and 1 bar, respectively.
- 6- The potential and kinetic energy are neglected.
- 7- The pressure loss is neglected.
- 8- The process in the throttling valve is adiabatic.
- 9- The recovery ratio in the RO system is 0.3.
- 10- Heat exchangers are shell and tube type.
- 11- In the environmental analysis, air pollution is considered as environmental pollutions.
- 12- The polarization effects are ignored in this study.

2.2. Mass, Concentration, and Energy Balance

Generally, the mass and energy conservation equations are written as follows [55]:

$$\sum_{in} \dot{m} = \sum_{out} \dot{m} \quad (1)$$

$$\dot{Q} - \dot{W} = \sum_P \dot{m} (h_f + (h - h_0)) - \sum_R \dot{m} (h_f + (h - h_0)) \quad (2)$$

In which $\dot{W}$ and $\dot{Q}$ are the work and heat transfer rate, h and $\dot{m}$ are enthalpy and mass flow rate, respectively. Subscripts P, R, f, and 0 mean product, reactant, formation, and dead state, respectively.

The mass, concentration, and energy balance equations for the combined power and cooling system (Goswami cycle) and geothermal loop are shown in Table 3 [56-58].

Table 3. Mass, concentration, and energy balance equations for the Goswami cycle

No.	Components	Mass balance	Energy equation	X
Combined power and cooling system (Goswami cycle)				
1	Pump III (P)	$\dot{m}_1 = \dot{m}_2$	$\dot{W}_{pIII} = \dot{m}_1(h_2 - h_1)$	$X_1 = X_2$
2	Throttling valve	$\dot{m}_{10} = \dot{m}_{11}$	$h_{10} = h_{11}$	$X_{10} = X_{11}$
3	Recovery heat exchanger	$\dot{m}_3 = \dot{m}_2$, $\dot{m}_{10} = \dot{m}_9$	$\dot{m}_{20}(h_9 - h_{10})\eta_{RHX}$ $= \dot{m}_2(h_3 - h_2)$	$X_3 = X_2$ $X_{10} = X_9$
4	Boiler	$\dot{m}_3 = \dot{m}_4$, $\dot{m}_{14} = \dot{m}_{15}$	$\dot{m}_{14}(h_{14} - h_{15})\eta_{Boiler}$ $= \dot{m}_3(h_4 - h_3)$	$X_3 = X_4$
5	Rectifier/ separator (RS)	$\dot{m}_4 = \dot{m}_5 + \dot{m}_9$	$\dot{m}_4 h_4 = \dot{m}_5 h_5 + \dot{m}_9 h_9$	$\dot{m}_4 X_4 = \dot{m}_9 X_9 + \dot{m}_5 X_5$
6	Superheater (SH)	$\dot{m}_5 = \dot{m}_6$ $\dot{m}_{13} = \dot{m}_{14}$	$\dot{m}_{13}(h_{13} - h_{14})\eta_{SH} = \dot{m}_5(h_6 - h_5)$	$X_5 = X_6$
7	Turbine (T)	$\dot{m}_6 = \dot{m}_7$	$\dot{W}_T = \dot{m}_6(h_6 - h_7)$	$X_6 = X_7$
8	Refrigeration heat exchanger (RHE)	$\dot{m}_7 = \dot{m}_8$	$\dot{Q}_{RHE} = \dot{m}_7(h_7 - h_8)$	$X_7 = X_8$
9	Absorber (Abs)	$\dot{m}_8 + \dot{m}_{11} = \dot{m}_1$	$\dot{Q}_{Abs} = \dot{m}_8 h_8 + \dot{m}_{11} h_{11} - \dot{m}_1 h_1$	$\dot{m}_8 X_8 + \dot{m}_{11} X_{11} = \dot{m}_1 X_1$
Geothermal loop				
10	Pump I (P)	$\dot{m}_{12} = \dot{m}_{13}$	$\dot{W}_{pI} = \dot{m}_{12}(h_{12} - h_{13})$	-

In Table 3, $\dot{m}$, h , X , and η mean mass flow rate, enthalpy, ammonia mass ratio, and polytrophic efficiency for rotary equipment (pump and turbine), as well as, effectiveness factor for boiler, superheater, and heat exchangers.

In RO sub-system, the mass and concentration balance equations are as follows [49, 59, 60]:

$$\dot{m}_{SW} = \dot{m}_{BW} + \dot{m}_{PW} \quad (3)$$

$$\dot{m}_{SW}x_{SW} = \dot{m}_{PW}x_{PW} + \dot{m}_{BW}x_{BW} \quad (4)$$

where x is the salt concentration. Subscripts SW , PW , and BW denote seawater, potable water, and brain water, respectively.

The relation between sea and portable water is as follows [49, 59]:

$$\dot{m}_{PW} = RR\dot{m}_{SW} \quad (5)$$

where RR is the recovery ratio.

Osmosis pressure for the three main streams are calculated by [49, 59]:

$$\pi_{SW} = RT \times x_{SW} \quad (6)$$

$$\pi_{PW} = RT \times x_{PW} \quad (7)$$

$$\pi_{BW} = RT \times x_{BW} \quad (8)$$

R is the universal gas constant.

The net pressure in the membrane is calculated by [49, 59]:

$$\Delta\pi = \left(\frac{\pi_{SW} + \pi_{BW}}{2} \right) - \pi_{PW} \quad (9)$$

The water permeability coefficient is calculated by [49, 59]:

$$K_W = \frac{6.84 \times 10^{-8}(18.68 - 0.177x_{BW})}{T_{SW}} \quad (10)$$

The net pressure of the RO pump is calculated by [49, 59]:

$$\Delta P = \frac{\dot{m}_{PW}}{K_W A_m} + \Delta \pi \quad (11)$$

A_m is the membrane area.

The power needs of the RO pump is calculated as [49, 59]:

$$\dot{W}_{P,RO} = \frac{\Delta P \dot{m}_{SW}}{\rho_{SW} \eta_{P,RO}} \quad (12)$$

where ρ is the density.

The mass, concentration, and energy balance equations for the RO sub-system are presented in Table 4.

Table 4. Mass, concentration, and energy balance equations for the RO sub-system

No.	Components	Mass balance	Energy equation	x
1	Pump II	$\dot{m}_{17} = \dot{m}_{19}$	$\dot{W}_{PII} = \dot{m}_{17}(h_{19} - h_{17})$	$x_{17} = x_{19}$
2	Pump IV	$\dot{m}_{18} = \dot{m}_{20}$	$\dot{W}_{PIV} = \dot{m}_{18}(h_{20} - h_{18})$	$x_{18} = x_{20}$
3	Membrane I	$\dot{m}_{19} = \dot{m}_{21} + \dot{m}_{22}$	$\dot{m}_{19}h_{19} = \dot{m}_{21}h_{21} + \dot{m}_{22}h_{22}$	$\dot{m}_{19}x_{19} = \dot{m}_{21}x_{21} + \dot{m}_{22}x_{22}$
4	Membrane II	$\dot{m}_{20} = \dot{m}_{23} + \dot{m}_{24}$	$\dot{m}_{20}h_{20} = \dot{m}_{23}h_{23} + \dot{m}_{24}h_{24}$	$\dot{m}_{20}x_{20} = \dot{m}_{23}x_{23} + \dot{m}_{24}x_{24}$
5	Recovery turbine	$\dot{m}_{27} = \dot{m}_{28}$	$\dot{W}_{\text{Recovery turbine}} = \dot{m}_{27}(h_{27} - h_{28})$	$x_{27} = x_{28}$

In which x means the concentration of salt.

In the NaClO plant, the following reaction happens:

For the NaClO plant, the following relations between temperature and concentration ratio are considered [49, 59]:

$$T_{NaClO} = T_{BW} + 14 \quad (14)$$

$$x_{NaClO} = \frac{1}{6} x_{BW} \quad (15)$$

The power need of the NaClO plant is calculated by [49, 59]:

$$\dot{W}_{NaClO} = \frac{10^{-5}(5.9 \times 3600 \times \dot{m}_{NaClO} \times x_{NaClO})}{1.05} \quad (16)$$

Table 5 shows the mass, concentration, and energy balance equations for the NaClO plant.

Table 5. Mass, concentration, and energy balance equations for the NaClO plant.

Mass balance	$\dot{m}_{29} = \dot{m}_{30} + \dot{m}_{31}$
Concentration balance	$\dot{m}_{29}x_{29} = \dot{m}_{30}x_{30} + \dot{m}_{31}x_{31}$
Energy balance	$\dot{m}_{29}h_{29} + \dot{W}_{NaClO} = \dot{m}_{31}h_{31} + \dot{m}_{30}h_{30}$

The electrical power production equations for the Goswami, Goswami/RO, and system plants are shown below:

$$\dot{W}_{net,Goswami} = \dot{W}_T - \dot{W}_{P,I} - \dot{W}_{P,III} \quad (17)$$

$$\dot{W}_{net,Goswami/RO} = \dot{W}_T + \dot{W}_{recovery\ turbine} - \sum_{i=1}^4 \dot{W}_{P,i} \quad (18)$$

$$\dot{W}_{net,sys} = \dot{W}_T + \dot{W}_{recovery\ turbine} - \sum_{i=1}^4 \dot{W}_{P,i} - \dot{W}_{NaClO} \quad (19)$$

The energy efficiency equations for the Goswami, Goswami/RO, and system plants are defined as:

$$\eta_{en,Gowsami} = \frac{\dot{W}_{net,Goswami}}{\dot{m}_{12}(h_{12} - h_{15})} \quad (20)$$

$$\eta_{en,Gowsami/RO} = \frac{\dot{W}_{net,Goswami/RO} + \dot{m}_{25}h_{25}}{\dot{m}_{12}(h_{12} - h_{15})} \quad (21)$$

$$\eta_{en,system} = \frac{\dot{m}_{31}h_{31} + \dot{m}_{30}h_{30} + \dot{m}_{25}h_{25} + \dot{W}_{net,Goswami/RO/NaClO}}{\dot{m}_{12}(h_{12} - h_{15})} \quad (22)$$

2.3. Exergy Analysis

Exergy analysis is carried out by including four parts which are physical, chemical, kinetic, and potential. Specific exergy equation is written below [61, 62]:

$$e = \sum x_i ex_{chi} + \frac{V^2}{2} + gz + (h - h_0) - T_0(s - s_0) + T_0 \sum x_i R_i \ln y_i \quad (23)$$

e and x are specific exergies and mass fraction. V, g, and z are defined as velocity, gravitational acceleration, and height. h, T, s, y are specific enthalpy, entropy, temperature, and mole fraction. Abbreviations ch, i, and 0 are defined as chemical, species, and dead state condition.

Tables 6, 7, and 8 show the exergy destruction rate and exergy efficiency for each component of the combined power and cooling system and geothermal loop (Goswami cycle), RO, and NaClO plant, respectively.

Table 6. Exergy efficiency and exergy destruction rate for each component of the combined power and cooling system and geothermal loop (Goswami cycle)

No.	Components	Exergy efficiency	Exergy destruction rate (kW)
Combined power and cooling system (Goswami cycle)			
1	Pump III (P)	$\frac{\dot{W}_{P_{III}}}{\dot{m}_1(e_2 - e_1)}$	$\dot{m}_1 e_1 - \dot{m}_2 e_2 + \dot{W}_{P_{III}}$
2	Throttling value	$\frac{\dot{m}_{11} e_{11}}{\dot{m}_{10} e_{10}}$	$\dot{m}_{11} e_{11} - \dot{m}_{10} e_{10}$
3	Recovery heat exchanger	$\frac{\dot{m}_2(e_3 - e_2)}{\dot{m}_{20}(e_9 - e_{10})}$	$\dot{m}_2 e_2 + \dot{m}_9 e_9 - \dot{m}_3 e_3 - \dot{m}_{10} e_{10}$
4	Boiler	$\frac{\dot{m}_3(e_4 - e_3)}{\dot{m}_{11}(e_{14} - e_{15})}$	$\dot{m}_3 e_3 + \dot{m}_{14} e_{14} - \dot{m}_{15} e_{15} - \dot{m}_4 e_4$
5	Rectifier/ separator (RS)	$\frac{\dot{m}_5 e_5 + \dot{m}_9 e_9}{\dot{m}_4 e_4}$	$\dot{m}_4 e_4 - \dot{m}_5 e_5 - \dot{m}_9 e_9$
6	Superheater (SH)	$\frac{\dot{m}_5(e_6 - e_5)}{\dot{m}_6(e_{13} - e_{14})}$	$\dot{m}_{13} e_{13} + \dot{m}_5 e_5 - \dot{m}_6 e_6 - \dot{m}_{14} e_{14}$
7	Turbine (T)	$\dot{m}_6(e_6 - e_7) - \dot{W}_T$	$\frac{\dot{W}_T}{\dot{m}_6(e_6 - e_7)}$
8	Refrigeration heat exchanger (RHE)	$\dot{m}_7(e_7 - e_8) - \dot{Q}_{RHE}(1 - \frac{T_8}{T_0})$	$\frac{\dot{Q}_{RHE}(1 - \frac{T_8}{T_0})}{\dot{m}_7(e_7 - e_8)}$

9	Absorber (Abs)	$\dot{m}_8 e_8 + \dot{m}_{11} e_{11} - \dot{m}_1 e_1 - \dot{Q}_{abs}$	$\frac{\dot{m}_1 e_1}{\dot{m}_8 e_8 + \dot{m}_{11} e_{11} - \dot{Q}_{abs}}$
Geothermal loop			
10	Pump I (P)	$\frac{\dot{W}_{PI}}{\dot{m}_1 (e_{13} - e_{12})}$	$\dot{m}_{12} e_{12} - \dot{m}_{13} e_{13} + \dot{W}_{PII}$

Table 7. Exergy destruction rate and exergy efficiency for each component of the RO system

No.	Components	Exergy efficiency	Exergy destruction rate (kW)
1	Pump II	$\frac{\dot{W}_{PII}}{\dot{m}_{17}(e_{19} - e_{17})}$	$\dot{m}_{17}(e_{17} - e_{19}) + \dot{W}_{PII}$
2	Pump IV	$\frac{\dot{W}_{PIV}}{\dot{m}_{18}(e_{20} - e_{18})}$	$\dot{m}_{18}(e_{18} - e_{20}) + \dot{W}_{PIV}$
3	Membrane I	$\frac{\dot{m}_{21} e_{21}}{\dot{m}_{19} e_{19}}$	$\dot{m}_{19} e_{19} - \dot{m}_{21} e_{21} - \dot{m}_{22} e_{22}$
4	Membrane II	$\frac{\dot{m}_{23} e_{23}}{\dot{m}_{20} e_{20}}$	$\dot{m}_{20} e_{20} - \dot{m}_{23} e_{23} - \dot{m}_{24} e_{24}$
5	Recovery turbine	$\frac{\dot{W}_{recovery\ turbine}}{\dot{m}_{17}(e_{27} - e_{28})}$	$\dot{m}_{27} e_{27} - \dot{m}_{28} e_{28} - \dot{W}_{recovery\ turbine}$

Table 8. Exergy efficiency and exergy destruction rate for each component of the NaClO plant

Exergy efficiency	$\frac{\dot{m}_{31} e_{31}}{\dot{W}_{NaClO}}$
Exergy destruction rate	$\dot{m}_{29} e_{29} + \dot{W}_{NaClO} - \dot{m}_{30} e_{30} - \dot{m}_{31} e_{31}$

The exergy efficiency equations for the Goswami, Goswami/RO, and system are presented below:

$$\eta_{ex,Goswami} = \frac{\dot{W}_{net,Goswami}}{\dot{m}_{12}(e_{12} - e_{15})} \quad (24)$$

$$\eta_{ex,Goswami/RO} = \frac{\dot{W}_{net,Goswami/RO} + \dot{m}_{25} e_{25}}{\dot{m}_{12}(e_{12} - e_{15})} \quad (25)$$

$$\eta_{ex,sys} = \frac{\dot{W}_{net,sys} + \dot{m}_{31} e_{31} + \dot{m}_{30} e_{30} + \dot{m}_{25} e_{25}}{\dot{m}_{12}(e_{12} - e_{15})} \quad (26)$$

2.4. Economic Evaluation

The cogeneration annual income CF is calculated as follows [63, 64]:

$$CF = Y_{power}k_{power} + Y_{cooling}k_{cooling} + Y_{PW}k_{PW} + Y_{NaCl}k_{NaCl} + Y_{H2}k_{H2} \quad (27)$$

where k and Y are products specific cost and annual capacity of system productions. The production costs are shown in Table 9.

Table 9. Specific cost of fuel and products

Specific cost of products	Unit	Value	Ref.
k_{power}	US\$/kWh	0.22	[65]
k_{PW}	US\$/kg	0.0004	[66]
$k_{cooling}$	US\$/kWh	0.07	[67]
k_{NaCl}	US\$/kg	10.5	[68]
k_{H2}	US\$/kg	13.99	[69]

The system investment cost equation is given below [63, 64]:

$$C_0 = K_{Goswami} + K_{Geothermal\ loop} + K_{RO} + K_{NaClO} \quad (28)$$

K is the investment and installation cost of each subsystem shown in Table 10. For the operation and maintenance cost, 3% of the initial cost is considered [63, 64].

Table 10. K values for different components

No.	Components	Cost function	Ref
Combined power and cooling system (Goswami cycle)			
1	Pump	$1120 \dot{W}^{0.8}$	[70-73]

2	Throttling value	<i>Neglected</i>	[50, 74]
3	Heat exchanger	$588 A^{0.8}$	[70-72]
4	Boiler	$588 A^{0.8}$	[70-72]
5	Superheater (SH)	$588 A^{0.8}$	[70-72]
6	Turbine	$4405 \dot{W}^{0.7}$	[70-73]
7	Rectifier/Separator	$\frac{576.1}{397} 10^{(3.4974+0.4485 \log(V_{sep})+0.1074(\log(V_{sep}))^2)} (2.25$ $+ 1.82 \text{ maximum}\{\frac{(P_{sep} + 1)D_{sep}}{2[850 - 0.6(P_{sep} + 1)]} + 0.00315, 1\}$	[75]
8	Absorber (Abs)	$0.322(30000 + 0.75 A^{0.8})$	[66]
Geothermal loop			
9	Pump	$3540 \dot{W}^{0.71}$	[76, 77]
10	Drilling well	$16.5 z^{1.607}$	[78]
RO			
11	Pump	$996 (86400\dot{Q})^{0.8}$	[79]
12	Membrane	50	[67]
13	Tank	$1.14(158,62V_{Tank} + 18321$	[80]
14	Recovery turbine	$52 (86400\dot{Q}\Delta P^{0.8})$	[79]
NaClO Plant			
15	NaClO Plant (Model HD:6000)	45000	[81]

In Table 10, z, D, and V mean depth of geothermal well, diameter, and volume, respectively. Subscript sep denotes separator.

For estimating the surface area of the heat exchanger, the logarithmic method is applied. In this regard, the following equation is considered [82]:

$$\dot{Q} = UAF_t\Delta T_{In} \quad (29)$$

where $\dot{Q}$, U , A , F_t , and ΔT_{In} are the heat transfer rate, overall heat transfer coefficient, surface area, correction factor, and logarithmic mean temperature difference. The overall heat transfer coefficient for various components is shown in Table 10 [50]. The method for estimating the volume of the separator is explained in Ref. [83].

Table 11. U values for various components

No.	Components	$U(W/m^2K)$
1	Separator	300
2	Boiler	500
3	Heat exchanger	700
4	Absorber	800

Since the cost function is based on various years, the effect of inflation can be represented by the following equation [84]:

$$C_n = C_0(1 + i)^n \quad (30)$$

where n is the number of years, and i is the inflation rate which is equal to 3.11% [85].

The simple payback period (SPP) index is calculated by [63, 64]:

$$SPP = \frac{C_n}{CF} \quad (31)$$

The payback period (PP) index can be expressed as [63, 64]:

$$PP = \frac{\ln(\frac{C_F}{CF - r \cdot C_n})}{\ln(1 + r)} \quad (32)$$

where r represents the discount factor (3%).

The Net Present Value (NPV) is obtained as [63, 64]:

$$NPV = CF \frac{(1 + r)^N - 1}{r(1 + r)^N} - C_n \quad (33)$$

N is the project lifetime that is considered 25 years.

The Internal Rate of Return (IRR) is given by [63, 64, 86]:

$$IRR = \frac{CF}{C_n} \left[1 - \frac{1}{(1 + IRR)^N} \right] \quad (34)$$

2.4. Exergoenvironmental Analysis

To investigate the system from the combination of exergy and environmental perspective, exergoenvironmental analysis is considered. The exergoenvironment factor which is affected by the exergy destruction rate is shown below [87-89]:

$$f_{ei} = \frac{\dot{E}_D}{\sum \dot{E}_{in}} \quad (35)$$

In equation (35), subscripts D and in are destruction and input. The environmental damage effectiveness factor can be calculated as [87-89]:

$$\theta_{ei} = f_{ei} \cdot C_{ei} \quad (36)$$

C_{ei} is the exergoenvironmental impact coefficient which is calculated by [87-89]:

$$C_{ei} = \frac{1}{\eta_{ex}} \quad (37)$$

In equation (37), η_{ex} is the system exergy efficiency. The exergoenvironmental impact is expressed as [87-89]:

$$\theta_{eii} = \frac{1}{\theta_{ei}} \quad (38)$$

The exergy stability factor is given by [87-89]:

$$f_{es} = \frac{\dot{E}_D}{\dot{E}_{out} + \dot{E}_D + 1} \quad (39)$$

2.5. Environmental Analysis

To establish the relation between environmental air pollution and economics, the social cost of air pollution is considered. The social cost of air pollution is the cost associated with the harmful

effects of air pollution on society. These effects are including diseases, deaths, etc. This cost can vary from one region to another. Also, the standard of living affects this cost. Further explanations are provided in ref. [90, 91].

The air pollution factors are not limited to these categories. Other sources of pollution such as water, soil, and noise... are existing that are ignored in this work because no data is existing in the literature, and the effects of these pollutions are much lower than air pollution.

In addition, during the components system production, various kinds of environmental pollution are produced that are out of the scope of this work. The environmental pollution produced during the operation time is related to life cycle analysis (LCA) and it can be investigated in future research [90, 91].

In order to establish a relationship between the environmental pollution and economics direct/indirect effect, four scenarios are considered. In all scenarios, it is assumed that the same amount of electrical power produced by the proposed system in this work, is produced by non-renewable energy resource power production systems. These scenarios are as follows:

Scenario I: Natural gas-fueled gas turbine power plant

Scenario II: Gas oil-fueled gas turbine power plant

Scenario III: Coal-fired steam power plant

Scenario IV: Natural gas-fueled gas turbine with heat recovery boiler and steam turbine

The social cost of air pollution for carbon dioxide (CO₂), nitrogen oxide (NO_x), and sulfur dioxide (SO₂) are presented in Table 12 [90, 91]. The four scenarios with air pollution generation are shown in Table 13 [92].

Table 12. Social cost of air pollution for CO₂, NO_x, and SO₂

Pollution	Unit	Values
CO ₂	US\$/kg	0.042
NO _x		7.3
SO ₂		7.4

Table 13. Four scenarios and air pollution generation [92]

Scenario	Power plant types	Fuel	CO ₂ (g/kWh)	NO _x (g/kWh)	SO ₂ (g/kWh)
1	Gas turbine power plant	NG	610	1.1	-
2	Gas turbine power plant	GO	800	1.6	1.4
3	Coal-fired steam power plant	Coal	930	2.1	8.8
4	Gas turbine with heat recovery boiler and steam turbine	NG	510	0.9	-
Abbreviations: NG: Natural gas; GO: Gas oil					

In the proposed system of this study, since the system does not produce any air pollution during the operation time, it can be considered as a benefit of this system. So, cogeneration annual income (CF) can be considered by the following expression to show the effect of the social cost of air pollution:

$$CF = Y_{power}k_{power} + Y_{cooling}k_{cooling} + Y_{PW}k_{PW} + Y_{NaCl}k_{NaCl} + Y_{H_2}k_{H_2} + Y_{CO_2}k_{CO_2} + Y_{SO_2}k_{SO_2} + Y_{NO_x}k_{NO_x} \quad (40)$$

where Y represents the annual air pollution generated by different scenarios depicted in Table 13, and k is the social cost of various air pollutions shown in Table 12.

3. Results and Discussion

3.1. Description of the Simulation Method

After the mathematical modeling of the system, a computer program code was developed in engineering equation solver (EES) software. For the mixture of ammonia/water mixture properties calculation, the subroutine (NH₃H₂O) which is existing in the external library of the EES is used. Other working fluids' properties exist in EES software and they can be used easily by definition of thermodynamic function. The input information of the simulation program is depicted in Table 14.

Table 14. Input information of the simulation code

Parameter	Unit	Value	Ref
X_1	-	0.53	[45]
X_4	-	0.94	[45]
X_5	-	0.99	[45]
$\dot{m}_1$	kg/s	0.4	-
T_1	K	280	[45]
T_5	K	348	[45]
T_7	K	278	[45]
P_1	kPa	202.6	[45]
P_2	kPa	3039	[45]
x_{16}	mg/l	40200	[93]
x_{27}	mg/l	150	[93]
A_m	m ²	35.3	[94]
RR	-	0.3	[59]
$\dot{m}_{16}$	kg/s	2	-

3.2. Model Validation

Since the whole plant has not been investigated yet, the validation of the whole plant by using experimental data is not feasible. Thus, each of the sub-systems has been validated individually.

For validation of the combined power and cooling sub-systems (Goswami cycle), ref. [56] is considered. The input information of that reference is inserted into the computer simulation program. Table 15 shows the results of the comparison between the simulation model of this work with ref. [56].

Table 15. Results of the comparison between the simulation model with ref. [56]

No.	P ₁ (kPa)	P ₂ (kPa)	η_{en}		
			Model	Ref[56]	Error(%)
1	673.6	12124.8	3.54	3.5	1.2
2	673.6	12798.4	2.98	2.8	4.2
3	673.6	13472	2.36	2.2	2.5

The comparison shows that the errors in the three situations are 1.2%, 4.2%, and 2.5%, respectively.

For validation of the RO system, the ref. [59] is considered. The data from the table of that reference is inserted into the computer code. Table 16 shows the comparison between the results of the RO system and ref. [59]. The minimum and maximum errors are 0.7% and 7%, respectively.

For validation of the NaClO plants, the ref. [81] is considered. The electrical power requirement of the NaClO plant is 4 kW while it is 3.78 kW in the computer code developed for this study. The error is around 5.5%. The reason for this error is that the salt concentration in the feed mixture is unknown in ref. [81].

In conclusion, the developed computational code provides consistent results for each process sub-systems, in agreement with the previously published data.

Table 16. Comparison between the results of the RO system and ref. [59]

$\dot{m}_{brin}(\frac{kg}{s})$			$\dot{m}_{PW}(\frac{kg}{s})$			$\dot{W}_{recovery\ turbine}(kW)$			$\dot{W}_{P,RO}(kW)$		
Model	Ref	Error(%)	Model	Ref	Error(%)	Model	Ref	Error(%)	Model	Ref	Error(%)
1.092	1.104	0.7	0.468	0.456	2.6	3.45	3.711	7	8.42	8.96	6

3.3. Energy and Exergy Analyses

Table 17 shows the thermodynamic properties for each point of the system. Table 18 shows the annual system productions. By using this system, 1.075 GJ/year electrical energy, 1.04 GJ/year cooling energy, 18106.8 m³/year potable water, 7.396 Ton/year hydrogen, and 3.838 Ton/year salt are produced annually. The cooling and electrical energy in the combined cooling and power system are close. The ratio of cooling to electrical energy is 0.97 (around unit).

Figure 3 shows the system power production in three configurations (Goswami, Goswami/RO, Goswami/RO/NaClO(global system)). It is clear that by adding the RO and NaClO plants to the system, power production declines to 36.78 and 37.09 kW, respectively due to electrical power consumption of the RO and NaClO plants.

Figure 4 shows the energy and exergy efficiencies for three different configurations (Goswami, Goswami/RO, global system). It can be found that adding the RO system to the Goswami cycle increases the system energy efficiency from 10.2% to 12.4%. From the energy point of view, although adding the RO system to the Goswami cycle reduces the electrical power production, the freshwater is also produced in the system ($\dot{m}_{25h25}$). The amount of this increase overcomes the reduction of the electrical power consumed in the RO system, since it adds the energy rate of the fresh water to the numerator of energy efficiency. From an exergy point of view, adding the RO system to the Goswami cycle is not beneficial, since it reduces the exergy efficiency from 25.6% to 20.2%. It means that the electrical power exergy rate has a higher value than the freshwater

exergy rate. The reason for this phenomenon is that the RO system operates near the dead state (25°C, 101.3 kPa). So, the value of ($\dot{m}_{25}e_{25}$) in equation 25 is low. Adding the NaClO plant to the Goswami/RO reduces the energy and exergy efficiencies slightly from 12.4% and 20.2% to 12.25% and 19.6%, respectively. In both energy and exergy analyses, the penalty of consumed electrical power by the NaClO plant is higher than the products amount of energy and exergy. However, the small amount of electrical power consumed in NaClO plant compensates with the recovery turbine.

Table 17. Thermodynamic properties for each point of the system

No.	$\dot{m}$ (kg/s)	T (K)	P (kPa)	h (kJ/kg)	e (kJ/kg)
1	0.4	280	202.6	-208.9	-20.8
2	0.4	282	3039	-197	-17.62
3	0.4	287.4	3039	-172.5	-17.9
4	0.4	373	3039	1287	320.7
5	0.3429	348	3039	1273	324.1
6	0.3429	378	3039	1437	361.3
7	0.3429	278	202.6	1268	-1.841
8	0.3429	303	202.6	1364	-0.6563
9	0.05714	348	3039	132	26.04
10	0.05714	305	3039	-69.66	2.402
11	0.05714	305	202.6	532.1	-8.933
12	15	393.2	202.6	503.8	52.1
13	15	393.2	263.4	498.6	52.16
14	15	391.9	255.5	444.7	50.9
15	15	379.2	247.8	59.45	38.68
16	2	298.2	101.3	59.45	13.46
17	1	298.2	101.3	59.45	13.46
18	1	298.2	101.3	63.69	13.46
19	1	298.2	4767	63.69	17.98
20	1	298.2	4767	67.49	17.98
21	0.3	298.2	4767	61.83	4.659
22	0.7	298.2	4767	67.49	6.596
23	0.3	298.2	4767	61.83	4.659
24	0.7	298.2	4767	67.49	6.596
25	0.6	298.2	4767	63.05	4.659
26	0.6	298.2	101.3	61.83	0.000242
27	1.4	298.2	4767	57.84	6.596
28	1.4	298.2	303.9	57.84	2.323

29	0.014	298.2	101.3	3932	2.323
30	0.0002568	298.2	101.3	3932	5491
31	0.000133	312.2	101.3	274.7	0.8442

Table 18. Annual system productions

Product	Unit	Values
$W_{\text{net,system}}$	GJ/year	1.0751
Q_{cooling}	GJ/year	1.04
V_{PW}	m ³ /year	18106.8
m_{NaCl}	Ton/year	3.838
m_{H_2}	Ton/year	7.396

Figure 3. System power production in three configurations (Goswami, Goswami/RO, Goswami/RO/NaClO(system))

Figure 4. Energy and exergy efficiencies for three configurations (Goswami, Goswami/RO, global system)

Figure 5 shows the share of the exergy destruction rate for each subsystem. The maximum value is related to the Goswami cycle (87.31%). This is because this subsystem has the highest number of components and it operates at a temperature which is much higher than the two other subsystems. The RO plant has 11.04% of the total system exergy destruction rate. The reason is that the RO system operates at temperature (25°C) near the dead state (15°C, 101.3 kPa). Furthermore, this system has a lower number of components than the Goswami cycle. The lowest portion of the total exergy destruction rate is related to the NaClO plant (1.65%). The reason is that the mass flow rate of the brine water flowing through the NaClO plant is low. Similar to the RO system, this plant operates near the dead state. In general, the addition of these two sub-systems does not induce much exergy destruction on the system.

Figure 5. Share of the exergy destruction rate for each subsystem

3.4. Economic Analysis Results

Figure 6 shows the Net Present Value (NPV) from the Goswami, Goswami/RO, and total system, respectively. The NPV for the Goswami cycle is 0.826 million US dollars. Adding the RO system to the Goswami cycle is not beneficial considering this factor, because it decreases the NPV from 0.826 to 0.6 million US dollars. It means that the extra cost imposed on the system is higher than the product costs during the lifetime of this system. However, adding the NaClO plant is beneficial since the value of the NPV increased significantly from 0.6 to 3.1 (higher than five times). Unlike the RO system, in this case, the production benefits (salt and hydrogen) of the NaClO plant during the lifetime is higher than the initial cost. So, it can be concluded that producing NaClO and H_2 is beneficial from the economic point of view.

Figure 6. The NPV from the Goswami, Goswami/RO, and total system

The values of the Payback Period (PP) and Simple Payback Period (SPP) are shown in Figure 7. Adding the RO system to the Goswami cycle increases the PP and SPP from 4.26 and 3.95 years to 8.86 and 7.68 years, respectively. But adding the NaClO plant decreases these values. In general, the total system PP and SPP (2.7 and 2.56 years) are lower than the Goswami cycle and combination of Goswami and RO.

Figure 8 shows the internal rate of return for the Goswami, Goswami/RO, and the total system. By adding the RO system to the Goswami cycle, the IRR is reduced from 0.25 to 0.12. This reduction is not appropriate. Adding the NaClO plant to Goswami/RO system compensates this reduction (0.12 to 0.39).

From the economic analysis, it is clear that the RO system should be combined with the NaClO plant to bring more benefit to the system.

Figure 7. Values of PP and SPP for the Goswami, Goswami/RO, and the total system

Figure 8. Internal rate of return for the Goswami, Goswami/RO, and the total system

3.5. Exergoenvironmental Analysis Results

Figure 9 shows three exergoenvironmental factors (exergoenvironment (f_{ei}), environmental damage effectiveness (θ_{ei}), and exergy stability (f_{es})) for three configurations (Goswami, Goswami/RO, and total system), respectively.

Figure 9. Exergoenvironment (f_{ei}), environmental damage effectiveness (θ_{ei}), and exergy stability (f_{es}) factors for three configurations (Goswami, Goswami/RO, and total system)

The exergoenvironment factor (f_{ei}) increases by adding the RO and NaClO plant. If equation 35 is considered, it is clear that the denominator of this equation is the same for all three configurations, since in all three states, the energy resource is geothermal energy. However, the numerator of this equation is increased and each system added to the Goswami cycle has an exergy destruction rate. The trend of the environmental damage effectiveness factor (θ_{ei}) is similar to the exergoenvironmental factor (f_{ei}), since the exergy efficiency of the system does not improve by adding the RO and NaClO plants. Thus, this factor is increased due to higher exergy destruction rate and lower exergy efficiency.

The exergy stability factor is increased from 0.83 to 0.85 and 0.86, by adding the RO and NaClO systems to the Goswami cycle. It means that the exergy stability factor for Goswami, Goswami/RO, and the total system are 0.83, 0.85, and 0.86, respectively. This increase is however

not considerable. Considering the related equation (equation 36), it can be concluded that the amount of exergy destruction rate added to the Goswami cycle is higher than the output exergy of the added system. It means that the output exergy of the RO and NaClO system cannot compensate for the exergy destruction produced in these systems.

3.6. Environmental Analysis Results

As mentioned before in the environment section, four scenarios are considered for environmental evaluations.

Figure 10 shows the amount of CO₂, SO₂, NO_x produced by the four scenarios if producing the same amount of electrical power generated by the proposed system in this work. The maximum amount of pollution is related to carbon dioxide (CO₂). The highest amount of CO₂ is related to the third scenario (coal-fired power plant) and the minimum amount of CO₂ is related to the fourth scenario (gas turbine with heat recovery boiler and back-pressure steam turbine). Similar to CO₂, the maximum and minimum amounts of NO_x are related to the third and fourth scenarios.

The first and fourth scenarios do not exhibit any sulfur dioxide production. The maximum amount of SO₂ is related to the third scenario.

Figure 10. Amount of CO₂, SO₂, NO_x produced in the four scenarios

As mentioned before, if the social cost of air pollutions generated by the four scenarios is considered in the economic investigation, due to the absence of air pollution produced by the proposed system in this work, the economic factors (NPV, PP, SPP, IRR) are changed considerably.

Figure 11 shows the amount of NPV if the social cost of air pollution by each scenario is considered. The third scenario displays the maximum amount of NPV, since this scenario generates the maximum amount of air pollution in comparison with other scenarios.

Assuming that the same electrical power of the proposed system is produced by the third scenario and considering the social cost of air pollution, the NPV is changed from 3.1 million US\$ to 3.58 million US\$. If the first, second, and fourth scenarios are considered, this value is changed to 3.17, 3.28, and 3.17 million US\$, respectively. It can be concluded that by inserting the social cost of air pollution, the multigeneration system powered by renewable energy is more beneficial.

Figure 11. Amount of NPV considering the social cost of air pollution by the four scenarios

Figure 12 shows the comparison of PP and SPP between the system and scenarios I to IV when these scenarios produce the same amount of electrical power. By considering the social cost of air pollution, the amounts of PP and SPP are reduced. For example, if the third scenario is considered,

the amount of PP and SPP are reduced from 2.7 and 2.56 years to 2.32 and 2.2 years, respectively. The various amounts of the IRR for the system and four scenarios are shown in Figure 13. The same results can be observed in this figure too. By considering the social cost of air pollution, this factor is improved from 0.39 to 0.41, 0.42, 0.45, and 0.41 for the first to fourth scenario, respectively. The maximum amount of IRR is related to the third scenario that relies on the coal power plant with the highest air pollution impact.

Figure 12. Comparison of PP and SPP between the system and scenarios I to IV

Figure 13. IRR for the system and four scenarios

In general, it can be concluded that if the social cost of air pollution or other sources of pollution is considered in the economic evaluation of the renewable energy powered systems, such multi-generation systems are more economical.

4. Conclusion

This study investigated a combined cogeneration system including the combined power and cooling system (Goswami cycle), Reverse Osmosis (RO), and NaClO production plant. The products of this system are electrical and cooling energy, potable water, hydrogen, and NaClO (salt).

The energy, exergy, economic, exergoenvironmental, and environmental analyses were conducted in this work to assess all of the aspects of this system. For the environmental analysis and establishment of a relationship between environmental pollutions and economics, the social cost of air pollution was considered. In this regard, four scenarios were defined. It is assumed the same amount of electrical power is produced by the non-renewable energy resource power production systems. These systems are gas turbines with natural gas and gas oil fuels, coal fired steam power plants, and natural gas fueled gas turbines with heat recovery boiler and backpressure steam turbine.

The air pollutions generated by these systems are estimated by typical data existing in literature. By considering these social costs as benefits for this proposed system due to the absence of air pollution produced during the operation time, the environmental effect can be highlighted.

Summly, the main results of this research are as follows:

- This system produces 1.075 GJ/year electrical energy, 1.04 GJ/year cooling energy, 18106.8 m³/year potable water, 7.396 Ton/year hydrogen, and 3.838 Ton/year salt are produced annually.
- The system energy efficiency for the Goswami, Goswami/RO, and the total system are equal to 10.2%, 12.4%, and 12.25%, respectively.
- The system exergy efficiency for the Goswami, Goswami/RO, and the total system are equal to 25.6%, 20.2%, and 19.6%, respectively.
- The share of the exergy destruction rate for the Goswami cycle, RO, and NaClO plant are 87.3%, 11.04%, and 1.65%, respectively.
- The system NPV, PP, SPP, IRR are equal to 3.1 million US\$, 2.7 years, 2.56 years, and 0.39, respectively.
- The f_{ei} , Θ_{ei} , f_{es} for the total system are 1.45, 7.43, and 0.86, respectively.
- Adding the NaClO plant to the system is appropriate from economic point of view.
- By considering the social cost of air pollution in economic evaluation, the renewable energy resource multi-generation systems can be more economical.

Nomenclature

Abbreviation	Definition
AFC	Ammonia fuel cell
ASR	Absorption refrigeration
CPVT	Concentrated Photovoltaics/Thermal
DHW	Domestic Hot Water
ED	Electrodialysis, Electrolyzer
ESC	Evacuated Solar Collector
FC	Fuel Cell
FGPP	Flash-Binary Geothermal Power Plant

GO	Gas Oil
HDH	Humidification-Dehumidification unit
KC	Kalina Cycle
LCOE	Levelized Cost of Electricity
LCOW	Levelized Cost of water
MD	Membrane Distillation
MED	Multi-Effect Distillation
MSF	Multi-Stage Flash Distillation
NG	Natural Gas
ORC	Organic Rankin Cycle
PCM	Phase Change Material
PEMFC	Proton Exchange Membrane Fuel Cell
PRO	Pressure Retarded Osmosis
PTC	Parabolic Through Collector
PV	Photovoltaic
RHE	Refrigeration Heat Exchanger
RHX	Recovery Heat Exchanger
RO	Reverse Osmosis
SC	Steam Cycle
SD	Solar Dish
SSE	Single Stage Evaporator
SUCP	Sum Unit Cost of Product
TES	Thermal Energy Storage
TGOR	Trigeneration-based Gain-Output-Ratio
VC	Vapor-Compression Evaporation

Symbols	Unit	Definition
A	m ²	Area
C₀	US\$	System investment cost
C_{ei}	-	Exergoenvironmental impact coefficient
C_n	US\$	System investment cost in the specific year with considering inflation rate
CF	US\$	Cogeneration annual income
D	m	Diameter
e	kJ/kg	Specific exergy
$\dot{E}$	kW	Exergy rate

f_{ei}	-	Exergoenvironment factor
f_{es}	-	Exergy stability factor
F_t	-	Correction factor
g	m/s ²	Gravitational acceleration
h	kJ/kg	Specific enthalpy
IRR	-	Internal rate of return
k	US\$/kWh	Products specific cost
K	US\$	Investment and installation cost of each subsystem
K_w	1/K	Water permeability coefficient
$\dot{m}$	kg/s	Mass flow rate
N	Years	Lifetime of the project
NPV	US\$	Net Present Value
P	kPa	Pressure
PP	Years	Payback Period
$\dot{Q}$	kW	Heat transfer rate
r	-	Discount factor
R	kJ/kmoleK	Global gas constant
RR	-	Recovery ratio
s	kJ/kgK	Specific entropy
SPP	Years	Simple Payback Period
T	°C/K	Temperature
U	W/m ² K	Overall heat transfer coefficient
V	m/s, m ³	Velocity, Volume
$\dot{W}$	kW	Work transfer rate
x	-	Concentration of salt, Mass fraction
X	-	Ammonia mass ratio
y	-	Mole fraction
Y	US\$/kWh, US\$/kg	Annual capacity of system productions
z	m	Height, Depth of geothermal well
Greek Symbols		
η	-	Polytrophic efficiency
$\Delta\pi$	kPa	Net-pressure membrane
θ_{ei}	-	Environmental damage effectiveness factor

θ_{eii}	-	Exergoenvironmental impact
Subscripts		Definition
0		Dead state
BW		Brain water
ch		Chemical
D		Destruction
en		Energy
ex		Exergy
f		Formation
i		Species
in		Inlet
out		Outlet
m		Membrane
P		Product, Pump
PW		Potable water
R		Reactant
Sep		Seperator
SW		Seawater
T		Turbine

References

- [1] The Global Risks Report 2019, [weforum.org/reports/the-global-risks-report-2019](https://www.weforum.org/reports/the-global-risks-report-2019) [Access 03.06.2020], in, 2019.
- [2] M. Ehyaei, S. Hakimzadeh, N. Enadi, P. Ahmadi, Exergy, economic and environment (3E) analysis of absorption chiller inlet air cooler used in gas turbine power plants, *International Journal of Energy Research*, 36 (2012) 486-498.
- [3] M.M. Mekonnen, A.Y. Hoekstra, Four billion people facing severe water scarcity, *Science Advances*, 2 (2016) e1500323.
- [4] How do we prevent today's water crisis becoming tomorrow's catastrophe? [weforum.org/agenda/2017/03/building-freshwater-resilience-to-anticipate-and-address-water-crises](https://www.weforum.org/agenda/2017/03/building-freshwater-resilience-to-anticipate-and-address-water-crises) [Access 03.06.2020] in, 2017.
- [5] C.J. Vörösmarty, P. Green, J. Salisbury, R.B. Lammers, Global Water Resources: Vulnerability from Climate Change and Population Growth, *Science*, 289 (2000) 284-288.
- [6] R.G. Raluy, L. Serra, J. Uche, A. Valero, Life-cycle assessment of desalination technologies integrated with energy production systems, *Desalination*, 167 (2004) 445-458.
- [7] A.D. Khawaji, J.-M. Wie, Potabilization of desalinated water at Madinat Yanbu Al-Sinaiyah, *Desalination*, 98 (1994) 135-146.

- [8] M. Al-Shammiri, M. Safar, Multi-effect distillation plants: state of the art, *Desalination*, 126 (1999) 45-59.
- [9] O.K. Buross, The ABCs of Desalting, in, International Desalination Association, Topsfield, Massachusetts, USA, 2000.
- [10] The Desalting and Water Treatment Membrane Manual: A Guide to Membranes for Municipal Water Treatment, Water Treatment Technology Program, Report No. 1, usbr.gov/research/dwpr/reportpdfs/report001.pdf [Access 03.06.2020], in, the United States Department of the Interior, Bureau of Reclamation, Denver Office, Research and Laboratory Services Division, Applied Sciences Branch (R-93-15), 1993.
- [11] A.D. Khawaji, I.K. Kutubkhanah, J.-M. Wie, Advances in seawater desalination technologies, *Desalination*, 221 (2008) 47-69.
- [12] T. Xu, Ion exchange membranes: State of their development and perspective, *Journal of Membrane Science*, 263 (2005) 1-29.
- [13] J.E. Miller, Review of Water Resources and Desalination Technologies in, Sandia National Laboratories Albuquerque, New Mexico 87185 and Livermore, California 94550 2003.
- [14] M.I.M. Shatat, Solar water desalination, in, , School of Engineering, Durham University, UK, 2008.
- [15] Water Desalination Technologies in the ESCWA Member Countries, in, United Nations. Economic and Social Commission for Western Asia, 2001.
- [16] M.A. Darwish, H. El-Dessouky, The heat recovery thermal vapour-compression desalting system: A comparison with other thermal desalination processes, *Applied Thermal Engineering*, 16 (1996) 523-537.
- [17] S. Karellas, A. Schuster, A. Leontaritis, Influence of supercritical ORC parameters on plate heat exchanger design, *Applied Thermal Engineering*, s 33–34 (2012) 70–76.
- [18] S.A. Kalogirou, Seawater desalination using renewable energy sources, *Progress in Energy and Combustion Science*, 31 (2005) 242-281.
- [19] W. Rice, D.S.C. Chau, Freeze desalination using hydraulic refrigerant compressors, *Desalination*, 109 (1997) 157-164.
- [20] H. Chen, L. Wang, Chapter 8 - Posttreatment Strategies for Biomass Conversion, in: H. Chen, L. Wang (Eds.) *Technologies for Biochemical Conversion of Biomass*, Academic Press, Oxford, 2017, pp. 197-217.
- [21] M.W. Shahzad, M. Burhan, L. Ang, K.C. Ng, Energy-water-environment nexus underpinning future desalination sustainability, *Desalination*, 413 (2017) 52-64.
- [22] H. Mahmoudi, N. Ghaffour, M.F. Goosen, J. Bundschuh, *Renewable energy technologies for water desalination*, CRC Press, 2017.
- [23] M.A. Ehyaei, A. Ahmadi, M. El Haj Assad, M.A. Rosen, Investigation of an integrated system combining an Organic Rankine Cycle and absorption chiller driven by geothermal energy: Energy, exergy, and economic analyses and optimization, *Journal of Cleaner Production*, 258 (2020) 120780.
- [24] M. El Haj Assad, E. Bani-Hani, M. Khalil, Performance of geothermal power plants (single, dual, and binary) to compensate for LHC-CERN power consumption: comparative study, *Geothermal Energy*, 5 (2017) 17.
- [25] H. Kianfard, S. Khalilarya, S. Jafarmadar, Exergy and exergoeconomic evaluation of hydrogen and distilled water production via combination of PEM electrolyzer, RO desalination unit and geothermal driven dual fluid ORC, *Energy Conversion and Management*, 177 (2018) 339-349.
- [26] L. Ozgener, A. Hepbasli, I. Dincer, Energy and exergy analysis of the Gonen geothermal district heating system, Turkey, *Geothermics*, 34 (2005) 632-645.
- [27] M.A. Abdelkareem, M. El Haj Assad, E.T. Sayed, B. Soudan, Recent progress in the use of renewable energy sources to power water desalination plants, *Desalination*, 435 (2018) 97-113.

- [28] V. Zare, A comparative thermodynamic analysis of two tri-generation systems utilizing low-grade geothermal energy, *Energy Conversion and Management*, 118 (2016) 264-274.
- [29] O. Siddiqui, I. Dincer, A new solar and geothermal based integrated ammonia fuel cell system for multigeneration, *International Journal of Hydrogen Energy*, (2020).
- [30] A. Mohammadi, M. Mehrpooya, Energy and exergy analyses of a combined desalination and CCHP system driven by geothermal energy, *Applied Thermal Engineering*, 116 (2017) 685-694.
- [31] B. Ghorbani, A. Ebrahimi, M. Moradi, M. Ziabasharhagh, Energy, exergy and sensitivity analyses of a novel hybrid structure for generation of Bio-Liquefied natural Gas, desalinated water and power using solar photovoltaic and geothermal source, *Energy Conversion and Management*, 222 (2020) 113215.
- [32] P. Behnam, A. Arefi, M.B. Shafii, Exergetic and thermoeconomic analysis of a trigeneration system producing electricity, hot water, and fresh water driven by low-temperature geothermal sources, *Energy Conversion and Management*, 157 (2018) 266-276.
- [33] A. Colmenar-Santos, E. Palomo-Torrejón, F. Mur-Pérez, E. Rosales-Asensio, Thermal desalination potential with parabolic trough collectors and geothermal energy in the Spanish southeast, *Applied Energy*, 262 (2020) 114433.
- [34] T. Gholizadeh, M. Vajdi, H. Rostamzadeh, A new trigeneration system for power, cooling, and freshwater production driven by a flash-binary geothermal heat source, *Renewable Energy*, 148 (2020) 31-43.
- [35] S.A. Makkeh, A. Ahmadi, F. Esmaeilion, M.A. Ehyaei, Energy, exergy and exergoeconomic optimization of a cogeneration system integrated with parabolic trough collector-wind turbine with desalination, *Journal of Cleaner Production*, 273 (2020) 123122.
- [36] A. Shekari Namin, H. Rostamzadeh, P. Nourani, Thermodynamic and thermoeconomic analysis of three cascade power plants coupled with RO desalination unit, driven by a salinity-gradient solar pond, *Thermal Science and Engineering Progress*, 18 (2020) 100562.
- [37] A. Mouaky, A. Racheq, Thermodynamic and thermo-economic assessment of a hybrid solar/biomass polygeneration system under the semi-arid climate conditions, *Renewable Energy*, 156 (2020) 14-30.
- [38] B. Ghorbani, R. Shirmohammadi, M. Mehrpooya, Development of an innovative cogeneration system for fresh water and power production by renewable energy using thermal energy storage system, *Sustainable Energy Technologies and Assessments*, 37 (2020) 100572.
- [39] F. Calise, F.L. Cappiello, R. Vanoli, M. Vicidomini, Economic assessment of renewable energy systems integrating photovoltaic panels, seawater desalination and water storage, *Applied Energy*, 253 (2019) 113575.
- [40] G. Filippini, M.A. Al-Obaidi, F. Manenti, I.M. Mujtaba, Design and economic evaluation of solar-powered hybrid multi effect and reverse osmosis system for seawater desalination, *Desalination*, 465 (2019) 114-125.
- [41] N. Sezer, M. Koç, Development and performance assessment of a new integrated solar, wind, and osmotic power system for multigeneration, based on thermodynamic principles, *Energy Conversion and Management*, 188 (2019) 94-111.
- [42] Q. Li, L.-J. Beier, J. Tan, C. Brown, B. Lian, W. Zhong, Y. Wang, C. Ji, P. Dai, T. Li, P. Le Clech, H. Tyagi, X. Liu, G. Leslie, R.A. Taylor, An integrated, solar-driven membrane distillation system for water purification and energy generation, *Applied Energy*, 237 (2019) 534-548.
- [43] F. Xu, Analysis of a novel combined thermal power and cooling cycle using ammonia-water mixtures as a working fluid, in, University of Florida, 1997.
- [44] G. Tamm, D.Y. Goswami, S. Lu, A.A. Hasan, Novel Combined Power and Cooling Thermodynamic Cycle for Low Temperature Heat Sources, Part I: Theoretical Investigation, *Journal of Solar Energy Engineering*, 125 (2003) 218-222.
- [45] D.Y. Goswami, F. Xu, Analysis of a New Thermodynamic Cycle for Combined Power and Cooling Using Low and Mid Temperature Solar Collectors, *Journal of Solar Energy Engineering*, 121 (1999) 91-97.

- [46] G. Tamm, D.Y. Goswami, S. Lu, A.A. Hasan, Theoretical and experimental investigation of an ammonia–water power and refrigeration thermodynamic cycle, *Solar Energy*, 76 (2004) 217-228.
- [47] A. Behzadi, E. Gholamian, P. Ahmadi, A. Habibollahzade, M. Ashjaee, Energy, exergy and exergoeconomic (3E) analyses and multi-objective optimization of a solar and geothermal based integrated energy system, *Applied Thermal Engineering*, 143 (2018) 1011-1022.
- [48] S.M. Alirahmi, S. Rahmani Dabbagh, P. Ahmadi, S. Wongwises, Multi-objective design optimization of a multi-generation energy system based on geothermal and solar energy, *Energy Conversion and Management*, 205 (2020) 112426.
- [49] R. Yargholi, H. Kariman, S. Hoseinzadeh, M. Bidi, A. Naseri, Modeling and advanced exergy analysis of integrated reverse osmosis desalination with geothermal energy, *Water Supply*, 20 (2020) 984-996.
- [50] B.H. Gebreslassie, G. Guillén-Gosálbez, L. Jiménez, D. Boer, Design of environmentally conscious absorption cooling systems via multi-objective optimization and life cycle assessment, *Applied Energy*, 86 (2009) 1712-1722.
- [51] A. Al-Zahrani, J. Orfi, Z. Al-Suhaibani, B. Salim, H. Al-Ansary, Thermodynamic Analysis of a Reverse Osmosis Desalination Unit with Energy Recovery System, *Procedia Engineering*, 33 (2012) 404-414.
- [52] A. Ahmadi, M. El Haj Assad, D.H. Jamali, R. Kumar, Z.X. Li, T. Salameh, M. Al-Shabi, M.A. Ehyaei, Applications of geothermal organic Rankine Cycle for electricity production, *Journal of Cleaner Production*, 274 (2020) 122950.
- [53] E. Ghasemian, M.A. Ehyaei, Evaluation and optimization of organic Rankine cycle (ORC) with algorithms NSGA-II, MOPSO, and MOEA for eight coolant fluids, *International Journal of Energy and Environmental Engineering*, 9 (2018) 39-57.
- [54] M.A. Ehyaei, A. Ahmadi, M.A. Rosen, A. Davarpanah, Thermodynamic Optimization of a Geothermal Power Plant with a Genetic Algorithm in Two Stages, *Processes*, 8 (2020) 1277.
- [55] A. Bejan, *Advanced engineering thermodynamics*, John Wiley & Sons, 2016.
- [56] G. Demirkaya, R.V. Padilla, A. Fontalvo, M. Lake, Y.Y. Lim, Thermal and Exergetic Analysis of the Goswami Cycle Integrated with Mid-Grade Heat Sources, *Entropy*, 19 (2017) 416.
- [57] F. Xu, D.Y. Goswami, S.S. Bhagwat, A combined power/cooling cycle, *Energy*, 25 (2000) 233-246.
- [58] D.Y. Goswami, F. Xu, Analysis of a new thermodynamic cycle for combined power and cooling using low and mid temperature solar collectors, (1999).
- [59] A. Naseri, M. Bidi, M.H. Ahmadi, Thermodynamic and exergy analysis of a hydrogen and permeate water production process by a solar-driven transcritical CO₂ power cycle with liquefied natural gas heat sink, *Renewable Energy*, 113 (2017) 1215-1228.
- [60] H.T. El-Dessouky, H.M. Ettouney, *Fundamentals of salt water desalination*, Elsevier, 2002.
- [61] A. Lazzaretto, G. Tsatsaronis, SPECO: a systematic and general methodology for calculating efficiencies and costs in thermal systems, *Energy*, 31 (2006) 1257-1289.
- [62] A. Bejan, G. Tsatsaronis, M. Moran, *Thermal Design and Optimization* John Wiley and Sons, Inc. New York, (1996).
- [63] E. Bellos, S. Pavlovic, V. Stefanovic, C. Tzivanidis, B.B. Nakomcic-Smaradgakis, Parametric analysis and yearly performance of a trigeneration system driven by solar-dish collectors, *International Journal of Energy Research*, 43 (2019) 1534-1546.
- [64] C. Tzivanidis, E. Bellos, K.A. Antonopoulos, Energetic and financial investigation of a stand-alone solar-thermal Organic Rankine Cycle power plant, *Energy conversion and management*, 126 (2016) 421-433.
- [65] H. Nami, I.S. Ertesvåg, R. Agromayor, L. Riboldi, L.O. Nord, Gas turbine exhaust gas heat recovery by organic Rankine cycles (ORC) for offshore combined heat and power applications-Energy and exergy analysis, *Energy*, 165 (2018) 1060-1071.
- [66] M. Mishra, P.K. Das, S. Sarangi, Optimum design of crossflow plate-fin heat exchangers through genetic algorithm, (2004).

- [67] A. Ahmadi, D.H. Jamali, M.A. Ehyaei, M.E.H. Assad, Energy, exergy, economic and exergoenvironmental analyses of gas and air bottoming cycles for production of electricity and hydrogen with gas reformer, *Journal of Cleaner Production*, 259 (2020) 120915.
- [68] <https://www.flinnsci.com/sodium-chloride-laboratory-grade-500-g/s0063/> [Access 03.06.2020], in, 2020.
- [69] H. Nami, E. Akrami, Analysis of a gas turbine based hybrid system by utilizing energy, exergy and exergoeconomic methodologies for steam, power and hydrogen production, *Energy Conversion and Management*, 143 (2017) 326-337.
- [70] J.C.E.P. Carlos Eymel Campos Rodríguez, César Rodríguez Sotomonte, Marcio Lemea, Osvaldo J. Venturinia, Electro E. Silva Lora, Vladimir Melián Cobasa, Daniel Marques dos Santosb, Fábio R. Lofrano Dottoc, Vernei Giallucad, Exergetic and economic analysis of Kalina cycle for low temperature geothermal sources in Brazil, in: *The 25th international conference on efficiency, cost, optimization, simulation and environmental impact of energy systems*, Perugia, Italy, 2012, pp. 1-13.
- [71] P. Dorj, Thermoeconomic Analysis of a New Geothermal Utilization CHP Plant in Tsetserleg, in: *Department of Mechanical and Industrial Engineering, Iceland, University of Iceland*, 2005.
- [72] A. Bejan, G. Tsatsaronis, M.J. Moran, *Thermal design and optimization*, John Wiley & Sons, 1995.
- [73] K. Bahloul, R. Khoshbakhti Saray, N. Sarabchi, Parametric investigation and thermo-economic multi-objective optimization of an ammonia–water power/cooling cycle coupled with an HCCI (homogeneous charge compression ignition) engine, *Energy*, 86 (2015) 672-684.
- [74] L.S. Vieira, J.L. Donatelli, M.E. Cruz, Exergoeconomic improvement of a complex cogeneration system integrated with a professional process simulator, *Energy Conversion and Management*, 50 (2009) 1955-1967.
- [75] R. Turton, R.C. Bailie, W.B. Whiting, J.A. Shaeiwitz, *Analysis, synthesis and design of chemical processes*, Pearson Education, 2008.
- [76] J.L. Silveira, C.E. Tuna, Thermoeconomic analysis method for optimization of combined heat and power systems. Part I, *Progress in Energy and Combustion Science*, 29 (2003) 479-485.
- [77] M. Ameri, P. Ahmadi, A. Hamidi, Energy, exergy and exergoeconomic analysis of a steam power plant: A case study, *International Journal of Energy Research*, 33 (2009) 499-512.
- [78] M.L. Koenraad F. Beckers, Timothy J. Reber, Brian J. Anderson, Michal C. Moore, Jefferson W. Tester, Introducing geophires V1.0 software package for estimating levelized cost of electricity and/or heat from enhanced geothermal systems, in: *Thirty-Eighth Workshop on Geothermal Reservoir Engineering*, Stanford University, Stanford, California, USA, 2012.
- [79] Y. Du, L. Xie, J. Liu, Y. Wang, Y. Xu, S. Wang, Multi-objective optimization of reverse osmosis networks by lexicographic optimization and augmented epsilon constraint method, *Desalination*, 333 (2014) 66-81.
- [80] Establishment of cost functions for construction of various types of public water services assets in Portugal, in, 2003.
- [81] Sodium hypochlorite production plant of chlorination system chemical production plant [alibaba.com/product-detail/Sodium-hypochlorite-production-plant-of-chlorination_60489161719](https://www.alibaba.com/product-detail/Sodium-hypochlorite-production-plant-of-chlorination_60489161719) [Access 03.06.2020], in, 2020.
- [82] L. Pierobon, T.-V. Nguyen, U. Larsen, F. Haglind, B. Elmegaard, Multi-objective optimization of organic Rankine cycles for waste heat recovery: Application in an offshore platform, *Energy*, 58 (2013) 538-549.
- [83] S.J. Zarrouk, M.H. Purnanto, Geothermal steam-water separators: Design overview, *Geothermics*, 53 (2015) 236-254.
- [84] T. Shafer, Calculating Inflation Factors for Cost Estimates, in, *City of Lincoln Transportation and Utilities Project Delivery*.
- [85] Statista, Global inflation rate compared to previous year, in.
- [86] S. Edalati, M. Ameri, M. Iranmanesh, H. Tarmahi, M. Gholampour, Technical and economic assessments of grid-connected photovoltaic power plants: Iran case study, *Energy*, 114 (2016) 923-934.

- [87] T.A. Ratlamwala, I. Dincer, M.A. Gadalla, Comparative environmental impact and sustainability assessments of hydrogen and cooling production systems, in: *Causes, Impacts and Solutions to Global Warming*, Springer, 2013, pp. 389-408.
- [88] T.A. Ratlamwala, I. Dincer, B.V. Reddy, Exergetic and Environmental Impact Assessment of an Integrated System for Utilization of Excess Power from Thermal Power Plant, in: *Causes, Impacts and Solutions to Global Warming*, Springer, 2013, pp. 803-824.
- [89] A. Midilli, I. Dincer, Development of some exergetic parameters for PEM fuel cells for measuring environmental impact and sustainability, *International Journal of Hydrogen Energy*, 34 (2009) 3858-3872.
- [90] J.S. David Birchby, Sally Whiting,, M. Vedrenne, Air Quality damage cost update 2019, in, 2019.
- [91] S. Karkour, Y. Ichisugi, A. Abeynayaka, N. Itsubo, External-Cost Estimation of Electricity Generation in G20 Countries: Case Study Using a Global Life-Cycle Impact-Assessment Method, *Sustainability*, 12 (2020) 2002.
- [92] Combined Heat and Power (CHP) Developers Guides in, United Kingdom Government Department of Energy & Climate Change 2009.
- [93] H.I. Emara, Nutrient salts, inorganic and organic carbon contents in the waters of the Persian Gulf and the Gulf of Oman, *Journal of the Persian Gulf*, 1 (2010) 33-44.
- [94] FILMTEC™ Membranes How to Evaluate the Active Membrane Area of Seawater Reverse Osmosis Elements, [dupont.com/content/dam/dupont/amer/us/en/water-solutions/public/documents/en/45-D01504-en.pdf](https://www.dupont.com/content/dam/dupont/amer/us/en/water-solutions/public/documents/en/45-D01504-en.pdf) [Access 03.06.2020] (2015).